

## **2. PITTSBURGH NO. 8 COAL**

This section is dedicated to the design and cost estimate for a hydrogen plant fed with Pittsburgh No. 8 bituminous coal. This coal is characterized having high volatility, low ash and moisture content, and high as-received heating value. The high sulfur content results in a significant value-added from the sulfuric acid byproduct.

### **2.1 HEAT AND MATERIAL BALANCE**

The heat and material balance for the IGCC plant is based on the maximum hydrogen production from 2,500 tons per day of dry coal. Ambient operating conditions are indicated in the plant design basis. The pressurized entrained flow E-Gas™ two-stage gasifier uses a coal/water slurry and oxygen to produce a medium heating value fuel gas. The syngas produced in the gasifier first stage at about 2450°F (1343°C) is quenched to 1900°F (1038°C) by reacting with slurry injected into the second stage. The syngas passes through a fire tube boiler syngas cooler and leaves at 1300°F (704°C). A second gas cooler in series cools the gas further to 645°F (341°C). High-pressure saturated steam is generated in the syngas coolers and is joined with the main steam supply. The process flow diagram resulting from the heat and material balance is shown as Figure 2-1.

The gas goes through a series of additional gas coolers and cleanup processes including a scrubber. Slag captured by the syngas scrubber is recovered in a slag recovery unit.


The syngas stream from the syngas scrubber enters the high-temperature shift converter, which contains a bed of sulfided shift catalyst. The shift reaction converts over 80 percent of the CO to hydrogen and CO<sub>2</sub> and hydrolyzes COS to H<sub>2</sub>S. Following the shift converter, the cooled gas stream passes through a proprietary amine acid gas removal (AGR) process, which removes H<sub>2</sub>S and some of the CO<sub>2</sub>. The clean gas stream then passes through the pressure swing adsorption (PSA) for final purification of the hydrogen. Regeneration gas from the PSA contains fuel value, and is fed to the heat recovery steam generator (HRSG). Regeneration gas from the AGR plant is fed to a sulfuric acid plant.

The cryogenic oxygen plant supplies 99 percent pure oxygen to the gasifiers at the rated pressure. A dedicated air compressor provides air supply for the oxygen plants.

The steam cycle is based on maximizing heat recovery from the gasifier cooler and HRSG, as well as utilizing steam generation opportunities in the shift process.

The steam turbine selected to match this cycle is a two-casing, reheat, double-flow (exhaust) machine, exhausting downward to the condenser. The HP and IP turbine sections are contained in one casing, with the LP section in a second casing. The steam turbine drives a 3600 rpm hydrogen-cooled generator. The turbine exhausts to a single-pressure condenser operating at a nominal 1.2 psia at the 100 percent load design point. Two 50 percent capacity, motor-driven pumps are provided for feedwater and condensate.

Figure 2-1



Overall performance for the entire plant is summarized in Table 2-1, which includes auxiliary power requirements. The net plant output power, after plant auxiliary power requirements are deducted, is nominally 38 MW<sub>e</sub>. The overall plant thermal effective efficiency (thermal value of hydrogen and power produced) is 62.3 percent, on an HHV basis.

**Table 2-1**  
**Plant Performance Summary**  
**Hydrogen Production from Pittsburgh No. 8 Coal**


<b>Plant Output</b>			
Steam Turbine Power	78,460	kW <sub>e</sub>	
<b>Total</b>	<b>78,460</b>	<b>kW<sub>e</sub></b>	
<b>Hydrogen Production</b>			
Hydrogen Product	26,049	lb/h	
<b>Auxiliary Load</b>			
Gasifier O <sub>2</sub> Compressor	9,470	kW <sub>e</sub>	
ASU Air Compressor	21,720	kW <sub>e</sub>	
Gasifier Slurry Pump	190	kW <sub>e</sub>	
Coal Handling	210	kW <sub>e</sub>	
Slag Handling	530	kW <sub>e</sub>	
Amine Unit	300	kW <sub>e</sub>	
Recycle Compressor	220	kW <sub>e</sub>	
H <sub>2</sub> SO <sub>4</sub> Plant	100	kW <sub>e</sub>	
H <sub>2</sub> S Furnace Air Blower	870	kW <sub>e</sub>	
Boiler Feedwater Pumps	1,570	kW <sub>e</sub>	
Steam Turbine Auxiliaries	250	kW <sub>e</sub>	
Cooling Tower	1,100	kW <sub>e</sub>	
Circulating Water Pumps	1,760	kW <sub>e</sub>	
Miscellaneous Balance of Plant	750	kW <sub>e</sub>	
Condensate Pumps	240	kW <sub>e</sub>	
Flue Gas Burner Air Blower	1,130	kW <sub>e</sub>	
Wastewater Treatment	500	kW <sub>e</sub>	
<b>Total</b>	<b>40,910</b>	<b>kW<sub>e</sub></b>	
<b>Plant Performance</b>			
Net Auxiliary Load	40,910	kW <sub>e</sub>	
Net Plant Power	37,550	kW <sub>e</sub>	
Net Plant Efficiency (HHV) <sup>1</sup>	62.3%		
Coal Feed Flowrate	221,631	lb/h	
Thermal Input <sup>2</sup>	808,673	kW <sub>e</sub>	
Condenser Duty	570.5	MMBtu/h	

1 – Efficiency calculation includes thermal value of hydrogen and power produced.

2 – HHV of as-fed Pittsburgh No. 8 coal is 12,450 Btu/lb.

Figure 2-2 is a block flow diagram for the plant, and is accompanied by Table 2-2, which includes detailed process stream composition and state points.

Figure 2-2  
Process Block Flow Diagram  
E-Gas™ Gasifier-Based Hydrogen Production Plant – Pittsburgh No. 8 Coal



**Table 2-2**  
**Process Stream Compositions and State Points – Pittsburgh No. 8 Coal**

STREAM NUMBER	1	2	3	4	5	6	7	8	9	10	11	12	13
Vapor - Liquid													
Mole Fraction													
Ar	0.0094	0.0027	0.0000	0.0360	0.0000	0.0000	0.0000	0.0082	0.0000	0.0048	0.0048	0.0069	0.0077
CH <sub>4</sub>	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0042	0.0000	0.0024	0.0024	0.0035	0.0039
CO	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.4195	0.0000	0.2443	0.0627	0.0905	0.1011
CO <sub>2</sub>	0.0003	0.0000	0.0266	0.0000	0.0000	0.0000	0.0000	0.0975	0.0000	0.0568	0.2387	0.3435	0.2735
H <sub>2</sub>	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.3320	0.0000	0.1933	0.3750	0.5414	0.6053
H <sub>2</sub> O	0.0108	0.0000	0.9734	0.0000	0.0000	1.0000	0.0000	0.1219	1.0000	0.4887	0.3068	0.0027	0.0031
H <sub>2</sub> SO <sub>4</sub>	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
N <sub>2</sub>	0.7719	0.9973	0.0000	0.0140	0.0000	0.0000	0.0000	0.0057	0.0000	0.0033	0.0033	0.0048	0.0054
NH <sub>3</sub>	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0028	0.0000	0.0016	0.0016	0.0000	0.0000
O <sub>2</sub>	0.2076	0.0000	0.0000	0.9500	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
COS (ppmv)	0	0	0	0	0	0	0	388	0	226	0	0	0
H <sub>2</sub> S (ppmv)	0	0	0	0	0	0	0	7,772	0	4,526	4,752	6,738	15
SO <sub>2</sub> (ppmv)	0	0	0	0	0	0	0	0	0	0	0	0	0
SO <sub>3</sub> (ppmv)	0	0	0	0	0	0	0	0	0	0	0	0	0
Total V-L Flow (lb <sub>mol</sub> /hr)	25,425	19,588	282	5,550	0	5,219	0	25,458	18,257	43,716	43,716	29,067	25,990
Total V-L Flow (lb/hr)	733,505	549,364	5,281	178,860	0	94,025	0	504,010	328,910	832,920	832,920	566,376	433,172
Solids Flow													
Coal	0	0	0	0	221,631	0	0	0	0	0	0	0	0
Ash	0	0	0	0	0	0	0	0	0	0	0	0	0
Slag	0	0	0	0	0	0	22,632	0	0	0	0	0	0
Temperature (°F)	63	60	100	316		60		500	500	500	857	105	123
Pressure (psia)	14.4	14.7	87.5	620.0	14.7	14.7	15.0	391.0	470.0	391.0	381.0	353.0	338.0

**Table 2-2 (Cont'd)**  
**Process Stream Compositions and State Points – Pittsburgh No. 8 Coal**

<b>STREAM NUMBER</b>	<b>14</b>	<b>15</b>	<b>16</b>	<b>17</b>	<b>18</b>	<b>19</b>	<b>20</b>	<b>21</b>	<b>22</b>	<b>23</b>	<b>24</b>	<b>25</b>
<b>Vapor - Liquid</b>												
<b>Mole Fraction</b>												
Ar	0.0000	0.0148	0.0000	0.0094	0.0032	0.0033	0.0094	0.0046	0.0048	0.0000	0.0094	0.0129
CH <sub>4</sub>	0.0000	0.0076	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
CO	0.0000	0.1953	0.0003	0.0000	0.0002	0.0002	0.0000	0.0002	0.0002	0.0000	0.0000	0.0000
CO <sub>2</sub>	0.0009	0.5274	0.9340	0.0003	0.6412	0.6740	0.0003	0.5509	0.5736	0.0000	0.0003	0.3431
H <sub>2</sub>	0.9980	0.2396	0.0020	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
H <sub>2</sub> O	0.0000	0.0059	0.0000	0.0108	0.0486	0.0000	0.0108	0.0022	0.0000	0.0103	0.0108	0.1292
H <sub>2</sub> SO <sub>4</sub>	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.9897	0.0000	0.0000
N <sub>2</sub>	0.0011	0.0093	0.0000	0.7719	0.2594	0.2727	0.7719	0.3783	0.3939	0.0000	0.7719	0.4928
NH <sub>3</sub>	0.0000	0.0000	0.0001	0.0000	0.0001	0.0001	0.0000	0.0001	0.0001	0.0000	0.0000	0.0000
O <sub>2</sub>	0.0000	0.0000	0.0000	0.2076	0.0037	0.0038	0.2076	0.0263	0.0274	0.0000	0.2076	0.0219
COS (ppmv)	0	0	0	0	0	0	0	0	0	0	0	0
H <sub>2</sub> S (ppmv)	0	29	63,511	0	0	0	0	0	0	0	0	0
SO <sub>2</sub> (ppmv)	0	0	0	0	43,597	45,826	0	112	117	0	0	14
SO <sub>3</sub> (ppmv)	0	0	0	0	0	0	0	37,340	0	0	0	0
Total V-L Flow (lb <sub>mol</sub> /hr)	12,531	13,459	3,077	1,507	4,483	4,265	1,051	5,219	5,012	196	18,143	28,672
Total V-L Flow (lb/hr)	26,071	407,102	133,203	43,463	176,667	172,739	30,319	203,057	187,251	19,200	523,404	930,451
<b>Solids Flow</b>												
Coal	0	0	0	0	0	0	0	0	0	0	0	0
Ash	0	0	0	0	0	0	0	0	0	0	0	0
Slag	0	0	0	0	0	0	0	0	0	0	0	0
Temperature (°F)	70	70	123	331	750	650	180	300	315	315	89	280
Pressure (psia)	310.0	17.0	338.0	45.0	42.0	29.5	25.0	20.0	19.0	19.0	17.0	14.7

## **2.2 PROCESS DESCRIPTION**

Following are more detailed descriptions of the key process elements:

### **2.2.1 Gasifier**

For this application to produce hydrogen, a dual-train E-Gas™ gasifier of the Wabash River configuration consisting of two 50 percent gasifiers is utilized. The net temperature for gas leaving the gasifier is 1900°F by using a 78/22 flow split between the first and second stages of the gasifier. Slag produced in the high-temperature gasifier reaction flows to the bottom of the first stage, where it falls into a water bath and is cooled and shattered to become an inert frit.

Gas leaving the gasifier at 1900°F goes through an internal cyclone that separates entrained particles from the gas for recycle to the gasifier, followed by a fire-tube boiler and a gas cooler to reduce gas temperature to 645°F (341°C). Following the cooler, remaining particulates are removed from the gas with a metallic filter and are returned to the gasifier.

### **2.2.2 Air Separation Unit**

Oxygen supply for this plant is also provided through a conventional cryogenic ASU. The air separation plant is designed to produce a nominal output of 2,150 tons/day of 99 percent pure O<sub>2</sub>. The high-pressure plant is designed with one production train, with liquefaction and liquid oxygen storage providing an 8-hour backup supply of oxygen.

### **2.2.3 Particulate Removal**

The particulate removal device is a sintered metal candle configuration, operating at the relatively low temperature of 645°F (341°C). The vessel and candle array is similar to the configuration used at the Wabash River demonstration plant. A particulate removal vessel is provided for each gasifier train.

### **2.2.4 CO Shift**

After leaving the particulate control unit, steam is injected into the gas stream and the CO in the syngas is shifted to hydrogen and CO<sub>2</sub> in the shift converter utilizing a sulfur-tolerant shift catalyst. The shift catalyst also promotes the COS hydrolysis reaction. Heat is removed from the gas stream following the shift, the gases are cooled, sour water is condensed, and the gas stream is sent to the sulfur removal unit.

The CO shift converter consists of four fixed-bed reactors with two reactors in series and two in parallel. Two reactors in series with cooling between the two are required to control the exothermic temperature rise. The two reactors in parallel are required due to the high gas mass flow rate. Feed to the shift converter is first preheated by hot effluent from the second converter, heated by hot effluent from the first converter, and fed to the top of the two first-stage converters in parallel. Effluent from the first stage is cooled and fed to the top of the second-stage

converters. Effluent from the second stage is cooled by exchanging heat with incoming feed, by an air cooler and finally by a water cooler.

### **2.2.5 Amine Unit/Acid Gas Concentrator**

The purpose of the amine unit is to remove  $H_2S$  from the fuel gas stream. This step is necessary in order to minimize plant sulfur emissions. The solvent used in this case is a proprietary formulation based on MDEA. A traditional absorber/stripper arrangement will be used.

Cool, dry, and particulate-free synthesis gas enters the absorber unit at 353 psia and 105°F (41°C). In the absorber,  $H_2S$  along with some  $CO_2$  is removed from the fuel gas stream. Clean fuel gas exits the top of the absorber and is then routed to the saturator column.

The rich solution leaving the bottom of the absorber is regenerated in a stripper through the indirect application of thermal energy via condensing low-pressure steam in a reboiler. The stripper acid gas stream, consisting of 16 percent  $H_2S$  and 78 percent  $CO_2$  (with the balance mostly  $H_2O$ ), requires further treatment before being sent to the sulfuric acid plant.

Typically, for good performance and operation, the minimum  $H_2S$  concentration in the acid gas feed to an acid plant should be above 27 percent. In this case, an acid gas concentrator was used to further concentrate the  $H_2S$  stream.

### **2.2.6 Hydrogen Purification**

The product hydrogen stream exits the absorber and is sent to a PSA unit to purify the hydrogen. The product hydrogen leaves the PSA unit at 310 psia, and the PSA tail gas is sent to the HRSG to be fired with oxygen.

Treated gas from the amine unit absorber is fed directly to the PSA unit where hydrogen is purified up to approximately 99.9 percent. Carbon oxides are limited to 10 ppm in the final hydrogen product. The PSA process is based on the principle of adsorbent beds adsorbing more impurities at high gas-phase partial pressure than at low partial pressure.

The gas stream is passed through adsorbent beds at 338 psia, and then the impurities are purged from the beds at 17 psia. Purge gas is sent to the gas-fired heat recovery unit for steam generation. Purified hydrogen is produced at 310 psia. The PSA process operates on a cyclic basis and is controlled by automatic switching valves. Multiple beds are used in order to provide constant product and purge gas flows.



## 2.3 MAJOR EQUIPMENT LIST FOR BITUMINOUS COAL CASE

This section contains the equipment list corresponding to the power plant configuration shown in Figure 2-1. This list, along with the heat and material balance and supporting performance data, was used to generate plant costs and used in the financial analysis. In the following, all feet (ft) conditions specified for process pumps correspond to feet of liquid being pumped.

### ACCOUNT 1 COAL RECEIVING AND HANDLING

<u>Equipment No.</u>	<u>Description</u>	<u>Type</u>	<u>Design Condition</u>	<u>Qty.</u>
1	Bottom Trestle Dumper and Receiving Hoppers	N/A	100 ton	2
2	Feeder	Vibratory	150 tph	2
3	Conveyor 1	54" belt	200 tph	1
4	As-Received Coal Sampling System	Two-stage	N/A	1
5	Conveyor 2	54" belt	200 tph	1
6	Reclaim Hopper	N/A	40 ton	2
7	Feeder	Vibratory	150 tph	2
8	Conveyor 3	48" belt	200 tph	1
9	Crusher Tower	N/A	200 tph	1
10	Coal Surge Bin w/Vent Filter	Compartment	200 ton	1
11	Crusher	Granulator reduction	6"x0 - 3"x0	1
12	Crusher	Impactor reduction	3"x0 - 1"x0	1
13	As-Fired Coal Sampling System	Swing hammer	N/A	2
14	Conveyor 4	48" belt	200 tph	1
15	Transfer Tower	N/A	200 tph	1
16	Tripper	N/A	200 tph	1
17	Coal Silo w/Vent Filter and Slide Gates	N/A	400 ton	2

**ACCOUNT 2                      COAL-WATER SLURRY PREPARATION AND FEED**

<u>Equipment No.</u>	<u>Description</u>	<u>Type</u>	<u>Design Condition</u>	<u>Qty.</u>
1	Feeder	Vibrating	80 tph	2
2	Weigh Belt Feeder		48" belt	2
3	Rod Mill	Rotary	80 tph	2
4	Slurry Water Pumps	Centrifugal	180 gpm @ 500 ft	2
5	Slurry Water Storage Tank	Vertical	1,500 gal	1
6	Rod Mill Product Tank	Vertical	35,000 gal	2
7	Slurry Storage Tank with Agitator	Vertical	150,000 gal	2
8	Coal-Slurry Feed Pumps	Positive displacement	700 gpm @ 1,250 ft	2
9	LT Slurry Heater	Shell and tube	20 x 10 <sup>6</sup> Btu/h	2
10	HT Slurry Heater	Shell and tube	7 x 10 <sup>6</sup> Btu/h	2

**ACCOUNT 3                      FEEDWATER AND MISCELLANEOUS BOP SYSTEMS**

**ACCOUNT 3A                    CONDENSATE AND FEEDWATER SYSTEM**

<u>Equipment No.</u>	<u>Description</u>	<u>Type</u>	<u>Design Condition</u>	<u>Qty</u>
1	Cond. Storage Tank	Vertical, cylindrical, outdoor	200,000 gal	1
2	Condensate Pumps	Vert. canned	1,000 gpm @ 400 ft	2
3	Deaerator	Horiz. spray type	1,100,000 lb/h 205°F to 240°F	1
4	IP Feed Pump	Horiz. centrifugal single stage	400 gpm/1,850 ft	2
5	HP Feed Pump	Barrel type, multi-staged, centr.	500 gpm @ 4,000 ft	2

**ACCOUNT 3B MISCELLANEOUS EQUIPMENT**

<u>Equipment No.</u>	<u>Description</u>	<u>Type</u>	<u>Design Condition</u>	<u>Qty</u>
1	Auxiliary Boiler	Shop fab., water tube	400 psig, 650°F 70,000 lb/h	1
2	Service Air Compressors	Recip., single stage, double acting, horiz.	100 psig, 750 cfm	2
3	Inst. Air Dryers	Duplex, regenerative	750 cfm	1
4	Service Water Pumps	Horiz. centrifugal, double suction	200 ft, 1,200 gpm	2
5	Closed Cycle Cooling Water Pumps	Horizontal, centrifugal	70 ft, 1,200 gpm	2
6	Fire Service Booster Pump	Two-stage horiz. centrifugal	250 ft, 1,200 gpm	1
7	Engine-Driven Fire Pump	Vert. turbine, diesel engine	350 ft, 1,000 gpm	1
8	Raw Water Pumps	SS, single suction	60 ft, 300 gpm	2
9	Filtered Water Pumps	SS, single suction	160 ft, 120 gpm	2
10	Filtered Water Tank	Vertical, cylindrical	15,000 gal	1
11	Makeup Demineralizer	Anion, cation, and mixed bed	650 gpm	2
12	Sour Water Stripper System	Vendor supplied	300,000 lb/h sour water	1
13	Liquid Waste Treatment System	Vendor supplied	600 gpm	1

**ACCOUNT 4                      GASIFIER AND ACCESSORIES**

**ACCOUNT 4A                    GASIFICATION**

<b><u>Equipment No.</u></b>	<b><u>Description</u></b>	<b><u>Type</u></b>	<b><u>Design Condition</u></b>	<b><u>Qty</u></b>
1	Gasifier	Pressurized entrained bed/syngas cooler	2,500 std (dry-coal basis) @ 425 psia	2
2	Raw Gas Cooler Steam Generator	Fire tube boiler	1,500 psig/600°F 132.7 MMBtu/h	2
3	Raw Gas Cooler Steam Generator	Shell and tube	800 psig/518°F 135.1 MMBtu/h	2
4	Medium-Temperature Candle Filter	Sintered stainless	400 psia, 645°F	2
5	Flare Stack	Self-supporting, carbon steel, stainless steel top, pilot ignition	600,000 lb/h, medium-Btu gas	1

**ACCOUNT 4B                    AIR SEPARATION PLANT**

<b><u>Equipment No.</u></b>	<b><u>Description</u></b>	<b><u>Type</u></b>	<b><u>Design Condition</u></b>	<b><u>Qty</u></b>
1	Air Compressor	Centrifugal, multi-stage	75,000 scfm, 67 psia discharge pressure	2
2	Cold Box	Vendor supplied	2,150 ton/day O <sub>2</sub>	1
3	Oxygen Compressor	Centrifugal, multi-stage	17,000 scfm, 600 psig discharge pressure	2
4	Liquid Oxygen Storage Tank	Vertical	60' dia x 80' vert	1

**ACCOUNT 5 SYNGAS SHIFT AND CLEANUP**

**ACCOUNT 5A WATER-GAS SHIFT AND RAW GAS COOLING**

<u>Equipment No.</u>	<u>Description</u>	<u>Type</u>	<u>Design Condition</u>	<u>Qty</u>
1	High Temperature Shift Reactor	Fixed bed	400 psia, 750°F	1
2	HP Steam Generator	Shell and tube	70 x 10 <sup>6</sup> Btu/h @ 1700 psia and 613°F	1
3	IP Steam Generator	Shell and tube	45 x 10 <sup>6</sup> Btu/h @ 800 psia and 518°F	1
45	LP Steam Generator	Shell and tube	20 x 10 <sup>6</sup> Btu/h @ 200 psia and 382°F	1
5	Raw Gas Coolers	Shell and tube with condensate drain	150 x 10 <sup>6</sup> Btu/h	2
67	Raw Gas Knock Out Drum	Vertical with mist eliminator	400 psia, 130°F	1

**ACCOUNT 5B ACID GAS REMOVAL AND HYDROGEN PURIFICATION**

<u>Equipment No.</u>	<u>Description</u>	<u>Type</u>	<u>Design Condition</u>	<u>Qty</u>
1	Amine Absorber 1	Column	100,000 scfm (4,900 acfm), 353 psia, 103°F	2
2	Amine Regenerator 1	Column	Vendor design	1
3	Sulfuric Acid Plant	Vendor design	230 tpd sulfuric acid	1
4	PSA Unit	Fixed bed	112 MMscfd H <sub>2</sub> @ 310 psia	1

**ACCOUNT 6 COMBUSTION TURBINE/ACCESSORIES**

Not applicable.

**ACCOUNT 7 WASTE HEAT BOILER, DUCTING, AND STACK**

<u>Equipment No.</u>	<u>Description</u>	<u>Type</u>	<u>Design Condition</u> <u>Drums</u>	<u>Qty</u>
1	Heat Recovery Steam Generator	Fired drum	1700 psig/1000°F 600,000 lb/h 200 x 10 <sup>6</sup> Btu/h	1
2	Stack	Carbon steel plate, type 409 stainless steel liner	213 ft high x 28 ft dia.	1

**ACCOUNT 8                      STEAM TURBINE GENERATOR AND AUXILIARIES**

<b><u>Equipment No.</u></b>	<b><u>Description</u></b>	<b><u>Type</u></b>	<b><u>Design Condition</u> (per each)</b>	<b><u>Qty</u></b>
1	78 MW Steam Turbine Generator	TC2F26	1800 psig 1000°F/1000°F	1
2	Bearing Lube Oil Coolers	Plate and frame		2
3	Bearing Lube Oil Conditioner	Pressure filter closed loop		1
4	Control System	Digital electro-hydraulic	1600 psig	1
5	Generator Coolers	Plate and frame		2
6	Hydrogen Seal Oil System	Closed loop		1
7	Surface Condenser	Single pass, divided waterbox	1,030,000 lb/h steam @ 2.4 in. Hga	1
8	Condenser Vacuum Pumps	Rotary, water sealed	2500/25 scfm (hogging/holding)	2

**ACCOUNT 9                      COOLING WATER SYSTEM**

<b><u>Equipment No.</u></b>	<b><u>Description</u></b>	<b><u>Type</u></b>	<b><u>Design Condition</u> (per each)</b>	<b><u>Qty</u></b>
1	Circ. Water Pumps	Vert. wet pit	40,000 gpm @ 60 ft	2
2	Cooling Tower	Mechanical draft	100,000 gpm	1

**ACCOUNT 10                      ASH/SPENT SORBENT RECOVERY AND HANDLING**

**ACCOUNT 10A                      SLAG DEWATERING AND REMOVAL**

<b><u>Equipment No.</u></b>	<b><u>Description</u></b>	<b><u>Type</u></b>	<b><u>Design Condition</u></b>	<b><u>Qty</u></b>
1	Slag Dewatering System	Vendor proprietary	272 tpd	1

## 2.4 CAPITAL COST

The total plant cost for the plant producing 313 tons of hydrogen per day from Pittsburgh No. 8 coal is \$376.1 million in 2001 dollars. The capital cost summary is included in Table 2-3.

**Table 2-3**  
**Capital Cost Summary – Hydrogen Production from Pittsburgh No. 8 Coal**

Client: Project:		DEPARTMENT OF ENERGY NETL H <sub>2</sub> Production Facility					Report Date: 03-Jun-2002 01:19 PM					
Case: Plant Size:		Bituminous H <sub>2</sub> Plant w/o CO <sub>2</sub> Capture 312.6 H <sub>2</sub> TPD					Estimate Type: Conceptual Cost Base (Dec) 2001 (\$X1000 & \$X1000/TPD)					
TOTAL PLANT COST SUMMARY												
Acct No.	Item/Description	Equipment Cost	Material Cost	Labor		Sales Tax	Bare Erected Cost \$	Eng'g CM H.O. & Fee	Contingencies		TOTAL PLANT COST	
				Direct	Indirect				Process	Project	\$	\$/TPD
1	COAL & SORBENT HANDLING	5,354	1,099	3,955	277		\$10,686	855		1,154	\$12,694	41
2	COAL & SORBENT PREP & FEED	8,987	1,307	4,905	343		\$15,542	1,733		1,728	\$19,003	61
3	FEEDWATER & MISC. BOP SYSTEMS	4,506	1,339	2,679	187		\$8,711	697		941	\$10,348	33
4	GASIFIER & ACCESSORIES											
4.1	Gasifier, Syngas Cooler & Auxiliaries (E	51,616		21,976	1,538		\$75,130	9,016		8,415	\$92,560	296
4.2	Syngas Cooling			w/ 4.1	w/ 4.1			w/ 4.1		w/ 4.1		
4.3	ASU/Oxidant Compression	29,284		w/equip.			\$29,284	2,343		3,163	\$34,789	111
4.4-4.9	Other Gasification Equipment	6,881	5,691	4,811	337		\$17,720	1,447		1,917	\$21,084	67
	SUBTOTAL 4	87,781	5,691	26,787	1,875		\$122,134	12,805		13,494	\$148,433	475
5	HYDROGEN SEPARATION/GAS CLEANING	59,135	4,205	21,176	1,482		\$85,999	10,111		9,611	\$105,721	338
6	COMBUSTION TURBINE/ACCESSORIES											
6.1	Expander Turbine/Generator											
6.2-6.9	Combustion Turbine Accessories											
	SUBTOTAL 6											
7	HRSG, DUCTING & STACK											
7.1	Heat Recovery Steam Generator	4,533		551	39		\$5,123	410		553	\$6,086	19
7.2-7.9	HRSG Accessories, Ductwork and Stack	561	209	335	23		\$1,129	90		122	\$1,341	4
	SUBTOTAL 7	5,094	209	886	62		\$6,251	500		675	\$7,427	24
8	STEAM TURBINE GENERATOR											
8.1	Steam TG & Accessories	7,612		1,061	74		\$8,747	700		945	\$10,392	33
8.2-8.9	Turbine Plant Auxiliaries and Steam Piping	3,470	106	1,611	113		\$5,300	424		572	\$6,296	20
	SUBTOTAL 8	11,082	106	2,672	187		\$14,047	1,124		1,517	\$16,688	53
9	COOLING WATER SYSTEM	2,375	1,163	1,901	133		\$5,572	446		602	\$6,619	21
10	ASH/SPENT SORBENT HANDLING SYSTEM	5,147	653	2,196	154		\$8,150	888		904	\$9,941	32
11	ACCESSORY ELECTRIC PLANT	5,029	2,077	4,075	285		\$11,467	917		1,238	\$13,623	44
12	INSTRUMENTATION & CONTROL	5,292	1,257	3,903	273		\$10,725	858		1,158	\$12,741	41
13	IMPROVEMENTS TO SITE	1,566	900	2,593	182		\$5,241	419		566	\$6,226	20
14	BUILDINGS & STRUCTURES		2,663	2,711	190		\$5,564	445		601	\$6,610	21
TOTAL COST		\$201,347	\$22,671	\$80,439	\$5,631		\$310,088	\$31,798		\$34,189	\$376,074	1203

## 2.5 DETERMINATION OF COST OF HYDROGEN FROM PITTSBURGH NO. 8 COAL USING PRELIMINARY ASSUMPTIONS

For this economic analysis, the capital and operating costs for the two plants being evaluated have been upgraded to 2001 dollars. Coal cost has been estimated at \$1.00 per MMBtu.

### **2.5.1 Approach to Cost Estimating**

Economics in this report are stated primarily in terms of levelized cost of product, \$/short ton (\$/ton), or \$/MMBtu. The cost of product is developed from the identified financial parameters in Table 2-4, and:

- Total capital requirement of the plant (TCR).
- Fixed operating and maintenance cost (fixed O&M).
- Non-fuel variable operating and maintenance costs (variable O&M).
- Consumables and byproducts costs and credits.
- Fuel costs.

### **2.5.2 Production Costs (Operation and Maintenance)**

The production costs for the plant consist of several broad categories of cost elements. These cost elements include operating labor, maintenance material and labor, administrative and support labor, consumables (water and water treating chemicals, solid waste disposal costs, byproducts such as power sales, and fuel costs). Note that production costs do not include capital charges and should not be confused with cost of product.



**Table 2-4**  
**Operating Cost Data**

OPERATING LABOR REQUIREMENTS			
BITUMINOUS H <sub>2</sub> PLANT W/O CO <sub>2</sub> CAPTURE			
Operating Labor Rate (base)	\$26.15/hour		
Operating Labor Burden	30.00% of base		
Labor OH Charge Rate	25.00% of labor		
Operating Labor Requirements (OJ) per Shift			
Category	1 Unit/Mod	Total Plant	
Skilled Operator	1.0	1.0	
Operator	8.0	8.0	
Foreman	1.0	1.0	
Lab Techs, etc.	<u>1.0</u>	<u>1.0</u>	
TOTAL – OJs	11.0	11.0	
CONSUMABLES, BYPRODUCTS & FUELS DATA			
BITUMINOUS H <sub>2</sub> PLANT W/O CO <sub>2</sub> CAPTURE			
	Consumption		Unit Cost
Item/Description	Initial	/Day	
Water (/1,000 gal)		846	0.80
Chemicals			
Water Treatment (lb)	61,434	2,048	0.15
Limestone (ton)			16.25
Shift Catalyst (lb)	15,221	507.4	5.25
Amine (lb)	8,640	288.0	0.63
Other			
Supplemental Fuel (MMBtu)			
Purchased Power (MWh)			
LP Steam (/1,000 lb)			
Waste Disposal			
Sludge (ton)			
Slag (ton)		272	10.00
Byproducts & Emissions			
Sulfuric Acid (tons)		229	75.00
Excess Electric Generation (MWh)		901	30.00
Fuel (ton)		2,659	24.90

### 2.5.3 Consumables

#### *Shift Catalyst:*

- Change-out every 3 years
- 0.0045 pound of catalyst per 1,000 standard cubic feet of hydrogen
- 250 tons initial charge
- 85 tons per year annual cost

#### *Proprietary Amine:*

- 12 pounds per hour

- 100,000 pounds per year

**PSA Sorbent:**

- Periodic change-out with scheduled maintenance

**SO<sub>2</sub> Conversion Catalyst:**

- Periodic change-out with scheduled maintenance

## 2.5.4 Byproduct Credits

The production of 229 tons of sulfuric acid per day is taken as a byproduct credit at \$75 per ton.

## 2.5.5 Financial Assumptions

The cost of hydrogen was determined based on financial assumptions typically used by Parsons. These are summarized in Table 2-5.

**Table 2-5**  
**Financial Parameters**

Levelized capacity factor	90%
Design/construction period	4 years
Plant startup date	January 2005
Land area/Unit cost	100 acres @ 41,500/acre
Project book life	20 years
Project tax life	20 years
Tax depreciation method	Accelerated based on ACRS class
Property tax rate	1.0% per year
Insurance tax rate	1.0% per year
Federal income tax rate	34.0%
State income tax rate	4.2%
Capital structure	
Common equity	20% @ 16.50% annum
Debt	80% @ 6.30% annum
Weighted cost of capital (after tax)	6.49%

## 2.5.6 Cost Results

Applying the financial parameters from Table 2-5, the cost of hydrogen was estimated to be \$6.01/MMBtu (\$2.06/Mcf) for Pittsburgh No. 8 coal. The results of the cost estimating activity are summarized in Table 2-6. These results were used as the price of hydrogen input to the DOE IGCC financial model. The results are shown in Appendix A.

Table 2-6

CAPITAL INVESTMENT & REVENUE REQUIREMENT SUMMARY			
<b>TITLE/DEFINITION</b>			
Case:	Bituminous H <sub>2</sub> Plant w/o CO <sub>2</sub> Capture		
Plant Size:	312.6 TPD-Synga	HeatRate:	(Btu/kWh)
Primary/Secondary Fuel(type):	Pitts. #8	Cost:	1.00 (\$/MMBtu)
Design/Construction:	3 (years)	BookLife:	20 (years)
TPC(Plant Cost) Year:	2001 (Jan.)	TPI Year:	2005 (Jan.)
Capacity Factor:	90 (%)		
<b>CAPITAL INVESTMENT</b>			
	<b>\$x1000</b>	<b>\$x1000/H<sub>2</sub>TPD</b>	
Process Capital & Facilities	310,088	992.0	
Engineering(incl.C.M.,H.O.& Fee)	31,798	101.7	
Process Contingency			
Project Contingency	34,189	109.4	
TOTAL PLANT COST(TPC)	\$376,074	1203.1	
TOTAL CASH EXPENDED	\$376,074		
AFDC	\$24,114		
TOTAL PLANT INVESTMENT(TPI)	\$400,188	1280.2	
Royalty Allowance			
Preproduction Costs	9,621	30.8	
Inventory Capital	3,067	9.8	
Initial Catalyst & Chemicals(w/equip.)			
Land Cost	150	0.5	
TOTAL CAPITAL REQUIREMENT(TCR)	\$413,026	1321.3	
<b>OPERATING &amp; MAINTENANCE COSTS (2001 Dollars)</b>			
	<b>\$x1000</b>	<b>\$x1000/H<sub>2</sub>TPD</b>	
Operating Labor	3,276	10.5	
Maintenance Labor	2,642	8.5	
Maintenance Material	3,963	12.7	
Administrative & Support Labor	1,479	4.7	
TOTAL OPERATION & MAINTENANCE	\$11,361	36.3	
FIXED O & M		32.71	
VARIABLE O & M		3.63	
<b>CONSUMABLE OPERATING COSTS,less Fuel (2001 Dollars)</b>			
	<b>\$x1000</b>	<b>\$/T H<sub>2</sub>-yr</b>	
Water	222	2.17	
Chemicals	1,033	10.06	
Other Consumables			
Waste Disposal	892	8.69	
TOTAL CONSUMABLE OPERATING COSTS	\$2,147	20.91	
BY-PRODUCT CREDITS (2001 Dollars)	(\$14,531)	-141.51	
FUEL COST (2001 Dollars)	\$21,753	211.85	
<b>PRODUCTION COST SUMMARY</b>			
	<b>1st Year (2005 \$)</b>	<b>Levelized (Over Book Life \$)</b>	
	<b>\$/T H<sub>2</sub>-yr</b>	<b>\$/T H<sub>2</sub>-yr</b>	
Fixed O & M	99.57	99.57	
Variable O & M	3.63	3.63	
Consumables	20.91	20.91	
By-product Credit/Penalty	-141.51	-141.51	
Fuel	206.81	188.64	
TOTAL PRODUCTION COST	189.41	171.25	
LEVELIZED CARRYING CHARGES(Capital)	57,824	563.12	
LEVELIZED(Over Book Life)COST/Ton of Syngas		734.36	
Equivalent 1st.Yr.\$/MSCF / Lev'd \$/MMBtu	2.061	6.01	