

DOE/RA/50351-1300

**CROW TRIBE
OF
INDIANS**



**SYNFUELS FEASIBILITY
STUDY**

VOLUME II

**PROCESS DESIGN AND COST ESTIMATE
BOOK II: SECTIONS 6.3 AND 6.4**

AUGUST, 1982

**PREPARED FOR THE DEPARTMENT OF ENERGY
UNDER GRANT NO. DE-FG01-81RA50351**

DISTRIBUTION OF THIS DOCUMENT IS LIMITED

NOTICE

Portions of this Report were prepared by Fluor Engineers and Constructors, Inc., solely for the benefit of the Crow Tribe of Indians and not for the purpose of reliance by any third party. Fluor makes no guarantees and assumes no liability to any third party with respect to any information contained herein. Third parties using information contained in this Report do so at their own risk, and any use thereof shall constitute a release to Fluor and the Crow Tribe from any liability in connection therewith whether arising in contract, tort, or otherwise, and regardless of the fault or negligence of Fluor or the Crow Tribe.

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

NOTICE

PORTIONS OF THIS REPORT ARE ILLEGIBLE. It has been reproduced from the best available copy to permit the broadest possible availability.

MN ONLY

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

USE OR DISCLOSURE OF REPORT DATA
IS SUBJECT TO THE RESTRICTION ON THE
NOTICE PAGE AT THE FRONT OF THIS REPORT

PREFACE

Volume II, Process Design and Cost Estimate is a three book volume. Sections 1.0 through 6.2 are presented in Book I. This portion, Book II, contains Sections 6.3 and 6.4, the Base Case Utilities and Offsite Units Engineering Data and the Contents and Results of the Power Self-Sufficiency Case. Book III contains Sections 6.5 through 6.9, the Coproduction Case, Shell Coal Case, Process Studies, Design Plans and Drawings and Cost Estimates. The Table of Contents for Volume II is presented in total in each of the three books.

VOLUME II

PRELIMINARY DESIGN AND COST ESTIMATE

TABLE OF CONTENTS

<u>BOOK I</u>	<u>PAGE</u>
1.0 FEASIBILITY STUDY OVERVIEW	1-1
2.0 INTRODUCTION	2-1
3.0 SUMMARY	3-1
3.1 DESIGN CONSIDERATIONS	3-1
3.2 BASE CASE	3-3
3.3 COMPARISONS	3-4
3.3.1 Coal Feed Comparison	3-4
3.3.2 Product and Byproduct Summary	3-7
3.3.3 Capital Cost Summary	3-7
3.3.4 Operation and Cost Summary	3-11
4.0 SCOPE OF WORK	4-1
4.1 PROCESS DEVELOPMENT	4-1
4.2 UTILITY SYSTEMS DEVELOPMENT	4-3
4.3 OFFSITES DEVELOPMENT	4-4
4.4 SPECIAL PROCESS STUDY	4-5
4.5 CAPITAL AND OPERATING COSTS	4-5

VOLUME II

PRELIMINARY DESIGN AND COST ESTIMATE

TABLE OF CONTENTS

<u>BOOK I</u>	<u>PAGE</u>
5.0 CRITERIA, RATIONALE, AND ASSUMPTIONS	5-1
5.1 COAL ANALYSES	5-1
5.2 SITE DATA	5-5
5.2.1 Area Description	5-5
5.2.2 Sites Studied	5-5
5.2.3 Topographic Maps and Aerial Photographs	5-7
5.2.4 Site Reconnaissance	5-10
5.2.5 Meteorological and Design Data	5-10
5.2.6 Building Codes and Regulations	5-16
5.2.7 Description of Site 1	5-17
5.2.8 Description of Site 23	5-26
5.3 RAW WATER ANALYSIS	5-36
5.4 UTILITY DESIGN INFORMATION	5-38
5.5 PRODUCT AND BYPRODUCTS SPECIFICATIONS	5-40
5.5.1 Product Specifications	5-40
5.5.2 Byproducts and Ash Specifications	5-40

VOLUME II

PRELIMINARY DESIGN AND COST ESTIMATE

TABLE OF CONTENTS

<u>BOOK I</u>		<u>PAGE</u>
5.6	ECONOMIC CRITERIA - CAPITAL COSTS	5-42
5.6.1	Direct Field Cost Estimate	5-57
5.6.2	Indirect Field Cost Estimate	5-61
5.6.3	Office Cost Estimate	5-63
5.6.4	Material Transportation Cost Estimate	5-63
5.6.5	Other Capital Costs	5-64
5.6.6	Manpower Plans	5-70
5.7	ECONOMIC CRITERIA - OPERATING AND MAINTENANCE COSTS	5-71
5.7.1	Coal Cost	5-71
5.7.2	Catalysts and Chemicals	5-71
5.7.3	Plant Management Staff	5-71
5.7.4	Plant Operating Labor and Materials	5-72
5.7.5	Maintenance Labor and Materials	5-72
5.7.6	Water Pumping Costs	5-72
5.7.7	Solid Waste Disposal	5-73
5.7.8	Taxes and Insurance	5-73
5.7.9	Byproducts Credit	5-73

VOLUME II

PRELIMINARY DESIGN AND COST ESTIMATE

TABLE OF CONTENTS

<u>BOOK I</u>	<u>PAGE</u>
6.0 CONTENTS AND RESULTS	6-1
6.1 BASE CASE OVERALL PLANT DESCRIPTION	6-1
6.1.1 Introduction	6-1
6.1.2 Feed and Product Summary	6-5
6.1.3 Thermal Efficiency Calculation	6-8
6.1.4 Design Basis	6-10
6.1.5 Plant Units	6-17
6.1.6 Plant Train Philosophy	6-20
6.1.7 Plot Plan	6-28
6.1.8 Block Flow Diagrams	6-31
Overall Material Balance	6-31
Plant Water Balance	6-31
Sulfur Balance	6-35
Air Emissions	6-37
Solid Effluents	6-37
Steam Balance	6-40
6.1.9 Utility Summary	6-42
6.1.10 Catalyst and Chemicals Summary	6-44
6.1.11 Operating Manpower	6-51
6.1.12 Maintenance Manpower	6-53

VOLUME II

PRELIMINARY DESIGN AND COST ESTIMATE

TABLE OF CONTENTS

BOOK I

PAGE

6.2	BASE CASE PROCESS UNITS - ENGINEERING DATA	6-54
6.2.1	Unit 01 - Coal Screening	6-54
6.2.2	Unit 02 - Coal Distribution	6-62
6.2.3	Unit 03 - Ash Handling	6-68
6.2.4	Unit 10 - Coal Gasification	6-77
6.2.5	Unit 11 - Carbon Monoxide Shift	6-87
6.2.6	Unit 12 - Gas Cooling	6-94
6.2.7	Unit 13 - Rectisol	6-101
6.2.8	Unit 14 - Gas Liquor Separation	6-112
6.2.9	Unit 15 - Tar Distillation	6-121
6.2.10	Unit 16 - Naphtha Hydrotreating	6-128
6.2.11	Unit 17 - Phenosolvan	6-137
6.2.12	Unit 18 - Ammonia Recovery	6-147
6.2.13	Unit 19 - Sulfur Recovery	6-155
6.2.14	Unit 20 - Process Steam Superheating	6-177
6.2.15	Unit 21 - Methanol Synthesis	6-183
6.2.16	Unit 22 - Methanation	6-190
6.2.17	Unit 23 - SNG Purification and Compression	6-200
6.2.18	Unit 24 - Partial Oxidation	6-207
6.2.19	Unit 25 - PSA Hydrogen Production	6-215

VOLUME II

PRELIMINARY DESIGN AND COST ESTIMATE

TABLE OF CONTENTS

<u>BOOK II</u>		<u>PAGE</u>
6.3	BASE CASE UTILITY AND OFFSITE UNITS - ENGINEERING DATA	6-224
6.3.1	Unit 40 - Oxygen Production	6-224
6.3.2	Unit 41 - Steam Generation	6-233
6.3.3	Unit 42 - Power Generation	6-248
6.3.4	Unit 43 - Flue Gas Desulfurization	6-256
6.3.5	Unit 44 - Raw Water Treating	6-263
6.3.6	Unit 45 - Boiler Feedwater and Condensate Treating	6-273
6.3.7	Unit 46 - Air and Nitrogen Systems	6-293
6.3.8	Unit 47 - Process Cooling Water	6-304
6.3.9	Unit 48 - Utility Cooling Water	6-318
6.3.10	Unit 49 - Potable Water	6-328
6.3.11	Unit 50 - Utility Water	6-338
6.3.12	Unit 51 - Firewater	6-342
6.3.13	Unit 52 - Fuel Gas	6-349
6.3.14	Unit 53 - Flare	6-356
6.3.15	Unit 54 - Wastewater Treating	6-365
6.3.16	Unit 55 - Tank Farm and Dispatch	6-389
6.3.17	Unit 56 - Sanitary Waste Treatment System	6-419
6.3.18	Unit 57 - Interconnecting Pipeway	6-423
6.3.19	Unit 61 - Buildings	6-424

VOLUME II

PRELIMINARY DESIGN AND COST ESTIMATE

TABLE OF CONTENTS

<u>BOOK II</u>		<u>PAGE</u>
6.3.20	Unit 65 - Electrical Distribution	6-425
	Appendix 6.3.20-1 Electrical Design Drawings	6-443
6.3.21	Unit 68 - Control Systems	6-468
6.3.22	Unit 71 - Site Preparation	6-494
6.3.23	Unit 75 - Site Improvements	6-495
6.4	POWER SELF-SUFFICIENCY CASE	6-497
6.4.1	Overall Plant Description	5-497
6.4.2	Feed and Product Summary	6-498
6.4.3	Thermal Efficiency Calculation	6-500
6.4.4	Design Basis	6-502
6.4.5	Plant Units	6-503
6.4.6	Plant Train Philosophy	6-504
6.4.7	Plot Plan	6-505
6.4.8	Block Flow Diagrams	6-506
	6.4.8.1 Overall Material Balance	6-506
	6.4.8.2 Plant Water Balance	6-506
	6.4.8.3 Sulfur Balance	6-506
	6.4.8.4 Air Emissions	6-510
	6.4.8.5 Solid Effluent	6-510
	6.4.8.6 Steam Balance	6-510

VOLUME II

PRELIMINARY DESIGN AND COST ESTIMATE

TABLE OF CONTENTS

BOOK II

PAGE

6.4.9	Utility Summary	6-514
6.4.10	Catalyst and Chemicals Summary	6-517
6.4.11	Operating Manpower	6-522
6.4.12	Maintenance Manpower	6-523
6.4.13	Process Units Engineering Data	6-524
6.4.14	Utility and Offsites Units	6-528
6.4.15	Capacity Factors	6-546

VOLUME II

PRELIMINARY DESIGN AND COST ESTIMATE

TABLE OF CONTENTS

<u>BOOK III</u>		<u>PAGE</u>
6.5	COPRODUCTION CASE	6-549
6.5.1	Overall Plant Description	6-549
6.5.2	Feed and Product Summary	6-550
6.5.3	Thermal Efficiency Calculation	6-552
6.5.4	Design Basis	6-554
6.5.5	Plant Units	6-555
6.5.6	Plant Train Philosophy	6-556
6.5.7	Plot Plan	6-557
6.5.8	Block Flow Diagrams	6-560
6.5.9	Utility Summary	6-568
6.5.10	Catalyst and Chemical Summary	6-571
6.5.11	Operating Manpower	6-577
6.5.12	Maintenance Manpower	6-578
6.5.13	Process Units Engineering Data	6-579
6.5.13.1	Differences	6-579
6.5.13.2	Gas Cooling - Unit 12	6-580
6.5.13.3	Methanol Synthesis and Purification - Unit 21	6-589
6.5.13.4	Methanation - Unit 22	6-600
6.5.13.5	SNG Purification and Compression - Unit 23	6-608

VOLUME II

PRELIMINARY DESIGN AND COST ESTIMATE

TABLE OF CONTENTS

<u>BOOK III</u>		<u>PAGE</u>
6.7	PROCESS STUDIES	6-726
6.7.1	Steam Study	6-726
6.7.2	Flue Gas Desulfurization	6-738
	Appendix A	6-755
	Appendix B	6-763
6.7.3	Expanded Plant	6-766
6.8	DESIGN PLANS AND DRAWINGS	6-776
6.8.1	Site Preparation - Site 1	6-776
6.8.2	Roads - Site 1	6-786
6.8.3	Railroad - Site 1	6-796
6.8.4	Logistic Facilities - Site 1	6-798
6.8.5	Paving - Site 1	6-802
6.8.6	Foundations and Structures - Site 1	6-805
6.8.7	Buildings - Site 1	6-831
6.8.8	Ponds and Basins - Site 1	6-875
6.8.9	Site Preparation - Site 23	6-890
6.8.10	Roads - Site 23	6-895
6.8.11	Railroad - Site 23	6-899
6.8.12	Logistic Facilities - Site 23	6-900
6.8.13	Paving - Site 23	6-902
6.8.14	Foundations and Structures - Site 23	6-903

VOLUME II

PRELIMINARY DESIGN AND COST ESTIMATE

TABLE OF CONTENTS

<u>BOOK III</u>		<u>PAGE</u>
	6.5.14 Utility and Offsite Units	6-627
	6.5.15 Capacity Factors	6-646
6.6	SHELL COAL CASE	6-650
	6.6.1 Overall Plant Description	6-650
	6.6.2 Feed and Product Summary	6-651
	6.6.3 Thermal Efficiency Calculation	6-653
	6.6.4 Design Basis	6-655
	6.6.5 Plant Units	6-656
	6.6.6 Plant Train Philosophy	6-657
	6.6.7 Plot Plan	6-658
	6.6.8 Block Flow Diagrams	6-661
	6.6.9 Utility Summary	6-669
	6.6.10 Catalyst and Chemical Summary	6-671
	6.6.11 Operating Manpower	6-676
	6.6.12 Maintenance Manpower	6-677
	6.6.13 Process Units Engineering Data	6-678
	6.6.14 Utility and Offsite Units	6-700
	6.6.15 Capacity Factors	6-722

VOLUME II

PRELIMINARY DESIGN AND COST ESTIMATE

TABLE OF CONTENTS

<u>BOOK III</u>	<u>PAGE</u>
6.8.15 Buildings - Site 23	6-904
6.8.16 Ponds and Basins	6-906
6.9 COST ESTIMATES	6-907
6.9.1 Capital Cost Summary	6-907
6.9.2 Capital Cost Estimate	6-909
6.9.3 Other Capital Cost Allowances	6-917
6.9.4 Operating and Maintenance Cost Allowances	6-919
6.9.5 Cash Flow Data	6-921

6.3 BASE CASE UTILITY AND OFFSITE UNITS - ENGINEERING DATA

6.3.1 OXYGEN PRODUCTION - UNIT 40

6.3.1.1 DESIGN BASIS

Purpose of Unit

The oxygen plant produces gaseous oxygen for use in coal gasification and partial oxidation of liquid hydrocarbons. The oxygen plant also produces high purity nitrogen and instrument air required by the process, utility, and off-site units within the plant.

Scope of Unit

The oxygen plant consists of facilities to compress air, separate air via autorefrigeration and compress the oxygen product, nitrogen and instrument air for delivery to plant battery limits.

General Design Criteria

The oxygen production facility consists of two 50 percent capacity parallel trains, each train having air compressor, a cold box with column/expander, and two 100 percent oxygen compressors and LP expanders.

Each train is designed for continuous operation at design product rates with minimum onstream time before deriming or planned shutdown of two years. The onstream factor is expected to be 100 percent due to the sparing of equipment.

Air compressor drivers are back pressure turbines using 1450 psig/925°F steam exhausting at 650 psig. Oxygen compressor drivers and all other drivers are motors.

6.3.1.1 (Continued)

Each train is capable of operating independently and at turn down rates of approximately 70 percent of design capacity.

Process Performance Objectives

The oxygen plant is designed to produce a total of 2925 ST/D of 98.5 percent volume purity oxygen based on atmospheric air feed. The oxygen plant also produces 14.5 MM SCFD of 99.99 percent volume purity nitrogen⁽¹⁾ and 4.4 MM SCFD of instrument air with a maximum dew point of -40°F (at 100 psig).

Feedstock

Inlet air for the design of the oxygen plant is atmospheric air with the following properties:

Pressure	13.0 psia
Temperature	88°F
Dew Point	64°F

Inlet flow rate of air is 347 MM SCFD

The possible contaminants in the intake air are the following: Light hydrocarbons, ammonia, sulfur dioxide, hydrogen sulfide, and nitrogen oxides.

⁽¹⁾ O₂ content less than 100 ppm volume

6.3.1.1 (Continued)

Products

The condition of the oxygen plant product streams are given below:

<u>Product Stream</u>	<u>Temperature (°F)</u>	<u>Pressure (psig)</u>	<u>Phase</u>
Oxygen	230 (max)	495	gas
Nitrogen	75	50	gas
Instrument Air	75	50	gas

Utilities

The oxygen plant consumes the utilities listed below:

1450 psig/925°F Steam	1.2 x 10 ⁶ lb/hr (exits unit at 650 psig)
Cooling Water	10,400 gpm
Electrical Power	11,900 kW

The oxygen plant produces the utilities listed below:

Process Condensate	11,009 lb/hr
Electrical Power	600 kW

6.3.1.2 PROCESS DESCRIPTION

The utility flow sketch for the Oxygen Production unit is shown on Drawing No. 835704-40-4-101. The material balance (Table 6.3.1-1) for the unit follows the drawing. The plot plan is shown on Drawing No. 835704-40-4-050 and the equipment list (Table 6.3.1-2) follows.

6.3.1.2 (Continued)

The Oxygen Plant uses a low pressure cycle for air separation with reversing heat exchangers. The refrigeration requirements for the plant are covered by the expansion of air.

The process air is filtered, compressed (by an axial/radial centrifugal compressor) and cooled. The air stream is passed through a knockout drum where condensate is removed and sent to BFW and Condensate Treating Unit 45. The air stream then enters the reversing exchangers at near ambient temperature.

In the exchangers the air is cooled to near liquefaction temperature against separated cold product streams. Water and carbon dioxide contained in the air are deposited on the plate surface of the air passes during one half cycle. They are scavenged from there after flow reversal by waste nitrogen from the unit.

Flow reversal in the reversing heat exchangers is controlled by an electric switching device actuating valves located at the warm end of the heat exchangers. Flow reversal at the cold end of the exchangers is effected by means of automatically operating check valves.

The major portion of the process air, after leaving the cold end of the reversing exchangers, flows to the Air Separation unit. Within the Air Separation unit the process air is cryogenically separated into nitrogen and oxygen via autorefrigeration.

Pure nitrogen product is withdrawn from the Air Separation unit and flows to the reversing exchangers. The stream is warmed to ambient temperature in heat exchangers.

6.3.1.2 (Continued)

The gaseous oxygen product is warmed up in nonreversing passages of the main exchangers and leaves at ambient temperature and a pressure of approximately 24 psia. It then enters the suction of the oxygen product compressor system.

Deriming of the reversing exchangers is by heated plant air. Total deriming is required every two years, with downtime of approximately 80 hours.

Prevention of dangerous contaminants from entering the oxygen-rich section of the Air Separation Unit is provided by:


Air Filters - Upstream of the main air compressor to eliminate dust and particulate matter.

Reversing Exchangers - Reversing passages are used for the eliminating of carbon dioxide and water as well as for heat exchange. The passages also freeze out other condensible impurities which are then safely eliminated into the waste nitrogen stream.

Hydrocarbon Filters - Absorbers located within the Air Separation Unit are provided for the removal of hydrocarbon contaminants.


Unit Plot Area Requirements

Area required for two 1462 STPD trains is 200 x 200 feet.



NO.	REVISION	DATE	BY	CHKD.

DRUM 40C-0102A & B OXYGEN COMPRESSORS 40ME-0101 REVERSING HEAT EXCHANGERS 40ME-0102 AIR SEPARATION UNIT



NOTES:
 1. THIS DRAWING REPRESENTS ONE TRAIN OF A TWO TRAIN UNIT.
 2. TEMPERATURES, PRESSURES, FLOW QUANTITIES, AND COMPOSITIONS REFERENCED BY DIAMONDS ARE SHOWN ELSEWHERE.

FOR EACH SET OF REPORT OR A
 TO BE IN THE DISTRICTION ON THE
 VOLUME PAGE AT THE FRONT OF THIS REPORT

		R. WHITE G.C. ARATAY J. D'AMICO H. MCCARTHY R. LANG	PROCESS FLOW DIAGRAM OXYGEN PRODUCTION UNIT 40 CROW TRIBE OF INDIANS FUELS FEASIBILITY STUDY	NONE	835704-40-4-101	1	003 03740101
--	--	---	--	------	-----------------	---	--------------

TABLE 6.3.1-1

MATERIAL BALANCE

OXYGEN PRODUCTION - UNIT 40

Stream Number	40-1		40-2		40-3		40-4	
Stream Name	Oxygen Product		Nitrogen Product		Dry Instrument Air		Vent To Atmosphere	
Component	lb-mol/hr	Mol%	lb-mol/hr	Mol%	lb-mol/hr	Mol%	lb-mol/hr	Mol%
N ₂	114.4	1.5	1,592.1	100.0	374.9	78.0	27,651.8	97.4
Ar					4.5	0.9	252.7	1.2
O ₂	7,516.8	98.5			101.1	21.1	395.5	1.4
Total Dry Gas	7,631.2	100.0	1,592.1	100.0	480.5	100.0	28,401.0	100.0
H ₂ O								
Total Wet Gas	7,631.2		1,592.1		480.5		28,401.0	
Dry Gas lb/hr	243,743		44,604		13,926		28,401	
H ₂ O lb/hr								
Steam								
Total lb/hr	243,743		44,604		13,920		28,401	
Pressure, psia	508		63		63			
Temperature, °F	230 (Max)		75		75			

NOTE: Flow quantities, temperatures, and pressures shown are for the total unit on a stream-day design purposes, and are not necessarily the conditions which will be attained during actual

TABLE 6.3.1-1

MATERIAL BALANCE

OXYGEN PRODUCTION - UNIT 40

0-2	40-3		40-4		40-5		40-6	
rogen duct	Dry Instrument Air		Vent To Atmosphere		Process Condensate		HHP Stream	
er Mol%	lb-mol/hr	Mol%	lb-mol/hr	Mol%	lb-mol/hr	Mol%	lb-mol/hr	Mol%
1	100.0	374.9	78.0	27,651.8	97.4			
		4.5	0.9	252.7	1.2			
		101.1	21.1	395.5	1.4			
1	100.0	480.5	100.0	28,401.0	100.0			
1		480.5		28,401.0				
44,604		13,920		28,401		11,009		1,222,200
44,604		13,920		28,401		11,009		1,222,200
63		63						1,463
75		75						925


asures shown are for the total unit on a stream-day basis, are to be used solely for process
y the conditions which will be attained during actual operations.

USE OR DISCLOSURE OF REPORT DATA
IS SUBJECT TO THE RESTRICTIONS ON THE
NOTICE PAGE AT THE FRONT OF THIS REPORT

REDUCED DRAWING SCALE




1/16" = 1'-0"




DATE	BY	DESCRIPTION	CHECKED			
			DATE	BY	DATE	BY
1/11/68		APPROVED FOR STUDY				

USE THE DIMENSIONS OF ANY UNIT DRAWING AS SUBJECT TO THE RESTRICTION ON THE NOTICE PAGE AT THE FRONT OF THIS REPORT



REDUCED PRINT SCALE



REDUCED PRINT SCALE

ALL EQUIPMENT SIZES AND LOCATIONS ARE APPROXIMATE



60-S-030 SITE "1" PLOT PLAN		J. PARODI	PLOT PLAN - UNITS 40E46
		H. HAYES	OXYGEN PRODUCTION AND AIR & NITROGEN
60-S-030 SITE "1" PLOT PLAN	J. PARODI	J. HAYES	CROW TRIBE OF INDIANS
60-S-030 SITE "1" PLOT PLAN	J. PARODI	J. HAYES	MONTANA
60-S-030 SITE "1" PLOT PLAN	J. PARODI	J. HAYES	1"=20'-0"
60-S-030 SITE "1" PLOT PLAN	J. PARODI	J. HAYES	835704-40-4-050
60-S-030 SITE "1" PLOT PLAN	J. PARODI	J. HAYES	1

TABLE 6.3.1-2

EQUIPMENT LIST

OXYGEN PRODUCTION

<u>Item No.</u>	<u>Equipment Name</u>	<u>Number Required</u>	
		<u>Oper.</u>	<u>Spare</u>
40C-0101	Air Compressor	2	0
40C-0102 A/B	Oxygen Compressors	2	2
40E-0101	Air Compressor After Cooler	2	0
40DM-0101	Condensate K.O. Drum	2	0
40ME-0101	Reversing Heat Exchangers	2	0
40ME-0102	Air Separation Unit	2	0
40FT-0101	Inlet Air Filters	2	0
40T-0101	Air Compressor Turbine Driver	2	0

NOTE: Train #2 equipment numbers which are not shown are the same as indicated above except the train designation is 02 instead of 01.

Example:	<u>Train #1</u>	<u>Train #2</u>
	40C-0101	40C-0201

6.3.2 STEAM GENERATION - UNIT 41

6.3.2.1 DESIGN BASIS

Purpose of Unit

The Steam Generation unit produces steam using coal-fired boilers, distributes the steam throughout the plant and uses the cold condensate returning from the power plant for recycle to the boilers. The maximum use of returning condensate reduces the overall plant water makeup.

Scope of Unit

The Steam Generation unit consists of the production, collection, control and distribution of steam at five pressure levels to the process, offsite and utility consumers. Boiler feedwater deaeration is also included in this unit.

General Design Criteria

The Steam Generation unit consists of three 50 percent boilers plus ancillary equipment. Each boiler has a rated capacity of 2.1×10^6 lb/hr of 1500 psig/925°F steam with a normal operating rate of 1.4×10^6 lb/hr. Each boiler has two feed water pumps plus one spare with each pump rated at 2000 gpm. Normal operating flow rate for each pump is 1,400 gpm.

The Steam Generation Unit has the following equipment sparing philosophy:

Boilers - three 50 percent units

Boiler Feedwater Deaerators - 3 deaerators servicing three boilers.

Boiler Feedwater Pumps - 2 operating pumps and one spare per boiler.

6.3.2.1 (Continued)

Boilers are designed for continuous operation of steam supply to the plant. Scheduled shutdown of one boiler train does not affect the plant steam supply.

Drivers above 10,000 HP within the process, utility and offsite units are turbines using 600 psig/760°F steam to condensing.

Boiler Operating Range - 40 to 100% of design

Boiler Control Load - 50 to 100% of design

All steam pressure levels except LP steam have headers designed based on a line loss of 0.5 to 1.0 psi/100 ft. LP steam header is designed based on a line loss ranging from 0.25 to 0.5 psi/100 ft. Condensate return headers are designed for two phase flow.

Process Performance Objectives

The Steam Generation unit supplies and distributes the following levels of steam as required throughout the plant:

1500 psig/925°F superheated steam

600 psig/760°F superheated steam

650 psig/saturated steam

100 psig/saturated steam

60 psig/saturated steam

6.3.2.1 (Continued)

The steam generation unit also provides boiler feed water (BFW) at 1930 psig/ 230°F. The steam generation unit uses returning cold condensate from the power turbine surface condensers. The cold condensate is treated and then stored prior to use as boiler feed water. Demineralized water is used as BFW makeup.

Based on the analysis of Westmoreland coal, a boiler thermal efficiency of 85 percent is expected for the conversion of coal to raise steam.

Feedstock

The Steam Generation coal rate to the boilers is based on 40 percent fines or 7200 T/D (as received) of Westmoreland coal.

Coal Westmoreland (Lurgi Analysis)

<u>Proximate</u> (As received)		<u>Ultimate</u> (Dry Ash Free)	
Moisture	26.0%	Carbon	75.98%
Ash	7.4%	Hydrogen	4.59%
Fixed Carbon	40.1%	Nitrogen	1.09%
Volatiles	26.5%	Sulfur	1.23%
	100.0	Chlorine	.03%
Btu/lb (HHV)	8612.3	Oxygen	17.08%
			100.0
		Btu/lb (HHV)	12931.4

Treated Water

Makeup to boilers 392 gpm

6.3.2.1 (Continued)

Products

Steam

1500 psig/925°F	4,121,400 lb/hr
600 psig/760°F	4,121,300 lb/hr

Boiler Feed Water

HHP BFW	8,284 gpm
---------	-----------

Blowdown

Boiler Blowdown	41 gpm
-----------------	--------

Ash

Fly Ash	35,377 lb/hr
Bottom Ash	8,880 lb/hr

Flue Gas

Temperature, 300°F

<u>Component</u>	<u>Moles/hr</u>	<u>lb/hr</u>	<u>Mole %</u>
CO	11	308	58 ppm
CO ₂	25,280	1,112,585	13.4
H ₂ O	20,060	361,401	10.6
SO ₂	153	9,821	809 ppm
HCl	3	124	16 ppm
O ₂	8,073	258,339	4.3
N ₂	135,473	3,795,115	71.6
NO ₂	56	2,584	296 ppm
TOTAL	189,109	5,540,277	

6.3.2.1 (Continued)

Utilities

Power 32,500 kW Consumed

6.3.2.2 PROCESS DESCRIPTION

The utility flow stetch for the Steam Generation Unit is shown on Drawing No. 835704-41-R-101. The steam distribution system is shown on Drawing No. 835704-41-R-102. The material balance is shown on Table 6.3.2-1. The plot plan is shown on Drawing No. 835704-41-5-050. The equipment list is given in Table 6.3.2-2.

Steam Plant

The boilers are fired with coal fines recovered in the screening process required for obtaining sized coal for gasification. The boilers generate superheated 1500 psig steam to drive turbogenerators in the Power Generation Unit 42 and air compressors in the Oxygen Production Unit 40.

Boiler feed water consists of polished cold condensate from the surface condensers in the Power Generation unit. Makeup water is demineralized water from the BFW and Condensate Treating Unit 45. The BFW is preheated to 180°F with turbine extraction steam from the LP section of the turbogenerators. The preheated BFW is then deaerated.

The deaerator is normally operated at 7 psig and reduces the dissolved oxygen content in the BFW to less than 4 ppb. The temperature of the BFW flow from the deaerators is 230°F.

6.3.2.2 (Continued)

The deaerated BFW is pumped to the boilers by pumps driven by electrical motors. The pump discharge pressure is 1930 psig. The BFW is preheated to 430°F using turbine extraction steam from the LP section of the turbogenerators prior to flowing into the steam drum.

Boiler blowdown is flashed to recover 40 psig steam for BFW deaeration. The remaining blowdown is routed to the Utility Cooling Tower.

Steam Distribution

The process steam distribution system is comprised of distribution piping and controls for five levels of steam. The pressure levels are designated as:

1500 psig, 925°F superheated steam - this level is referred to as high-high pressure steam (HHP).

650 psig, saturated steam - this level is referred to as high pressure saturated steam (HPSAT).

600 psig, 760°F superheated steam - this level is referred to as high pressure superheated steam (HP).

100 psig, saturated steam - This level is referred to as medium pressure steam (MP).

60 psig saturated steam - this level is referred to as low pressure steam (LP).

6.3.2.2 (Continued)

High-High Pressure Steam

The HHP steam is generated in the coal fired boilers. The HHP steam is used to drive turbogenerators in the Power Generation Unit 42 and to drive the air compressors in the Oxygen Production Unit 40.

High Pressure Saturated Steam

The HPSAT steam is generated in process waste heat boilers in the Methanation Unit 22 and the Partial Oxidation Unit 24.

The HPSAT steam is consumed in the following process units:

Tar Distillation
Naphtha Hydrotreating
Phenosolvan
Ammonia Recovery
Partial Oxidation

Excess HPSAT steam is superheated in the Process Steam Superheating Unit 20 to produce high pressure superheated steam.

High Pressure Superheated Steam

The HP steam is exhausted from the backpressure section of the turbogenerators in the Power Generation Unit 42 and is passed through a reheater coil in the boiler before flowing into the HP steam header. Additional HP steam is generated in the Process Steam Superheating Unit 20.

6.3.2.2 (Continued)

The major consumers of HP steam are:

- Coal Gasification
- SNG Compressor Turbine Drivers
- LP Section of the Turbogenerators

The HP steam is also consumed in small amounts by:

- HPSAT steam startup
- MP steam startup
- LP steam startup

Medium Pressure Steam

The MP steam is produced in Gasification Unit 10 waste heat boilers, in Sulfur Recovery Unit 19 and in Partial Oxidation Unit 24. Letdown from the HP steam header is used to maintain pressure in the MP steam header as necessary.

MP steam is consumed in the following process units:

- Rectisol
- Phenosolvan
- Ammonia Recovery
- Tank Farm

MP steam is also used for steam tracing and motive steam for surface condenser ejectors. Any excess is let down to the LP steam header.

6.3.2.2 (Continued)

Low Pressure Steam


LP steam is produced in Gas Cooling Unit 12 and Sulfur Recovery Unit 19. Relatively small amounts are produced by blowdown flash drums from process waste heat boilers and by steam condensate flash drums. The LP steam header pressure is maintained, as necessary, by letdown from the MP steam header.

LP steam is consumed in the following units:


- Rectisol
- Tar Distillation
- Naphtha Hydrotreating
- Phenosolvan
- Sulfur Recovery
- Tank Farm
- Wastewater Treating

LP steam is also used in process BFW deaerators. During system upsets excess LP steam is vented to the atmosphere to control header pressure.

41ME-0106 MORPHOLINE INJECTION SYSTEM
 41ME-0107 HYDRAZINE INJECTION SYSTEM
 41DA-0101 HIGH-HIGH PRESSURE SERVICE DEAERATOR
 41HO-0101 SURGE HOPPER 7,200 TONS
41ME-0108 PHOSPHATE INJECTION SYSTEM



41HO-0101 SURGE HOPPER 7,200 TONS
 41FD-0101A/B VIBRATING FEEDERS
 41ME-0101A/B BELT CONVEYORS
 41DM-0101 BLOWDOWN FLASH DRUM
 41HO-0102A THRU D BOILER SILOS CAP: 200 TONS EACH
 41FD-0102A THRU D GRABBER FEEDERS
 41ME-0102A THRU D COAL PULVERIZERS
 41BO-1.500 BOILER




4180-0101
1,500 PSIG
BOILER

41ME-0103A/B
REGENERATIVE
AIR HEATERS

41C-0104A/B
SEAL AIR FANS

41C-010
FORCED DRA



DRAWING NO.	REV.	FRAME
B357D4-41-R-101	1	2 OF 2

4

3

41ME-0103A/B
REGENERATIVE
AIR HEATERS

41C-0104A/B
SEAL AIR FANS


41C-0101A/B
FORCED DRAFT FANS

41C-0102A/B
PRIMARY AIR FANS

41ME-0104
ELECTROSTATIC
PRECIPITATOR

41C-0103A/B
INDUCED DRAFT FANS

NOTE 11



FLY ASH TO
ASH HANDLING
UNIT 43


REVISIONS	
NO.	DESCRIPTION

3

2

41C-D103A/B
INDUCED DRAFT FANS

41ME-D105
BOILER STACK



NOTES:

1. EQUIPMENT WITHIN DOT-DASHED LINES REPRESENT ONE TRAIN OF A THREE TRAIN UNIT.
2. TEMPERATURES, PRESSURES, FLOW QUANTITIES AND COMPOSITIONS REFERENCED BY DIAMONDS ARE SHOWN SEPARATELY.

USE OR DISCLOSURE OF REPORT DATA IS LIMITED TO THE RESTRICTION ON THE FRONT PAGE AT THE FRONT OF THIS REPORT

FLUOR


DESIGNED BY
R. WHITE
CHECKED BY
G. E. ABATAY
APPROVED BY
R. M. CARLINO
DATE
R. LANG

PROCESS FLOW DIAGRAM
STEAM GENERATION
UNIT 41

LOW TRIBE OF INDIANS
SYNTHETIC FUELS FEASIBILITY STUDY
NONE
835704-41-R-101
MICROFILM FRAME NO. 1 OF 2

003 35741101

41ME-0121
HP TO MP DESUPERHEATER



41DM-0102
 HP BLOWDOWN
 FLASH DRUM

NAPHTHA
 HYDROTREATING
 UNIT 16

TAR DISTILLATION
 UNIT 15


WASTEWATER
 TREATING
 UNIT 54

METHA
 UNIT

PARTIAL
 OXIDATION
 UNIT 24
 NOTE:
 650 PSIG/547°F
 CONSUMPTION 11,500 LBS/HR
 PRODUCTION 18,300 LBS/HR
 NET PROD. 6,800 LBS/HR

TANK FARM
 UNIT 55


GEN PURIFIC
 AND COMPRES
 UNIT 2



DRAWING NO.	REV.	FRAME
635704-41-R-132	1	2 OF 2

4

3



LEGEND:

○ FLOW 1000 LBS/AH

NOTES:


1. THE TEMPERATURES TO BE USED

NO.	DATE	REVISION	BY	CHKD.

FLUOR

DESIGNED BY: **D. W. HALVORSON**
 CHECKED BY: **J. B. STANTON**
 DRAWN BY: **J. B. STANTON**
 DATE: **11/15/68**
 PROJECT: **STEAM**

NOTES:
 1. THIS DRAWING HAS BEEN REVISED AND IS THE ONLY PORTION OF FLUOR'S DESIGN AND CONSTRUCTION. IT IS NOT TO BE USED FOR THE DESIGN OR CONSTRUCTION OF ANY OTHER PROJECT.
 2. THE DESIGNER'S NAME AND ADDRESS IS TO BE PRINTED ON ALL DRAWINGS.
 3. ALL DIMENSIONS ARE TO BE GIVEN IN FEET AND INCHES.
 4. ALL DIMENSIONS ARE TO BE GIVEN TO THE CENTERLINE UNLESS OTHERWISE SPECIFIED.
 5. ALL DIMENSIONS ARE TO BE GIVEN TO THE SURFACE UNLESS OTHERWISE SPECIFIED.
 6. ALL DIMENSIONS ARE TO BE GIVEN TO THE CENTERLINE UNLESS OTHERWISE SPECIFIED.
 7. ALL DIMENSIONS ARE TO BE GIVEN TO THE SURFACE UNLESS OTHERWISE SPECIFIED.



LEGEND:
 FLOW 1000 LBS/HR

NOTES:
 1. THE TEMPERATURES, PRESSURES AND FLOW QUANTITIES SHOWN ARE TO BE USED SOLELY FOR PROCESS DESIGN PURPOSES.

USE OR DISSEMINATION OF THIS REPORT IS SUBJECT TO THE RESTRICTIONS ON THE NOTICE PAGE AT THE FRONT OF THIS REPORT

FLUOR		PROCESS FLOW DIAGRAM	
STEAM GENERATION - STEAM DISTRIBUTION SYSTEM		UNIT 41	
SYNTHESIS FEASIBILITY STUDY		835704-41-R-102	
MICROFILM FRAME NO. 1 OF 2		1	

APPROVED BY: _____ DATE: _____

DESIGNED BY: _____

CHECKED BY: _____

DATE: _____

SCALE: _____

PROJECT NO: _____

REV: _____

TA
MATE
STEAM GEN

Stream Number	41-1	41-2	41-3	4
Stream Name	Coal Fines	Demineralized Water	Cold Condensate	HP B S
Component	Lb-mol/hr Mol%	Lb-mol/hr Mol%	Lb-mol/hr Mol%	Lb-m
N ₂				
O ₂				
CO				
CO ₂				
SO ₂				
HCl				
NO ₂				
<hr/>				
Total Dry Gas				
H ₂ O				
Total Wet Gas				
<hr/>				
Dry Gas, lb/hr				
H ₂ O, lb/hr		196,100	2,912,800	
Steam, lb/hr				4,1
Coal, lb/hr	600,000			
Parti- culates, lb/hr				
<hr/>				
Total, lb/hr	600,000	196,100	2,912,800	4,121
Pressure, psia		88	88	
Temperature, °F		80	80	

NOTE: The flow quantities, temperatures, and pressures shown are for design purposes, and are not necessarily the conditions which will

TABLE 6.3.2-1



MATERIAL BALANCE

STEAM GENERATION - UNIT 41

41-4		41-5		41-6		41-7		41-8		41-9	
HP Exhaust Steam		Reheat Steam		HHP Steam		Boiler Flue Gas		Process Steam Superheating Flue Gas		Flue Gas To Stack	
Mol%	Lb-mol/hr	Mol%	Lb-mol/hr	Mol%	Lb-mol/hr	Mol%	Lb-mol/hr	Mol%	Lb-mol/hr	Mol%	Lb-mol/hr
						135,473	80.14	11,169	33.42	147,873	72.53
						8,073	4.78	642	1.92	9,043	4.44
						11	0.01	Trace	-	11	-
						25,280	14.95	21,602	64.64	46,882	23.00
						153	0.09	3	-	18	-
						3	-	-	-	-	-
						56	0.03	5	0.02	61	.03
						169,949	100.0	33,421	100.0	203,877	100.0
						20,060		3,327		36,296	
						189,109		36,748		240,173	
						5,178,876		1,284,596		6,497,327	
						361,401		59,934		653,376	
4,121,400		4,121,400		4,121,400							
						143				143	
4,121,400		4,121,400		4,121,400		5,540,420		1,844,530		7,150,846	
663		613		1513		13.3		13.5		13.1	
710		760		930		300		400		175	

shown are for the total unit on a stream-day basis, are to be used solely for process design which will be attained during actual operations.


USE ON PAGES 1-10 OF REPORT DATA
IS SUBJECT TO THE RESTRICTIONS ON THE
NOTICE PAGE AT THE FRONT OF THIS REPORT



SECTION A-A
1/20"

NO.	DATE	REVISION
1		APPROVED FOR STUDY

USE OR DISCLOSURE OF REPORT DATA IS SUBJECT TO THE RESTRICTION ON THE NOTICE PAGE AT THE FRONT OF THIS REPORT



REV.	DATE	DESCRIPTION	BY	CHKD.
1	03-0-80	WTR'S PLOT PLAN		

FLUOR

1/4 MILE
CONTRACT

CONTRACT NO. 833701-41-5-050

SCALE: 1"=30'-0"

PROJECT: PLOT PLAN - UNIT 4142.13
STEAM & POWER GENERATION,
FLUE GAS DESULFURIZATION

DATE: 03-0-80

PROJECT NO.: 833701-41-5-050

TABLE 6.3.2-2

EQUIPMENT LIST

OXYGEN PRODUCTION

<u>Item No.</u>	<u>Equipment Name</u>	<u>Number Required</u>	
		<u>Oper.</u>	<u>Spare</u>
41E-0101	1st BFW Preheater	3	0
41E-0102	2nd BFW Preheater	3	0
41E-0103	3rd BFW Preheater	3	0
41E-0104	4th BFW Preheater	3	0
41E-0105	5th BFW Preheater	3	0
41E-0106	6th BFW Preheater	3	0
41C-0101 A/B	Force Draft Fans	3	3
41C-0102 A/B	Primary Air Fans	3	3
41C-0103 A/B	Induced Draft Fans	3	3
41C-0104 A/B	Seal Air Fans	3	3
41DA-0101	High-High Pressure Service Deaerators	3	0
41BO-0101	1500 psig Boilers	3	0
41HO-0101	Surge Hopper	1	0
41HO-0102 A/B/C/D	Boiler Silos	12	
41P-0101 A/B/C	BFW Pumps	6	3
41DM-0101	Blowdown Flash Drum	3	0
41DM-0102	HP Blowdown Flash Drum		

TABLE 6.3.2-2 (Continued)

EQUIPMENT LIST

OXYGEN PRODUCTION

<u>Item No.</u>	<u>Equipment Name</u>	<u>Number Required</u>	
		<u>Oper.</u>	<u>Spare</u>
41FD-0101 A/B	Vibrating Feeders	2	0
41FD-0102 A/B/C/D	Gravimetric Feeders	12	0
41ME-0101 A/B	Belt Conveyors	2	0
41ME-0102 A/B/C/D	Coal Pulverizers	12	0
41ME-0103 A/B	Regenerative Air Heaters	6	0
41ME-0104	Electrostatic Precipitators	3	0
41ME-0105	Boiler Stack	1	0
41ME-0106	Morpholine Injection System	3	0
41ME-0107	Hydrozine Injection System	3	0
41ME-0108	Phosphate Injection System	3	0
41ME-0121	HP to MP Desuperheater	1	0

6.3.3 POWER GENERATION - UNIT 42

6.3.3.1 DESIGN BASIS

Purpose of Unit

The Power Generation Unit provides electric power for process, offsites and utility consumers. The Power Generation unit produces electric power in excess of the power required for total plant self-sufficiency. Export of this electric power is considered in the design.

Scope of Unit

The Power Generation unit consists of a stand-alone, onsite power plant, power distribution system and an uninterruptible power system for critical users. The integration of the Power Generation unit into the overall plant is shown on Figure 6.3.3-1.

General Design Criteria

The Power Generation unit will consist of three multistage reheat turbogenerators. Each turbogenerator will produce 135.0 MW of electric power.

Due to the high reliability of the turbogenerators, a spare turbogenerator train will not be required. Also, in the event of an emergency, power can be taken from an electrical grid source external to the plant (see Section 6.3.20, Electrical Distribution, in this volume).

The turbogenerators are designed for continuous operation. The onstream factor is compatible with the overall plant onstream factor of 332 days/year.

6.3.3.1 (Continued)

Process Performance Objectives

Power plant generation will be at 24,000 volts.

Power is supplied as follows:

<u>User</u>	<u>Voltage</u>	<u>Cycles</u>	<u>Phase</u>
Motors above 151 BHP	4,000	60	3
Motors below 151 BHP	400	60	3
Lighting, Instrumentation, etc.	240/120	60	1

Utilities

Steam


Consumed (1)	1500 psig/925°F	2.9 x 10 ⁶ lb/hr
	600 psig/760°F	3.8 x 10 ⁶ lb/hr
	100 psig/sat'd (ejectors)	78,700 lb/hr

Cooling Water	162,300 gpm
Power	310 kW

Produced	Condensate	2.91 x 10 ⁶ lb/hr
	Power	405 MW

(1) Steam exits the unit at 650 psig for reheat and inclusion in 600 psig 760°F flow.

FIGURE 6.3.3-1
POWER GENERATION INTERFACE WITH PROCESS PLANT



USE OR DISCLOSURE OF REPORT DATA
IS SUBJECT TO THE RESTRICTION ON THE
NOTICE PAGE AT THE FRONT OF THIS REPORT

6.3.3.2 PROCESS DESCRIPTION

The utility flow sketch for the Power Generation Unit is shown on Drawing No. 835704-42-4-101. The material balance is shown on Table 6.3.3-1 and the equipment list (Table 6.3.3-2) follows.

Power Plant

The power plant is designed to supply total plant requirement and export power for sales. Power is generated onsite by three parallel units of 135 MW turbogenerators. The generators are hydrogen cooled and rated a 24 kV. Power Generation by parallel units of 135 MW turbogenerators provides reliable and flexible supply of power to the Process and Utility/Offsite units in the plant. The total plant load for the Westmoreland 40 percent fines SNG case is 121.8 MW. Power in excess of plant requirements is approximately 283.2 MW.


The power plant is fully integrated with the Steam Generation Unit 41 which supplies 1500 psig/925°F steam to the back pressure section of the turbogenerators. The exhaust steam exits the turbine at 650 psig/710°F. This exhaust steam is reheated in the boilers to provide 600 psig/760°F steam for plant use and to generate additional power. A major portion of the reheated steam is sent back to the Power Generation unit and is used in the condensing section of the turbogenerators to generate additional power. The condensing section of the turbogenerators have several extraction ports to supply steam used for BFW preheating and BFW deaeration.

Cooling water is used to condense the exhaust steam from the LP section of the turbogenerators. Design condensing pressure is four inches Hg absolute. The cold condensate is pumped to the BFW & Condensate Treating Unit 45 where it is treated in a mixed bed de-ionization unit and recycled for use as BFW.

6.3.3.2 (Continued)


Power Distribution

The Power Distribution system is discussed in Section 6.3.20 of this report.



NO.	DATE	REVISION

42GE-D101
 1300 PSIG/600 PSIG TURBINE
 GENERATOR SET



NOTES:

1. THIS DRAWING REPRESENTS ONE TRAIN OF A THREE TRAIN UNIT.
2. TEMPERATURES, PRESSURES, FLOW QUANTITIES AND COMPOSITIONS REFERENCED BY DIAMOND SYMBOLS AND POWER GENERATION DATA REFERENCED BY HEXAGONS ARE SHOWN SEPARATELY.

USE ORIGINAL'S SET OF REPORT DATA
 TO VERIFY THE RESTRICTION IN THE
 NOTICE PAGE AT THE FRONT OF THIS REPORT

		D. P. HALVERSON R. C. ARATAY R. J. BELMOTO R. MCCARTHY R. LANG	PROCESS FLOW DIAGRAM POWER GENERATION UNIT 42	CROW TRIBE OF INDIANS SYNUELS FEASIBILITY STUDY
<small>WHEN THIS DRAWING HAS BEEN PUBLISHED AND IS THE SOLE PROPERTY OF FLUOR INDUSTRIES AND ENGINEERS, INC. AND IN LINE TO THE EXTENT PERMITTED BY LAW AND IN CONNECTION WITH THE DESIGN OF THIS DRAWING, THE SUPPLIER HEREBY AGREES TO RETURN IT UPON REQUEST AND ACKNOWLEDGE THAT IT SHALL NOT BE REPRODUCED, COPIED, OR OTHERWISE DISCLOSED BY ANY MEANS TO ANY OTHER PERSON WITHOUT THE WRITTEN CONSENT OF FLUOR INDUSTRIES AND ENGINEERS, INC.</small>		NONE	835704-42-4-101 1	

003 35742101

TABLE 6.3.3-1

MATERIAL BALANCE

POWER GENERATION - UNIT 42

Stream Number	42-1	42-2	42-3	42-4	42-5	42-10
Stream Name	Reheat Steam	HHP Steam	Condensate HP Exhaust Steam	From LP Heaters	Cold Condensate	Power Output
H ₂ O lb/hr	3,795,600	2,899,200	2,899,200	289,500	2,912,800	
Total lb/hr	2,795,600	2,899,200	2,899,200	289,500	2,912,800	405.0

Pressure, psia	563	1463	663		3.5	110
Temperature, °F	756	925	710		90	125

NOTE: Flow quantities, temperatures, and pressures shown are for the total unit on a stream-day basis, are to be used solely for process design purposes, and are not necessarily the conditions which will be attained during actual operations.

TABLE 6.3.3-2

EQUIPMENT LIST

POWER GENERATION - UNIT 42

<u>Item No.</u>	<u>Equipment Name</u>	<u>Number Required</u>	
		<u>Oper.</u>	<u>Spare</u>
42E-0101	HP Turbine Surface Condenser	3	0
42P-0101 A/B	HP Vacuum Condensate Pump	3	3
42GE-0101	1500 psig/600 psig Turbine Generator Set	3	0

NOTE: Train #2 and Train #3 equipment numbers which are not shown are the same as indicated above except the train designation is 02 or 03 instead of 01.

Example:	<u>Train #1</u>	<u>Train #2</u>	<u>Train #3</u>
	42E-0101	42E-0201	42E-0301

6.3.4 FLUE GAS DESULFURIZATION - UNIT 43

6.3.4.1 DESIGN BASIS

Purpose of Unit

The purpose of the Flue Gas Desulfurization unit is to reduce the SO₂ emissions from the coal-fired boiler plant.

Scope of Unit

The unit consists of facilities for SO₂ absorption, oxidation of SO₂ to SO₄²⁻, precipitation of gypsum, chemical makeup, and waste solids concentration.

General Design Criteria

The unit has three 50 percent capacity trains of absorption and oxidation. The chemical makeup systems and solids thickener are single train systems. The gypsum filtering consists of two 50 percent trains. Sufficient spare capacity is provided such that continuous SO₂ removal is expected.

Process Performance Objectives

The sulfur removal efficiency is 90 percent based on 0.82 weight percent sulfur as received in the coal feed to the boilers.

6.3.4.1 (Continued)

Feedstock

Boiler Flue Gas

<u>Component</u>	<u>moles/hr</u>
O ₂	8,073
N ₂	135,473
CO	11
CO ₂	25,280
H ₂ O	20,060
SO ₂	153
NO ₂	56
HCl	3
TOTAL	189,109
Temperature	300°F

Products

Flue Gas to Stack

<u>Component</u>	<u>moles/hr</u>
O ₂	8,401
N ₂	136,704
CO	11
CO ₂	25,280
H ₂ O	32,969
SO ₂	15
NO ₂	56
TOTAL	203,436
Temperature	128°F

6.3.4.1 (Continued)

Gypsum

32,350 lb/hr

Utility and Chemical Requirements

Lime	8,792 lb/hr
Formic Acid	117 lb/hr
Water Makeup	244,000 lb/hr
Power	5,070 kW

6.3.4.2 PROCESS DESCRIPTION

The process flow sketch for Unit 43 is shown on Drawing No. 835704-43-4-101. The unit material balance (Table 6.3.4-1) and the equipment list (Table 6.3.4-2) follow the drawing.

The Davy McKee Saarberg-Hoelter FGD process is a wet scrubbing process using lime for SO₂ removal. The process has four main steps: SO₂ absorption, oxidation, lime addition, and solids separation.

The boiler flue gas is contacted co-currently with the lime washing solution. Calcium ions in the form of calcium hydroxide, Ca(OH)₂, calcium formate, Ca(COOH)₂, and calcium chloride, CaCl₂, in the solution are used to absorb sulfur dioxide from the flue gas. The absorbed SO₂ reacts to form calcium bisulfite, Ca(HSO₃)₂, which is water soluble.

In the oxidizer, air contacts the solution and converts bisulfite ion, HSO₃⁻, to sulfate ions which react with the calcium ions to form calcium sulfate dihydrate (gypsum) crystals. The oxidizer solution overflows into the mixing channel and to the thickener.

6.3.4.2 (Continued)

In the mixing channel, lime in the form of slurred lime, $\text{Ca}(\text{OH})_2$, is added to the scrubbing fluid. Lime is added to replenish calcium ions (consumed by the formation of gypsum in the oxidizer) and to adjust the pH value to that required for SO_2 absorption. A small amount of formic acid is added to maintain calcium solubility in the clean solution.

The gypsum crystals formed in the oxidizer and mixing channel are separated from the washing fluid in the thickener. The crystals are pumped from the bottom of the thickener to a vacuum filter. The vacuum filter produces a gypsum cake containing approximately 77 percent solids (23 percent free H_2O). The filtrate is recirculated to the thickener. The clear overflow from the top of the thickener is returned to the absorber as washing fluid.

43C-0101
OXIDIZER AIR BLOWER


43VL-0101A-F
ABSORBER

43VL-0102
OXIDIZER

43ME-0101
MIST ELIMINATOR

43ME-0102
LINE SLAKING
SYSTEM

43ME-0103
CHEMICAL ADDITIO
SYSTEM




REV	DATE	BY	CHKD

3ME-0103
CAL ADDITION
SYSTEM

43TH-0101
THICKENER

43FT-0101
VACUUM FILTER

0103



NOTES:

1. THE FLOW QUANTITIES, COMPOSITIONS AND CONDITIONS REFERENCED BY DIAMONDS ARE SHOWN ELSEWHERE.
2. THIS DRAWING IS A SIMPLIFIED FLOW DIAGRAM OF A PROPRIETARY UNIT. STREAM CONFIGURATIONS AND/OR EQUIPMENT ARE NOT COMPLETELY REPRESENTED.

SEE NOTICE PAGE AT THE FRONT OF THIS REPORT

<p>FLUOR</p> <p>ENGINEERING CONSULTANTS</p>		<p>DESIGNED BY R. WHITE</p> <p>CHECKED BY C. C. ABATAY</p> <p>APPROVED BY R. J. PARTRIDGE</p> <p>DATE APR 11 1964</p>	<p>PROCESS FLOW DIAGRAM FLUE GAS DESULFURIZATION UNIT 43</p>		<p>101E4745</p>
<p>PROJECT: CROW TRIBE OF INDIANS FUELS FEASIBILITY STUDY</p>		<p>SCALE: AS SHOWN</p>	<p>DATE: APR 11 1964</p>	<p>1</p>	

TABLE 6.3.4-1

MATERIAL BALANCE

FLUE GAS DESULFURIZATION - UNIT 43

Stream Number	43-1	43-2	43-3
Stream Name	Flue Gas From Unit 41	Lime	Raw Water Makeup
Component	lb mol/hr	mol %	
N ₂	135,473	80.14	
O ₂	8,073	4.78	
CO ₂	35,380	14.95	
CO	11	0.01	
NO ₂	56	0.03	
HCl	3	0.002	
SO ₂	153	0.09	
Total Dry Gas	169,049	100.00	
H ₂ O	20,060		
Total Wet Gas	189,109		
Dry Gas, lb/hr	5,178,876		
H ₂ O, lb/hr	361,401	244,000	
Lime, lb/hr		8,792	
Dry Gypsum, lb/hr			
Particulates, lb/hr	143		
Total, lb/hr	5,540,420	8,792	244,000
Pressure, psia	13.3		
Temperature °F	300		

NOTE: Flow quantities, pressures and temperatures shown are for the total unit on a stream-day design purposes, and are not necessarily the conditions which will be attained during actual

TABLE 6.3.4-1

MATERIAL BALANCE

FLUE GAS DESULFURIZATION - UNIT 43

	43-2	43-3	43-4	43-5
is	Lime	Raw Water Makeup	Flue Gas to Unit 41	Gypsum to Unit 03
1				
ol %			lb mol/hr	mol %
.14			136,704	80.19
.78			8,701	4.93
.95			25,280	14.83
.01			11	0.01
.03			56	0.03
.002				
.09			15	0.01
1.00			170,467	100.00
			32,969	
			203,436	
			5,212,731	
		244,000	593,442	7,418
	8,792			
			143	24,832
	8,792	244,000	5,806,316	32,350
1.3				13.1
				128

res shown are for the total unit on a stream-day basis, are to be used solely for process the conditions which will be attained during actual operations.

USE OR OMISSION TO REPORT DATA
IN SUBJECT TO THE INSTRUCTIONS ON THE
REFERENCE PAGE AT THE FRONT OF THIS REPORT

TABLE 6.3.4-2

EQUIPMENT LIST

FLUE GAS DESULFURIZATION - UNIT 43

<u>Equipment Number</u>	<u>Equipment Name</u>	<u>No. Required</u>	
		<u>Operating</u>	<u>Spare</u>
43 VL-0101 A-F (1)	Absorber	18	0
43 VL-0102 (1)	Oxidizer	3	0
43 TH-0101	Thickener	1	0
43 FT-0101 (2)	Vacuum Filter	2	0
43 ME-0101 (1)	Mist Eliminator	3	0
43 ME-0102	Lime Slaking System	1	0
43 ME-0103	Chemical Addition System	1	0
43 C-0101 (1)	Oxidizer Air Blower	2	1
43 P-0101 (1)	Washing Fluid Pump	2	1
43 P-0102 A/B	Filter Feed Pump	1	1
43 P-0102 (2)	Filtrate Pump	2	0

NOTES: (1) Part of a three train area. Equipment numbers for Train #2 and Train #3 are the same as indicated above except the train designation is 02 or 03 instead of 01.

Example: Train #1 Train #2 Train #3
 43VL-0102 43VL-0202 43VL-0302

(2) Part of a two train area.