


NOTES:

1. BOILER DESIGN MEETS EPA CODE OF FEDERAL REGULATIONS-TITLE 40 EMISSION LIMITS:
SO_x = 1.2 LB/MMBTU
NO_x = 0.8 LB/MMBTU
PARTICULATES = 0.03 LB/MMBTU
2. BOILER FEED COAL = 98.6 T/MRIAS RECEIVED).
GASIFIER FEED COAL = 450 T/MRIAS RECEIVED).
3. COMPOSITION AND DURATION OF GASIFIER START-UP VENT ARE CONFIDENTIAL LURGI INFORMATION.
MAXIMUM EMISSIONS:
SO₂ = 372 LBS/HR
HYDROCARBONS = 468 LBS/HR
4. CATALYST REDUCTION REQUIRES FUEL GAS. FLOW SHOWN IS OF SHORT DURATION.
5. SO₂ VENTED IS BASED ON FGD REMOVAL EFFICIENCY OF 90%.
6. PARTICULATES VENTED ARE BASED ON AN EXIT CONCENTRATION OF 0.013 gr/SCF. OVERALL REMOVAL EFFICIENCY IS 99.7%.
7. HEATER FLUE GAS EMISSIONS ESTIMATED BASED ON THE FOLLOWING HEATER DUTY:
TAR DISTILLATION 12.2 MMBTU/HR
8. HYDROCARBON EMISSIONS FROM STORAGE TANKS BASED ON FLOATING ROOF DESIGN WITH SECONDARY SEALS AND VAPOR RECOVERY SYSTEMS UTILIZED ON CONE ROOF TANKS.
9. THE TEMPERATURES, FLOW QUANTITIES AND COMPOSITIONS SHOWN ARE TO BE USED SOLELY FOR PROCESS DESIGN PURPOSES AND ARE NOT NECESSARILY THE CONDITIONS WHICH WILL BE ATTAINED DURING ACTUAL OPERATIONS.

USE OF INFORMATION OF REPORT DATA IS LIMITED TO THE EXTENT OF THE SPACE PAGE AT THE FRONT OF THIS REPORT


		BLOCK FLOW DIAGRAM AIR EMISSIONS	
D.P. HALVERSON G.G. ABATAY W.D. BELMUTO R. J. BARTHY R. LANG		CASE: WESTMORELAND COAL-POWER SELF-SUFFICIENCY CROW TRIBE OF INDIANS FUELS FEASIBILITY STUDY	
NONE		835704-00-4-205	

50200101




(NOTE 1) 1 COAL	(NOTE 2 - 4) 2 ASH	(NOTE 3) 3 FGD GYPSUM	4 RAW WATER TREATMENT SLUDGE	5 WATER TREATING
TRACE ELEMENTS	MINERAL ASH ANALYSIS	WT%	WT%	WT%
ANTIMONY 0.67	SiO ₂ 35.8	H ₂ O 73.0	CaCO ₃ 55.5	SPENT ACTIVATED CARBON 41.9
ARSENIC 1.77	Al ₂ O ₃ 19.2	CaSO ₄ ·2H ₂ O 75.0	Water 0.5	SPENT ION EXCHANGE RESIN 58.1
BARIUM 181.60	Fe ₂ O ₃ 7.8	CaCl ₂ 0.5	H ₂ O 40.0	MISCELLANEOUS 3.6
BERYLLIUM 1.25	H ₂ O 3.0	INERT SOLIDS 1.5		
BORON 218.80	CaO 0.18	Ca(OH) ₂ TRACE		
BROMINE 19.35	CaO 14.5	Ca(COOH) ₂ TRACE		
CADMIUM 1.80	MnO 2.4			
CERIUM 17.64	TiO ₂ 1.2			
CHROMIUM 6.38	P ₂ O ₅ 0.28			
COBALT 3.62	SO ₂ 14.1			
COPPER 21.42	INDETERMINATE 1.74			
FLUORINE 227.42				
LEAD 3.30				
LITHIUM 35.20				
MANGANESE 202.00				
MERCURY 0.08				
NICKEL 7.42				
SELENIUM 1.30				
SILVER 0.08				
STRONTIUM 197.02				
THALLIUM 0.23				
URANIUM 1.43				
VANADIUM 18.48				
ZINC 15.70				
ZIRCONIUM 126.00				

- NOTES:
- TRACE ELEMENT ANALYSIS FROM WESTMORELAND MINE ENVIRONMENTAL IMPACT STATEMENT.
 - MINERAL ASH ANALYSIS BASED ON LURCI DATA. WESTMORELAND MINE. GASIFIER ASH ALSO CONTAINS 4% CARBON.
 - AMOUNT OF GASIFIER ASH CALCULATED BASED ON 450 T/MR GASIFIER COAL CONSUMED.
 - AMOUNT OF BOILER ASH CALCULATED BASED ON 98.5 T/MR BOILER COAL CONSUMED.
 - TOTAL GYPSUM PRODUCED BASED ON FGD LICENSOR INFORMATION.
 - THE CLEAN STORM WATER PONDS ARE CLEANED AS NECESSARY. THE AMOUNT OF SOLIDS REMOVED FROM THESE PONDS IS INDETERMINATE.
 - THE COMPOSITIONS OF THE INCINERATOR WASTE AND UCT BLOWDOWN TREATMENT SLUDGE ARE NOT AVAILABLE.
 - THE FLOW QUANTITIES AND COMPOSITIONS SHOWN ARE TO BE USED SOLELY FOR PROCESS DESIGN PURPOSES AND ARE NOT NECESSARILY THE CONDITIONS WHICH WILL BE ATTAINED DURING ACTUAL OPERATIONS.



DATE	BY	REVISION



USE OR DISCLOSURE OF REPORT DATA IS SUBJECT TO THE RESTRICTION ON THE NOTICE PAGE AT THE FRONT OF THIS REPORT

ALL INFORMATION CONTAINED HEREIN IS UNCLASSIFIED EXCEPT WHERE SHOWN OTHERWISE




DESIGNED BY
R. WHITE
C.C. ARATY
B. O'NEAL
R. MCCARTHY
IRLAND


**BLOCK FLOW DIAGRAM
 SOLID EFFLUENT**
 CASE: WESTMORELAND COAL - POWER SELF-SUFFICIENCY
 CROW TRIBE OF INDIANS
 SYN-FUELS FEASIBILITY STUDY


NONE 835704-00-4-206

001 35700206

NOTICE: THIS DRAWING HAS BEEN PUBLISHED AND IS THE SOLE PROPERTY OF FLUOR CORP. AND SUBSIDIARIES. IT IS TO BE USED ONLY FOR THE PROJECT AND FOR THE CLIENT'S USE ONLY. IT IS NOT TO BE REPRODUCED, COPIED, OR TRANSMITTED IN ANY FORM OR BY ANY MEANS, ELECTRONIC OR MECHANICAL, INCLUDING PHOTOCOPYING, RECORDING, OR BY ANY INFORMATION STORAGE AND RETRIEVAL SYSTEM, WITHOUT THE WRITTEN PERMISSION OF FLUOR CORP. AND SUBSIDIARIES.








DRAWING NO. | REV | FRAME
 1835704-00-R-207 | 1 | 2 OF 2


4

3



NOTES:
1. THE TEMPERATURES ARE TO BE

FLUOR		DRAWN BY: R. WHITE CHECKED BY: G.C. ARATAY PROJECT ENGINEER: R. MCCARTHY PROJECT MANAGER: R. LANG
I HEREBY CERTIFY THAT THIS DRAWING WAS PREPARED BY ME OR UNDER MY CLOSE PERSONAL SUPERVISION AND THAT I AM A LICENSED PROFESSIONAL ENGINEER IN THE STATE OF TEXAS.		CASE: 11111 DRAWING NO: 11111 SHEET NO: 11111



NOTES:

1. THE TEMPERATURES, PRESSURES, FLOW QUANTITIES SHOWN ARE TO BE USED ONLY FOR PROCESS DESIGN PURPOSES.

USE OF DESIGN DATA IS SUBJECT TO THE RESTRICTION ON THE NOTICE PAGE AT THE FRONT OF THIS REPORT

FLUOR

R. WHITE
C.C. ABATY
W.D. BELWITZ
R. MCCARTHY
R. LANG
SALVENDY

**BLOCK FLOW DIAGRAM
PLANT STEAM BALANCE**

CASE: WESTMORELAND COAL - POWER SELF-SUFFICIENCY
CROW TRICE OF INDIANS

SYN-FUELS FEASIBILITY STUDY

835704-00-R-207

NONE

MICROFILM FRAME NO. 1 OF 2

1000051 100

6.4.9 UTILITY SUMMARY

Table 6.4.9-1 indicates the utilities generated or consumed by each process or utility unit in the Westmoreland Coal-Power Self-sufficiency Case.

CASE: Westm

Unit	STEAM (M lb/hr)			
	1500 lb 925°F	650 lb Sat'd	600 lb 760°F	100 lb Sat'd
01 Coal Screening				
02 Coal Distribution				
03 Ash Handling				
10 Coal Gasification			-1090.9	+566.
11 CO Shift				
12 Gas Cooling				
13 Rectisol				-46.
14 Gas Liquor Separation				
15 Tar Distillation		-7.6		
16 Naphtha Hydrotreating		-10.2		
17 Phenosolvan		-3.4		-5.
18 Ammonia Recovery		-80.0		-142.
19 Sulfur Recovery				+21.
20 Process Steam Superheating		-722.8	+910.8	
21 Methanol Synthesis		(+2.8)		
22 Methanation		+817.2		
23 SNG Compression and Purification			-145.7	-4.
24 Partial Oxidation		+6.8		+38.
25 PSA Hydrogen Production				
40 Oxygen Production			-317.6	-9.
41 Steam Generation	+1359.9	-1359.9 ⁽¹⁾	+1158.0	-384.
42 Power Generation	-1359.9	+1359.9 ⁽¹⁾	-514.6	-15.
43 Flue Gas Desul- furization				
44 Raw Water Treating				
45 BFW and Condensate Treating				

TABLE 6.4.9-1

UTILITY SUMMARY

USE OR DISCLOSURE OF REPORT DATA
IS SUBJECT TO THE RESTRICTION ON THE
NOTICE PAGE AT THE FRONT OF THIS REPORT

Westmoreland Coal - Power Self-sufficiency

/hr)	100 lb	60 lb	Condensate	BFW	Steam and	Cooling Water		Electric	Fuel Gas
	Sat'd	Sat'd	(M lb/hr)	(M lb/hr)	Condensate	(MM Btu/hr)	(gpm)	Power	(MM Btu/hr)
					(M lb/hr)			(MW)	
								-0.7	
								-0.07	
								-0.70	
9	+566.6			-690.7	1215.0	-8.27	-551	-2.40	-0.7
		+126.5		-128.4	1.9	-9.14	-609	-0.35	
	-46.7	-91.7	+138.4	-37.9	37.9	-204.40	-13613	-22.90	+329.7
						-83.30	-5548	-0.69	
		-7.3	+14.9			-3.60	-240	-0.19	-12.2
		-34.8	+45.0			-3.10	-206	-0.19	(-1.4)
	-5.7	-54.1	+54.4		8.8	-11.7	-779	-0.67	
	-142.2		+222.2			-122.6	-8165	-0.48	
	+21.9	-22.9	+26.8	-29.3	3.5	-43.4	-2900	-3.00	-11.6
				-190.0	2.0			-2.08	-340.1
				(-2.9)	(0.1)	-1.2	-80	-0.07	+9.1
				-829.5	12.3	-4.4	-293	-4.50	(-43.0)
	-4.4		+150.1			-153.2	-10200	0.25	
	+38.4			-79.8	34.6	-6.98	-465	-0.17	-0.1
						-0.37	-25	-0.60	+30.4
	-9.5		+327.1			-456.3	-30400	-11.30	
	-384.9	+180.3	+96.8	-1051.0	0.8			-12.2	
	-15.4		+530.0			-477.0	-31800	+88.57	
								-1.70	
								-0.70	
		-92.5	-2947.0	+3036.6	2.9			-6.00	

CASE: Westm

Unit		STEAM (M lb/hr)			
NO.	NAME	1500 lb 925°F	650 lb Sat'd	600 lb 760°F	100 lb Sat'd
46	Air and Nitrogen Systems				
47	Process Cooling Water				
48	Utility Cooling Water				
49	Potable Water				
50	Utility Water				
51	Fire Water				
52	Fuel Gas				
53	Flare				
54	Water Treating				
55	Tank Farm and Dispatch				10.
56	Sanitary Sewer ⁽²⁾ Steam Tracing Export				-7.
Total (Process Units)		0	0	-325.8	+427.
Total (Utility Units)		0	0	+325.8	-427.
TOTAL		0	0	0	0

Legend: () indicate intermittent use. Not included in totals.
 + indicates production
 - indicates consumption

Note: (1) 650 psig/710°F steam
 (2) Include in Wastewater Treating (Unit 54)

6.4.10 CATALYST AND CHEMICALS SUMMARY

The catalysts and chemicals required for each unit in the Westmoreland Coal-Power Self-sufficiency Case are shown in Table 6.4.10-1. Initial and annual costs are provided.

TABLE 6.4.10-1

CATALYST AND CHEMICAL SUMMARY

CASE: Westmoreland Coal - Power Self-sufficiency

<u>Unit</u>	<u>Item</u>	<u>Initial Cost, \$</u>	<u>Annual Cost, \$</u>
03	Ash Handling		
	Flocculent	150	1,760
11	CO Shift Conversion		
	Sour Shift Catalyst	1,378,700	1,378,700
13	Rectisol		
	Propylene	36,600	51,600
	Caustic	-	89,400
16	Naphtha Hydrotreating		
	Dimethyl Sulfide	1,400	560
	Confidential Catalyst	58,400	19,500
17	Phenosolvan		
	Isopropylether Solvent	174,600	60,600
	Gravel	1,440	180
	Sand	3,200	400
	Filtrilur	70,300	8,790
18	Ammonia Recovery		
	Phosphoric Acid (100%)	155,500	74,500
	Sodium Hydroxide (50% sol'n)	480,200	160,100

TABLE 6.4.10-1 (Continued)

CATALYST AND CHEMICAL SUMMARY

CASE: Westmoreland Coal - Power Self-sufficiency

<u>Unit</u>	<u>Item</u>	<u>Initial Cost, \$</u>	<u>Annual Cost, \$</u>
19	Sulfur Recovery		
	Diisopropanolamine	5,130	2,530
	Claus Catalyst	18,800	6,290
	Shell 634 Catalyst	47,700	15,900
	Citric Acid	6,110	13,100
	ADA	61,300	130,900
	Caustic (50%)	5,800	(58,000) ()
	Vanadium	48,300	-
21	Methanol Synthesis		
	Synthesis Catalyst	411,800	137,300
22	Methanation		
	Synthesis Catalyst	2,500,000	2,500,000
41	Steam Generation		
	Hydrazine Hydrate	290	3,160
	Sodium Phosphate	30	280
	Morpholine	2,470	27,300
43	Flue Gas Desulfurization		
	Lime (90% CaO)	7,100	321,400
	Formic Acid (90% soln.)	10,200	94,700
	Anti-Foulant (Nalco 7319)	100	980
	HCl (30% soln.)	1,790	-

TABLE 6.4.10-1 (Continued)

CATALYST AND CHEMICAL SUMMARY

CASE: Westmoreland Coal - Power Self-sufficiency

<u>Unit</u>	<u>Item</u>	<u>Initial Cost, \$</u>	<u>Annual Cost, \$</u>
44,45	Raw Water, BFW Treating and Portable Water		
& 49	Poly-electrolyte	2,120	25,300
	Chlorine	3,770	45,500
	Quick Lime	1,760	4,230
	Soda Ash (Dense Bulk)	15,500	579,600
	Alum	1,690	4,720
	Hexametaphosphate	7,650	88,000
	Sulfuric Acid (93%)	20,000	87,000
	Caustic (50% soln.)	110,200	440,800
	Activated Carbon	57,000	28,500
	Hydrazine Hydrate	410	4,530
	Morpholine	3,400	37,600
	Chelant (EDTA)	780	8,660
46	Air and Nitrogen System		
	Activated Alumina	1,150	320
47	Process Cooling Water		
	Chlorine	3,190	37,700
	Sulfuric Acid (93%)	630	199,900
	Inhibitor	7,810	93,700
	Dispersant	2,130	25,500
	Biocide	8,740	42,200
	Nalprep	56,600	150
	Activated Carbon	33,000	16,500
	Hexametaphosphate	2,300	24,500

TABLE 6.4.10-1 (Continued)

CATALYST AND CHEMICAL SUMMARY

CASE: Westmoreland Coal - Power Self-sufficiency

<u>Unit</u>	<u>Item</u>	<u>Initial Cost, \$</u>	<u>Annual Cost, \$</u>
48	Utility Cooling Water		
	Chlorine	580	7,540
	Sulfuric Acid (93%)	2,800	33,700
	Inhibitor	1,080	12,900
	Dispersant	300	400
	Biocide	860	4,460
	Nalprep	5,900	20
	Poly-electrolyte	240	2,890
	Quick Lime	200	490
	Soda Ash (Dense Bulk)	1,720	66,200
54	Wastewater Treating		
	Caustic (50%)	153,700	3,451,000
	Sulfuric Acid (93%)	4,910	119,200
	Poly-electrolyte	210	25,200
	Phosphoric Acid (100%)	2,650	40,900
55	Tank Farm and Dispatch		
	SNG Odorant (Ethyl/Amyl Mercaptan)	140	1,690
	NaCl	1,200	320,000
TOTAL		\$6,004,720	\$10,981,430

NOTE:

(1) First year only, not included in total

6.4.11 OPERATING MANPOWER

The operating manpower for the Power Self-sufficiency Case was determined in the same way as the Base Case manpower.

The total operating staff is 392. There are 54 shift operating positions for the Power Self-sufficiency Case versus 58 for the Base Case.

6.4.12 MAINTENANCE MANPOWER

Annual maintenance cost is estimated as a percentage of the plant installed cost. The same procurement for determining maintenance cost as used on the Base Case (Section 6.1.12) was followed for the Power Self-sufficiency Case yielding a cost of \$30,900,000, which is 60 percent materials and 40 percent labor.

The labor portion of \$12,400,000 is equivalent to 353 maintenance staff positions using the same assumptions as the Base Case.

6.4.13 PROCESS UNITS ENGINEERING DATA

All aspects of the process units including material balance for the Power Self-sufficiency Case are identical to the Base Case except for Units 01, 02, and 03. Coal fines feed to boilers is significantly less than the Base Case due to reduced power generation. This reduces the coal throughput in the Coal Screening and Distribution units (01 and 02). As the coal input to gasifiers remains the same as Base Case, the percentage fines in coal feed changes from 40 percent in Base Case to 18 percent in this case. In the Ash Handling Unit (03), the quantity of boiler ash and FGD sludge are less than the Base Case due to smaller boiler capacity. Gasifier ash remains unaltered from the Base Case. The material balances for the Units 01, 02, and 03 are provided following this description. The process flow diagram, design criteria, and other aspects of the three units are similar to the Base Case and are included in Sections 6.2.1 through 6.2.3.

TABLE 6.4.13-1
MATERIAL BALANCE
COAL SCREENING - UNIT 01

Stream Number	1-1	1-2	1-3
Stream Name	Total Coal Feed	Sized Coal to Gasification	Coal Fines to Boilers
DAF Coal, lb/hr	730,713	599,400	131,313
Moisture, lb/hr	285,264	234,000	51,264
Ash, lb/hr	81,190	66,600	14,590
Total, lb/hr	1,097,167	900,000	197,167
ST/SD	13,166	10,800	2,366

NOTE: Flow quantities shown are for the total unit on a stream-day basis, are to be used solely for process design purposes, and are not necessarily the conditions which will be attained during actual operations.

TABLE 6.4.13-2
MATERIAL BALANCE
COAL DISTRIBUTION - UNIT 02

Stream Number	2-1	2-2
Stream Name	Sized Coal to Gasification	Coal Fines to Boilers
DAF Coal, lb/hr	599,400	131,313
Moisture, lb/hr	234,000	51,264
Ash, lb/hr	66,600	14,590
Total, lb/hr	900,000	197,167
ST/SD	10,800	2,366

NOTE: Flow quantities shown are for the total unit on a stream-day basis, are to be used solely for process design purposes, and are not necessarily the conditions which will be attained during actual operations.

TABLE 6.4.13-3

MATERIAL BALANCE

ASH HANDLING - UNIT 03

Stream Number	3-1	3-2	3-3	3-4	3-5	3-6	3-7
Stream Name	Gasifier Ash (2)	POX Ash (2)	Boiler Bottom Ash (2)	Boiler Fly Ash (2)	Makeup Water	FGD Sludge	Solid Waste to Disposal
Dry Solids, lb/hr	68,931	18	2,908	11,635	-	8,160	91,652
Water, lb/hr					36,220	2,438	38,658
Sludge, lb/hr					-	10,598	130,310
ST/SD					-	127.2	1,563.7
Wt/Solids					-0-	77.0	70.3

NOTES: (1) Flow quantities shown are for the total unit on a stream-day basis, are to be used solely for process design purposes, and are not necessarily the conditions which will be attained during actual operations.

(2) Only dry solids flows are shown.

6.4.14 UTILITY AND OFFSITES UNITS

6.4.14.1 GENERAL

The SNG production from the Power Self-sufficiency Case process plant does not change from the Base Case. The Power Generation unit, however, produces only the power required by the plant and no power for export. The decrease in plant power output is from 405 MW in the Base Case to 84.5 MW in the Power Self-sufficiency Case.

The reduction in power generation changes the following utilities and offsites units:

Unit 40	Oxygen Production
Unit 41	Steam Generation
Unit 42	Power Generation
Unit 43	Flue Gas Desulfurization
Unit 44	Raw Water Treatment
Unit 45	Boiler Feed Water and Condensate Treatment
Unit 47	Process Cooling Water
Unit 48	Utility Cooling Water
Unit 54	Waste Water Treatment

The remaining utilities and offsites units are the same as the Base Case.

6.4.14.2 OXYGEN PRODUCITON - UNIT 40

In the Power Self-sufficiency Case the air compressors within Unit 40 are driven by 600 psig, 760°F condensing steam turbines rather than 1500 psig, 1925°F to 650 psig back-pressure turbines as in the Base Case. The change increases the steam and cooling water requirement to Unit 40. The material balance of the unit is the same as the Base Case.

6.4.14.3 STEAM GENERATION - UNIT 41

Reduction of the power output proportionally reduces the steam requirements of Unit 42 and changes the number of boiler trains in Unit 41, Steam Generation, from three producing 4.1 million lb/hr of steam in the Base Case to two producing 1.4 million lb/hr in the Power Self-sufficiency Case. The steam balance for this alternate case is included as Drawing No. 835704-00-R-201 in Section 6.4.8. The material balance of Unit 41 for the Power Self-sufficiency Case follows as Table 6.4.14-1.

6.4.14.4 POWER GENERATION - UNIT 42

This unit decreases from three to two trains for the Power Self-sufficiency Case just as Unit 41. The material balance follows at Table 6.4.14-2.

6.4.14.5 FLUE GAS DESULFURIZATION - UNIT 43

This unit decreases in size and number of trains exactly as the Steam Generation boilers. The material balance for Unit 43 follows as Table 6.4.14-3.

6.4.14.6 RAW WATER TREATMENT - UNIT 44

The raw water flowing to the plant from the Bighorn River decreases from 6813 gpm in the Base Case to 2953 gpm in the Power Self-sufficiency Case because of reduced 1500 psig boiler feed water and reduced cooling water requirements. The material balance for Unit 44 for this alternate case follows as Table 6.4.14-4.

6.4.14.7 BOILER FEED WATER AND CONDENSATE TREATMENT - UNIT 45

Boiler feed water makeup to the 1500 psig boilers decreases from 6213 gpm in the Base Case to 2102 gpm in the Power Self-sufficiency Case, while the 600 psig and 100 psig boilers are process dependent and do not change in

6.4.14.7 (Continued)

BFW requirement for this case. Similarly, the cold condensate is reduced from 5821 gpm to 1664 gpm with the elimination of export power while the other plant condensate streams remain essentially the same. The material balance from Unit 45 for this alternate case follows as Table 6.4.14-5.

6.4.14.8 PROCESS COOLING WATER - UNIT 47

The Process Cooling Tower (F.C.T.) evaporation rate is critical to the plant water balance in that the equivalent of the flow of process waste water into the water balance must be eliminated here. To accomplish this without the heat load of the export power surface condensers in Unit 42, only the oxygen coolers are left on the Utility Cooling Tower (U.C.T.), and all other cooling load is shifted to the Process Cooling Towers. Even with these changes the cooling water flow in Unit 47 falls from 152,000 gpm in the Base Case to 85,200 gpm in the Power Self-sufficiency Case. As a result of the evaporative loss reduction, some of the Waste Treatment Evaporator condensate must be sent to the Utility Cooling Tower. The material balance for Unit 47 for the Plant Self-sufficiency Case follows as Table 6.4.14-6.

6.4.14.9 UTILITY COOLING TOWER - UNIT 48

For the Power Self-sufficiency Case the U.C.T. provides cooling water for the oxygen coolers only. This reduces its circulation load from 64,900 gpm in the Base Case to 10,400 gpm in this alternate case. The material balance for Unit 48 follows as Table 6.4.14-7.

6.4.14.10 WASTE WATER TREATMENT - UNIT 54

Waste water from the Process Units remains constant for the Power Self-sufficiency Case while utilities waste water from boiler and cooling tower

6.4.14.10 (Continued)

blowdown decrease. The biological treatment section of Waste Water Treatment Unit 54 only drops from 2536 gpm influent in the Base Case to 2518 gpm in the Power Self-sufficiency Case, too small a difference to match the drop in P.C.T. evaporation. Ten percent of the water purified in the waste treatment evaporator is sent to the Utility Cooling Tower as makeup. Also, the Flue Gas Desulfurization makeup water is taken from the treated waste water steam. In mid-winter, when evaporation is the lowest, 1131 gpm of waste water flows into the excess water holding pond to be recycled to the system in the summer. The material balance from Unit 54 for the Power Self-sufficiency Case follows as Table 6.4.14-8.

TABLE 6.4.14-1
MATERIAL BALANCE
STEAM GENERATION - UNIT 41

Stream Number	41-1		41-2		41-3	
Stream Name	Coal Fines		Demineralized Water		Cold Condensate	
Component	lb mol/hr	Mol %	lb mol/hr	Mol %	lb mol/hr	Mol %
<hr/>						
Total Dry Gas						
H ₂ O						
Total Wet Gas						
<hr/>						
H ₂ O	lb/hr		218,800		832,200	
Steam	lb/hr					
Coal	lb/hr	197,160				
<hr/>						
Total	lb/hr	197,160	218,800		832,200	
<hr/>						
Pressure, psia			88		88	
Temperature, °F			80		80	

NOTE: Flow quantities, pressures, and temperatures shown are for the total unit on a stream-d design purposes, and are not necessarily the conditions which will be attained during actu

TABLE 6.4.14-1

MATERIAL BALANCE
STEAM GENERATION - UNIT 41

41-2		41-3		41-4		41-5	
Demineralized Water		Cold Condensate		HP Exhaust Steam		Reheat Steam	
lb mol/hr	Mol %	lb mol/hr	Mol %	lb mol/hr	Mol %	lb mol/hr	Mol %
218,800		832,200		1,359,900		1,158,000	
218,800		832,200		1,359,900		1,158,000	
88		88		663		613	
80		80		710		760	

ures shown are for the total unit on a stream-day basis, are to be used solely for process the conditions which will be attained during actual operations.

USE OR DISCLOSURE OF REPORT DATA
IS SUBJECT TO THE RESTRICTION ON THE
NOTICE PAGE AT THE FRONT OF THIS REPORT

TABLE 6.4.14-1 (Continued)

MATERIAL BALANCE
STEAM GENERATION - UNIT 41

Stream Number	41-6	41-7	4
Stream Name	HHP Steam	Boiler Flue Gas	Process Super
Component	lb mol/hr Mol %	lb mol/hr Mol %	lb mol/hr
N ₂		44,518 80.14	11,169
O ₂		2,653 4.73	642
CO		4 0.01	Trace
CO ₂		8,307 14.95	21,602
SO ₂		50 0.09	3
HCl		1 -	
NO ₂		18 0.03	5
Total Dry Gas		55,551 100.0	33,421
H ₂ O		6,592	3,327
Total Wet Gas		62,143	36,748
Dry Gas lb/hr		1,701,777	1,284,596
H ₂ O lb/hr		118,760	59,934
Steam lb/hr		1,359,900	
Particulates lb/hr		47	
Total lb/hr	1,359,900	1,820,584	1,344,530
Pressure, psia	1.513	13.3	13
Temperature, °F	930	300	400

TABLE 6.4.14-1 (Continued)

MATERIAL BALANCE
STEAM GENERATION - UNIT 41

41-7		41-8		41-8	
Boiler Flue Gas		Process Steam Superheating		Flue Gas To Stack	
lb mol/hr	Mol %	lb mol/hr	Mol %	lb mol/hr	Mol %
44,518	80.14	11,169	33.42	56,091	62.72
2,653	4.78	642	1.92	3,403	3.80
4	0.01	Trace	-	4	-
8,307	14.95	21,602	64.64	29,909	33.44
50	0.09	3	-	8	0.01
1	-				
18	0.03	5	0.02	23	0.03
55,551	100.0	33,421	100.0	89,438	100.0
6,592		3,327		14,161	
62,143		36,748		103,599	
1,701,777		1,284,596		2,997,557	
118,760		59,934		254,946	
1,359,900					
47				47	
1,820,584		1,344,530		3,252,550	
13.3		13.5		13.1	
300		400		235	

USE OR DISCLOSURE OF REPORT DATA
IS SUBJECT TO THE RESTRICTIONS ON THE
NOTICE PAGE AT THE FRONT OF THIS REPORT

TABLE 6.4.14-2
MATERIAL BALANCE
POWER GENERATION - UNIT 42

Stream Number		42-1	42-2	42-3	42-4
Stream Name		Reheat Steam	HHP Steam	HP Exhaust Steam	Condensate From LP Heaters
H ₂ O Steam	lb/hr lb/hr	514,60	1,359,900	1,359,900	
MW					
TOTAL	lb/hr	514,600	1,359,900	1,359,900	
Pressure, psia		563	1463	663	
Temperature, °F		756	925	710	

- NOTES: (1) Flow quantities, pressures and temperatures shown are for the total unit on a str process design purposes, and are not necessarily the conditions which will be attained
- (2) LP Condensate heaters within the Steam Generation Unit 41 utilize 100 psig/sat'd ste from the condensing section of the turbogenerators. The condensate from the LP h Treating Unit 45.

TABLE 6.4.14-2

MATERIAL BALANCE
POWER GENERATION - UNIT 42

42-2	42-3	42-4	42-5	42-10
HHP Steam	HP Exhaust Steam	Condensate From LP Heaters	Cold Condensate	Power Output
,359,900	1,359,900		514,600	88.7
,359,900	1,359,900		514,600	
1463 925	663 710		110 125	

temperatures shown are for the total unit on a stream-day basis, are to be used solely for not necessarily the conditions which will be attained during actual operations.

Steam Generation Unit 41 utilize 100 psig/sat'd steam for heating instead of extraction steam e turbogenerators. The condensate from the LP heaters is routed to the BFW & Condensate

USE OR DISCLOSURE OF REPORT DATA
AS SUBJECT TO THE RESTRICTION ON THE
NOTICE PAGE AT THE FRONT OF THIS REPORT

TABLE 6.4.14-3
MATERIAL BALANCE
FLUE GAS DESULFURIZATION - UNIT 43

Stream Number	43-1		43-2	43-3
Stream	Flue Gas From Unit 41		Lime	Raw Water Makeup
Component	lb mol/hr	mol %	lb mol/hr	
N ₂	44,518	80.14		
O ₂	2,653	4.78		
CO ₂	8,307	14.95		
CO	4	0.01		
NO ₂	18	0.03		
HCl	1	0.002		
SO ₂	50	0.09		
Total Dry Gas	55,551	100.00		
H ₂ O	6,592			
Total Wet Gas	62,143			
Dry Gas, lb/hr	1,701,777			
H ₂ O, lb/hr	118,760			
Lime, lb/hr			2,889	80,180
Dry Gypsum, lb/hr	47			
Particulates, lb/hr				
Total, lb/hr	1,820,584		2,889	80,180
Pressure, psia	13.3			
Temperature, °F	300			

NOTE: Flow quantities, pressures and temperatures shown are for the total unit on a stream-day design purposes, and are not necessarily the conditions which will be attained during actu

TABLE 6.4.14-3

MATERIAL BALANCE

FLUE GAS DESULFURIZATION - UNIT 43

43-2	43-3	43-4	43-5
Lime	Raw Water Makeup	Flue Gas to Unit 41	Gypsum to Unit 03
lb mol/hr		lb mol/hr mol %	
		44,922 80.19	
		2,761 4.93	
		8,307 14.83	
		4 0.01	
		18 0.03	
		5 0.01	
		56,017 100.00	
		10,834	
		66,851	
		1,712,961	
	80,180	195,012	2,438
2,889		47	8,160
2,889	80,180	1,908,020	10,598
		13.1	
		128	

ures shown are for the total unit on a stream-day basis, are to be used solely for process by the conditions which will be attained during actual operations.

USE OR DISCLOSURE OF REPORT DATA IS SUBJECT TO THE RESTRICTION ON THE NOTICE PAGE AT THE FRONT OF THIS REPORT

TABLE 6.4.14-4

MATERIAL BALANCE

RAW WATER TREATMENT - UNIT 44

Stream Number		44-1	44-2	44-3	44-4
Stream Name		Raw Water Makeup	To Potable Water Treatment	To FGD Unit 43	RO Reject From Unit 43
Water	lb/hr (gpm)	1,476,500 (2953)	27,000 (54)	80,180 (160)	1000 (2)
Total	lb/hr	1,476,500	27,000	80,180	1000
Pressure, psia		13.7	63.7	88.7	300
Temperature, °F		60	60	60	80

NOTE: Flow quantities, pressures and temperatures shown are for the total unit on a stream-day design purposes, and are not necessarily the conditions which will be attained during actual

TABLE 6.4.14-4

MATERIAL BALANCE

RAW WATER TREATMENT - UNIT 44

44-2	44-3	44-4	44-5	44-6
To Potable Water Treatment	To FGD Unit 43	RO Reject From Unit 43	To U.C.T Makeup	To BFW Treatment Unit 45
27,000 (54)	80,180 (160)	1000 (2)	80,500 (161)	1,367,500 (2735)
27,000	80,180	1000	80,500	1,367,500
63.7 60	88.7 60	300 80	43.7 80	33.7 80

atures shown are for the total unit on a stream-day basis, are to be used solely for process
y the conditions which will be attained during actual operations.

USE OR DISCLOSURE OF REPORT DATA
IS SUBJECT TO THE RESTRICTION ON THE
NOTICE PAGE AT THE FRONT OF THIS REPORT

TABLE 6.4.14-5

MATERIAL BALANCE

BFW AND CONDENSATE TREATING-UNIT 45

Stream Number		45-1	45-2	45-3
Stream Name		BFW Feed From Unit 44	Demin. to Water Distribution	Cold Condensate for Polishing
Water	lb/hr (gpm)	1,367,500 (2735)	600,500 (1201)	832,000 (1664)
Total	lb/hr	1,367,500	600,500	832,000
Pressure, psia		33.7	88.7	40
Temperature, °F		80	100	285

NOTE: Flow quantities, pressures and temperatures shown are for the total unit on a stream-day design purposes, and are not necessarily the conditions which will be attained during actual

TABLE 6.4.14-5

MATERIAL BALANCE

FW AND CONDENSATE TREATING-UNIT 45

45-2	45-3	45-4	45-5
Demin. to Water Distribution	Cold Condensate for Polishing	Polished Cold Condensate	Vacuum Condensate From Unit 23
600,500 (1201)	832,000 (1664)	832,000 (1664)	144,000 (288)
600,500	832,000	832,000	144,000
88.7 100	40 285	88.7 285	40 285

ures shown are for the total unit on a stream-day basis, are to be used solely for process the conditions which will be attained during actual operation.

USE OR DISCLOSURE OF REPORT DATA
IS SUBJECT TO THE RESTRICTION ON THE
NOTICE PAGE AT THE FRONT OF THIS REPORT

TABLE 6.4.14-5 (Continued)

MATERIAL BALANCE

BFW AND CONDENSATE TREATING-UNIT 45

Stream Number		45-6	45-7	45-8
Stream Name		Process Condensate From Unit 22 & Unit 40	Softened Vacuum & Process Condensate	High TDS to Ash Handling
Water	lb/hr (gpm)	175,000 (350)	319,000 (638)	36,000 (72)
Total	lb/hr	175,000	319,000	36,000
Pressure, psia		88.7	78.7	63.7
Temperature, °F		100	100	100

TABLE 6.4.14-5 (Continued)

MATERIAL BALANCE

FW AND CONDENSATE TREATING-UNIT 45

45-7	45-8	45-9	45-10
Softened Vacuum & Process Condensate	High TDS to Ash Handling	Low TDS to UCT Makeup	Softened BFW to LP Deaerator
319,000 (638)	36,000 (72)	10,000 (20)	564,500 (1129)
319,000	36,000	10,000	564,500
78.7 100	63.7 100	63.7 100	88.7 100

USE OR DISCLOSURE OF REPORT DATA
IS SUBJECT TO THE RESTRICTION ON THE
NOTICE PAGE AT THE FRONT OF THIS REPORT

PROCESS

Stream Number		47-1	
Stream Name		P.C.T to Side Stream Filter	P Bl
Water	lb/hr (gpm)	2,130,000 (4260)	
Total	lb/hr	2,130,000	
Pressure, psia		13.7	
Temperature, °F		110	

NOTE: Flow quantities, pressures and temperatures shown design purposes, and are not necessarily the condit

TABLE 6.4.14-6

MATERIAL BALANCE

PROCESS COOLING WATER-UNIT 47

47-2	47-3	47-4	47-5
P.C.T. Blowdown	Side Stream Filtration to P.C.T	High TDS Effluent to Evaporation	Treated Waste To P.C.T Makeup
8,000 (16)	2,051,500 (4103)	79,000 (158)	1,176,500 (2353)
8,000	2,051,500	79,000	1,176,500
13.7 110	13.7 80	63.7 100	63.7 65

res shown are for the total unit on a stream-day basis, are to be used solely for process the conditions which will be attained during actual operation.

USE OR DISCLOSURE OF REPORT DATA IS SUBJECT TO THE RESTRICTIONS ON THE FRONT PAGE AT THE FRONT OF THIS REPORT

TABLE 6.4.14-6 (Continued)

MATERIAL BALANCE

PROCESS COOLING WATER-UNIT 47

Stream Number		47-6	47-7	47-8
Stream Name		From U.C.T Blowdown Treatment	From Evaporator	From P.C.T Makeup Water Treatment
Water	lb/hr (gpm)	183,500 (367)	313,000 (626)	878,000 (1756)
Total	lb/hr	183,500	313,000	878,000
Pressure, psia		43.7	13.7	13.7
Temperature, °F		80	100	65

TABLE 6.4.14-6 (Continued)

MATERIAL BALANCE

PROCESS COOLING WATER-UNIT 47

47-7	47-8	47-9	47-10
From Evaporator	From P.C.T Makeup Water Treatment	To Process Cooling Tower	To Unit 54 Evaporator
313,000 (626)	878,000 (1756)	1,294,500 (2589)	294,000 (588)
313,000	878,000	1,294,500	294,000
13.7 100	13.7 65	20.7 80	63.7 85

USE OR DISCLOSURE OF REPORT DATA IS SUBJECT TO THE RESTRICTIONS ON THE NOTICE PAGE AT THE FRONT OF THIS REPORT

UTILIT

Stream Number		48-1	
Stream Name		U.C.T. Blowdown	R Fr
Water	lb/hr (gpm)	74,000 (148)	
Solids	lb/hr		
Total	lb/hr	74,000	
Pressure, psia		13.7	
Temperature, °F		110	

NOTE: Flow quantities, pressures and temperatures show design purposes, and are not necessarily the cond

TABLE 6.4.14-7

MATERIAL BALANCE

UTILITY COOLING WATER-UNIT 48

48-2	48-3	48-4	48-5
RO Reject From Unit 45	RO Reject From Unit 49	Treated Water to P.C.T. Makeup Pond	Sludge to Land Fill
162,000 (324)	1,500 (3)	183,500 (367)	1,000 (2)
162,000	1,500	183,500	1,064
300 80	300 80	15.7 80	13.7 70

es shown are for the total unit on a stream-day basis, are to be used solely for process the conditions which will be attained during actual operation.

USE OR DISCLOSURE OF REPORT DATA
IS SUBJECT TO THE RESTRICTION ON THE
NOTICE PAGE AT THE FRONT OF THIS REPORT

TABLE 6.4.14-8
MATERIAL BALANCE
WASTE WATER TREATING UNIT-54

Stream Number		54-1	54-2	54-3
Stream Name		Storm Water	Oily Water	Oily Condensate
Water	lb/hr (gpm)	104,500 (209)	130,000 (260)	Normally 0
Solids	lb/hr			
Total	lb/hr	104,500	130,000	
Pressure, psia		13.7	13.7	
Temperature, °F		60	60	

NOTE: Flow quantities, pressures and temperatures shown are for the total unit on a stream-day design purposes, and are not necessarily the conditions which will be attained during actual

TABLE 6.4.14-8

MATERIAL BALANCE

WASTE WATER TREATING UNIT-54

54-2	54-3	54-4	54-5
Oily Water	Oily Condensate	1500 lb Boiler Blowdown	U.C.T Makeup Water
130,000 (260)	Normally 0	4,000 (8)	99,000 (198)
130,000		4,000	99,000
13.7 60		53.7 285	38.7 80

es shown are for the total unit on a stream-day basis, are to be used solely for process
the conditions which will be attained during actual operation.

USE OR DISCLOSURE OF REPORT DATA
IS SUBJECT TO THE RESTRICTION ON THE
NOTICE PAGE AT THE FRONT OF THIS REPORT

TABLE 6.4.14-8 (Continued)

MATERIAL BALANCE

WASTE WATER TREATING-UNIT 54

Stream Number		54-6	54-7	54-8
Stream Name		DAF Effluent To Biotreating	Stripped Gas Liquor	Waste Heat Boiler Blowdown
Water	lb/hr (gpm)	136,000 (272)	942,000 (1884)	21,000 (42)
Total	lb/hr	136,000	942,000	21,000
Pressure, psia		13.7	145	53.7
Temperature, °F		65	100	285

TABLE 6.4.14-8 (Continued)

MATERIAL BALANCE

WASTE WATER TREATING-UNIT 54

54-7	54-8	54-9	54-10
Stripped Gas Liquor	Waste Heat Boiler Blowdown	Treated Water Sanitary Unit 56	Water From Rectisol
942,000 (1884)	21,000 (42)	23,500 (47)	38,500 (77)
942,000	21,000	23,500	38,500
145 100	53.7 285	13.7 80	13.7 63

USE OR DISCLOSURE OF REPORT DATA
IS SUBJECT TO THE RESTRICTION ON THE
NOTICE PAGE AT THE FRONT OF THIS REPORT

TABLE 6.4.14-8 (Continued)

MATERIAL BALANCE

WASTE WATER TREATING-UNIT 54

Stream Number		54-11	54-12	54-13
Stream Name		Water From POX Unit 24	Ash to Land Fill	Incinerator Evaporation Loss
Water	lb/hr (gpm)	3,000 (6)		2,500 (5)
Solids	lb/hr		530	
Total	lb/hr	3,000	530	2,500
Pressure, psia		13.7	13.7	13.7
Temperature, °F		100	100	208

TABLE 6.4.14-8 (Continued)

MATERIAL BALANCE

WASTE WATER TREATING-UNIT 54

54-12	54-13	54-14	54-15
Ash to Land Fill	Incinerator Evaporation Loss	Effluent to PCT Treatment	Evap. Feed From NaZ Softener
530	2,500 (5)	1,176,500 (2353)	1,500 (3)
530	2,500	1,176,500	1,500
13.7 100	13.7 208	63.7 80	13.7 80

USE OR DISCLOSURE OF REPORT DATA
IS SUBJECT TO THE RESTRICTION ON THE
NOTICE PAGE AT THE FRONT OF THIS REPORT

TABLE 6.4.14-8 (Continued)

MATERIAL BALANCE

WASTE WATER TREATING-UNIT 54

Stream Number		54-16	54-17	54-18
Stream Name		Evaporator Feed From PCT-RO Reject	Evaporator Feed From PCT Blowdown	Combined Evaporator Load
Water	lb/hr (gpm)	292,500 (585)	79,000 (158)	373,000 (746)
Solids	lb/hr			
Total	lb/hr	292,500	79,000	373,000
Pressure, psia		300	15.7	13.7
Temperature, °F		80	80	80

TABLE 6.4.14-8 (Continued)

MATERIAL BALANCE

WASTE WATER TREATING-UNIT 54

54-17	54-18	54-19	54-20
Evaporator Feed From PCT Blowdown	Combined Evaporator Load	Evaporator Brine To Solar Pond	Evaporator Effluent To Cooling Towers
79,000 (158)	373,000 (746)	21,500 (43)	351,500 (703)
79,000	373,000	21,500	351,500
15.7 80	13.7 80	13.7 100	13.7 100

USE OR DISCLOSURE OF REPORT DATA
IS SUBJECT TO THE RESTRICTIONS IN THE
NOTICE PAGE AT THE FRONT OF THIS REPORT

6.4.15 CAPACITY FACTORS

The utility requirements and unit costs for all the units in the Power Self-sufficiency Case are capacity factored from the Base Case with a few exceptions. The capacity factors used and their basis for this case are tabulated in Table 6.4.15-1.

UNIT

NO.	NAME	BASIS
01	Coal Screening	Coal, TPD
02	Coal Distribution	Coal, TPD
03	Ash Handling	Gasifier Ash, TPD
10	Coal Gasification	No. of Gasifiers
11	CO Shift	Catalyst Volume, ft ³
12	Gas Cooling	Cooling Duty, MM Btu
13	Rectisol	Acid Gas Removed
14	Gas Liquor Separation	Net Gas Liquor Feed
15	Tar Distillation	Tar/Oil Feed, lb/H
16	Naphtha Hydrotreating	Naphtha Feed, lb/H
17	Phenosolvan	Net Gas Liquor Feed
18	Ammonia Recovery	Ammonia Product Rate
19	Sulfur Recovery-ADIP	Gas Feed, lb mol/H
		H ₂ S Absorbed, lb
	Claus	Sulfur Product Rate
	SCOT	Gas Feed, lb mol/H
	Stretford	Gas Feed, lb mol/H
20	Process Steam Superheating	Sulfur Product Rate
		Vent Gas Feed Rate
		Fired Duty, MM Btu
21	Methanol Synthesis	Methanol Production
22	Methanation	Feed Rate, lb mol/H
23	SNG Purification & Compression	Feed Rate, lb mol/H
24	Partial oxidation	Liquids Feed Rate
25	PSA H ₂ Production	H ₂ Production Rate
40	Oxygen Production	O ₂ Production Rate
41	Steam Generation	Steam Production Rate
42	Power Generation	No. of Boiler
		Generation Capacity
43	Flue Gas Desulfurization	No of Trains
		Flue Gas Feed Rate
		SO ₂ Removed, lb m
44	Raw Water Treating	Raw Water Flow Rate
45	BFW and Condensate Treating	Total BFW Flow Rate
46	Air and Nitrogen System	N ₂ + Air Quantity
47	Process Cooling Water	Cooling Water Flow
48	Utility Cooling Water	Cooling Water Flow
49	Potable Water	Water Flow, GPM
50	Utility Water	Design Capacity, G
51	Fire Water	Design capacity, G
52	Fuel Gas	Fuel Gas Quantity
53	Flare	Design capacity, MM
54	Wastewater Treating	Wastewater Flow Rate
55	Tank Farm & Dispatch	Working Capacity
	- Naphtha	
	- Ammonia	
	- Sulfur	
	- Intermediate	
	- MeOH	
	- PROP/IPE	
	- Inorg. Chemicals	
56	Sanitary Sewer	--
57	Interconnecting	--

TABLE 6.4.15-1
UNIT CAPACITY FACTORS

USE OR DISCLOSURE OF REPORT DATA
IS SUBJECT TO THE RESTRICTIONS ON THE
INSIDE PAGE AT THE FRONT OF THIS REPORT

BASIS	WESTMORELAND COAL CAPACITY		
	BASE CASE	POWER SELF-SUFFICIENCY CASE	FACTOR
D	18,000	13,166	0.731
D	18,000	13,166	0.731
Ash, TPD	827	827	1.0
Classifiers	14	14	1.0
Volume, ft ³	4,055	4,055	1.0
Duty, MM Btu/Hr	673.9	673.9	1.0
Removed, lb mol/Hr	19,940	19,940	1.0
Liquor Feed, lb/Hr	1,000,636	1,000,636	1.0
Feed, lb/Hr	25,265	25,265	1.0
Feed, lb/Hr	16,380	16,380	1.0
Liquor Feed, lb/Hr	969,596	969,596	1.0
Product Rate, lb/Hr	6,398	6,398	1.0
lb mol/Hr	690.9	690.0	1.0
Corbed, lb mol/Hr	114.4	114.4	1.0
Product Rate, lb mol/Hr	53.5	53.5	1.0
lb mol/Hr	898.3	898.3	1.0
lb mol/Hr	11,368.7	11,368.7	1.0
Product Rate, TPD	33.7	33.7	1.0
Feed Rate, lb mol/HR	21,870.2	21,870.2	1.0
Duty, MM Btu/Hr	320	320	1.0
Production Rate, TPD	30	30	1.0
lb mol/Hr	43,647.3	43,647.3	1.0
lb mol/Hr	18,207.5	18,207.5	1.0
Feed Rate, lb mol/Hr	23,487	23,487	1.0
Production Rate, lb mol/Hr	118.6	118.6	1.0
Production Rate, TPD	2,925	2,925	1.0
Production Rate, M lb/Hr	4,120	1,370	0.333
Capacity, MW	3	2	0.209
Capacity, MW	405	84.5	0.209
Capacity, MW	3	2	0.209
Feed Rate, MM SCFM	1.2	0.4	0.333
Removed, lb mol/Hr	138	41.4	0.300
Flow Rate, GPM	6813	2953	0.433
Flow Rate, GPM	9977	5869	0.588
Quantity, SCFM	23,100	23,100	1.0
Water Flow, GPM	152,000	85,200	0.561
Water Flow, GPM		400 Account	
Capacity, GPM	54	534	1.0
Capacity, GPM	500	500	1.0
Capacity, GPM	7,500	7,500	1.0
Quantity, MM Btu/Hr	369.2	369.2	1.0
Capacity, MM lb/Hr	1,878	1,878	1.0
Flow Rate, GPM	2,536	2,536	0.993
Capacity, BBL			
	41,200		1.0
	29,400		1.0
	7,800		1.0
	68,100		1.0
	5,000		1.0
	5,500		1.0
	10,650		1.0
	---	---	1.0
	---	---	1.0