

DOE/RA/50371-1135 Vol. 3

December 1981

GAI Report No. 2344

DOE/RA/50371--1135 Vol. 3

DE82 008248

ENVIRONMENTAL ASSESSMENT
PHILADELPHIA GAS WORKS
MEDIUM-BTU COAL GASIFICATION PROJECT

DISCLAIMER

This book was prepared at an account of work performed by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, results, or conclusions disclosed, or suggested that its use would not infringe on privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

MASTER

Prepared By:

PHILADELPHIA GAS WORKS
1518 WALNUT STREET
PHILADELPHIA, PA 19102

and

GILBERT ASSOCIATES, INC.
525 LANCASTER AVENUE
READING, PENNSYLVANIA 19603

Under

DOE GRANT NO. DE-FG01-80RA50371

FOR ONLY

NOTICE

PORTIONS OF THIS REPORT ARE ILLEGIBLE. It has been reproduced from the best available copy to permit the broadest possible availability.

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

TABLE OF CONTENTS

| <u>Section</u> | <u>Title</u> | <u>Page</u> |
|----------------|---|-------------|
| | <u>EXECUTIVE SUMMARY</u> | vi |
| 1.0 | <u>PROJECT DESCRIPTION</u> | 1-1 |
| 1.1 | <u>INTRODUCTION</u> | 1-1 |
| 1.2 | <u>BASIS FOR DESIGN</u> | 1-3 |
| 1.3 | <u>OVERALL PROCESS DESCRIPTION</u> | 1-5 |
| 1.4 | <u>COAL RECEIVING AND HANDLING</u> | 1-17 |
| 1.5 | <u>COAL PREPARATION AND CONVEYING</u> | 1-20 |
| 1.6 | <u>GKT COAL GASIFICATION AND WASH WATER TREATMENT</u> | 1-22 |
| 1.7 | <u>SULFUR REMOVAL AND RECOVERY</u> | 1-31 |
| 1.7.1 | <u>Stretford Desulfurization</u> | 1-31 |
| 1.7.2 | <u>Nittetu Incineration</u> | 1-36 |
| 1.8 | <u>AIR SEPARATION</u> | 1-39 |
| 1.9 | <u>PRODUCT GAS HANDLING</u> | 1-44 |
| 1.9.1 | <u>Gas Compression</u> | 1-44 |
| 1.9.2 | <u>Gas Dehydration</u> | 1-44 |
| 1.10 | <u>WASTEWATER TREATMENT</u> | 1-46 |
| 1.11 | <u>UTILITY SUPPORT SYSTEMS</u> | 1-48 |
| 1.11.1 | <u>Plant and Potable Water System</u> | 1-48 |
| 1.11.2 | <u>Cooling Water Systems - Process Plant</u> | 1-50 |
| 1.11.3 | <u>Steam, Condensate, and Boiler</u> | |
| | <u>Feedwater System</u> | 1-51 |
| 1.11.4 | <u>Other Plant Utility Support Systems</u> | 1-54 |
| 1.11.5 | <u>Plant Off-site Support Systems</u> | 1-55 |
| 1.12 | <u>LABOR, RAW MATERIALS, AND UTILITY REQUIREMENTS</u> | 1-59 |
| 2.0 | <u>DESCRIPTION OF THE ENVIRONMENT</u> | 2-1 |
| 2.1 | <u>PHYSICAL ENVIRONMENT</u> | 2-1 |
| 2.1.1 | <u>Environmental Setting</u> | 2-2 |
| 2.1.2 | <u>Geology</u> | 2-2 |
| 2.1.3 | <u>Hydrology</u> | 2-8 |
| 2.1.4 | <u>Climate and Meteorologic Conditions</u> | 2-10 |
| 2.1.5 | <u>Existing Air Quality</u> | 2-15 |
| 2.2 | <u>BIOTIC ENVIRONMENT</u> | 2-18 |
| 2.2.1 | <u>Terrestrial Ecology</u> | 2-18 |
| 2.2.2 | <u>Aquatic Ecology</u> | 2-19 |
| 2.2.3 | <u>Special Considerations</u> | 2-28 |
| 2.3 | <u>HUMAN ENVIRONMENT</u> | 2-30 |
| 2.3.1 | <u>Demography</u> | 2-30 |
| 2.3.2 | <u>Land Use</u> | 2-32 |
| 2.3.3 | <u>Transportation</u> | 2-36 |
| 2.3.4 | <u>Community Description</u> | 2-37 |
| 2.3.5 | <u>Other Socioeconomic Characteristics</u> | 2-41 |
| 2.4 | <u>REFERENCES</u> | 2-44 |

TABLE OF CONTENTS (Cont'd)

| <u>Section</u> | <u>Title</u> | <u>Page</u> |
|----------------|---|-------------|
| 3.0 | <u>ENVIRONMENTAL IMPACTS OF THE PROPOSED PROJECT</u> | 3-1 |
| 3.1 | <u>SUMMARY OF ANTICIPATED ENVIRONMENTAL IMPACTS</u> | 3-1 |
| 3.2 | <u>EFFECTS ON THE PHYSICAL ENVIRONMENT</u> | 3-8 |
| 3.2.1 | <u>Geotechnical Impact</u> | 3-8 |
| 3.2.2 | <u>Impacts on Hydrology</u> | 3-9 |
| 3.2.3 | <u>Impacts on Air Quality</u> | 3-9 |
| 3.3 | <u>EFFECTS ON THE BIOTIC ENVIRONMENT</u> | 3-15 |
| 3.3.1 | <u>Impacts on Terrestrial Ecology</u> | 3-15 |
| 3.3.2 | <u>Impacts on Aquatic Ecology</u> | 3-16 |
| 3.4 | <u>EFFECTS ON HUMAN ENVIRONMENT</u> | 3-18 |
| 3.4.1 | <u>Safety and Health Factors</u> | 3-19 |
| 3.4.2 | <u>Demographic Impacts</u> | 3-24 |
| 3.4.3 | <u>Land Use Impacts</u> | 3-25 |
| 3.4.4 | <u>Impacts on Transportation</u> | 3-27 |
| 3.4.5 | <u>Local Community Impacts</u> | 3-28 |
| 3.4.6 | <u>Employment and Economic Impacts</u> | 3-28 |
| 3.4.7 | <u>Impacts on Wage Rates</u> | 3-31 |
| 3.4.8 | <u>Institutional Effects (Growth and Tax Base)</u> | 3-32 |
| 3.4.9 | <u>Noise Impacts</u> | 3-33 |
| 3.5 | <u>REFERENCES</u> | 3-35 |
| 4.0 | <u>ALTERNATIVES TO THE PROPOSED ACTION AND THEIR IMPACTS</u> | 4-1 |
| 4.1 | <u>FUEL ALTERNATIVES</u> | 4-2 |
| 4.2 | <u>ALTERNATIVE GASIFIER</u> | 4-3 |
| 4.3 | <u>SULFUR REMOVAL ALTERNATIVES</u> | 4-4 |
| 4.4 | <u>NO ACTION ALTERNATIVE</u> | 4-4 |
| 5.0 | <u>AGENCIES OR COMPANIES CONTACTED AND LETTERS OF ENDORSEMENT</u> | 5-1 |
| Appendix A | <u>Letters of Endorsement</u> | A-1 |

LIST OF TABLES

| <u>Table</u> | <u>Title</u> | <u>Page</u> |
|--------------|--|-------------|
| 1-1 | PGW Gasification Plant Overall Material Balance - Design Product Gas Production - Ash Recycle Case | 1-10 |
| 1-2 | GKT Gasification Unit Material Balance - Design Product Gas Production, Non-Ash Recycle Case | 1-23 |
| 1-3 | PGW Gasification Project - Stretford Plant Process Material and Energy Balance | 1-34 |
| 1-4 | Material Balance For Nittetu Incineration Plant | 1-38 |
| 1-5 | Annual Raw Materials, Utility, Labor, and By-Product Summary | 1-60 |
| 1-6 | Operating Labor Requirements | 1-61 |
| 2-1 | Variation of Flow in the Estuary in August 1955-1957 | 2-9 |
| 2-2 | Flood Levels and Recurrence Intervals at the Proposed Site | 2-10 |
| 2-3 | Dilution of Pollutants - Philadelphia, Pa. | 2-15 |
| 2-4 | Water Quality Parameters For the Delaware River at Benjamin Franklin Bridge, Philadelphia, 1978-1979 | 2-20 |
| 2-5 | Water Quality Parameters for the Delaware River at Torresdale Intake, Philadelphia, 1978-1979 | 2-21 |
| 2-6 | Water Quality Parameters Measured in the Vicinity of River Miles 100-102, Delaware River | 2-23 |
| 2-7 | Pennsylvania Water Quality Criteria That Apply to the Delaware River in the Vicinity of the PGW Site | 2-24 |
| 2-8 | Temperature Criteria That Apply to the Delaware River in the Vicinity of the PGW Site | 2-25 |
| 2-9 | EPA's Quality Criteria for Water for Parameters That Have Been Measured Near the PGW Site | 2-26 |
| 2-10 | Socio-Economic Characteristics By Census Tract | 2-33 |
| 2-11 | Ranking of Primary Problem Issues | 2-40 |
| 2-12 | Major Employment Categories by Census Tract, 1970 | 2-42 |
| 2-13 | Unemployment by Census Tract, 1970 | 2-42 |
| 2-14 | Median Years of School Completed, 1970 | 2-43 |
| 3-1 | Site Specific Compliance With Water, Air, and Solid Waste Environmental Regulations For a Coal Gasification Facility in Philadelphia | 3-2 |
| 3-2 | Permits Required For PGW Coal Gasification Plant | 3-3 |
| 3-3 | Summary of Operational Impacts | 3-5 |

LIST OF TABLES (Cont'd)

| <u>Table</u> | <u>Title</u> | <u>Page</u> |
|--------------|---|-------------|
| 3-4 | Estimated Emissions Resulting From Industrial Burning of 20 Million Btu Per day Medium-Btu Gas Compared With Burning No. 6 Fuel Oil | 3-13 |
| 3-5 | Product Gas Flammability and Toxicity Data - GKT Gasification Plant | 3-20 |
| 3-6 | Summary of Gas Plant Total Economic Impacts | 3-31 |
| 5-1 | Agencies or Companies Contacted Concerning Environmental Aspects of Project | 5-2 |

LIST OF FIGURES

| <u>Figure</u> | <u>Title</u> | <u>Follows Page</u> |
|---------------|---|---------------------|
| 1-1 | Gasification Plant Block Flow Diagram | 1-5 |
| 1-2 | Process Flow Diagram - Coal Handling and Coal Receiving | 1-18 |
| 1-3 | Process Flow Diagram - GKT Gasification Plant - Unit 30 (Sheet 1 of 2) | 1-26 |
| 1-4 | Process Flow Diagram - GKT Gasification Plant - Unit 30 (Sheet 2 of 2) | 1-26 |
| 1-5 | Process Flow Diagram - GKT Wash Water Treatment - Unit 72 | 1-26 |
| 1-6 | Process Flow Diagram - Stretford Desulfurization -Unit 42 | 1-33 |
| 1-7 | Process Flow Diagram - Nittetu Incineration-Unit 44 | 1-37 |
| 1-8 | Process Flow Diagram - Air Separation Plant - Unit 50 | 1-40 |
| 1-9 | Process Flow Diagram - Gas Compression and Dehydration - Units 62 and 64 | 1-45 |
| 1-10 | Process Flow Diagram - Wastewater Treatment - Unit 74 | 1-46 |
| 1-11 | Process Flow Diagram - Distribution of Average Daily Water Use | 1-48 |
| 1-12 | Process Flow Diagram - Plant Make-up Water Treatment-Unit 84 | 1-49 |
| 1-13 | Process Flow Diagram - Cooling Water System - Process Plant - Unit 87 | 1-50 |
| 1-14 | Process Flow Diagram - Steam, Condensate, and B.F.W. - Unit 82 | 1-51 |
| 2-1 | Aerial Photographs | 2-1 |
| 2-2 | Primary Study Area | 2-1 |
| 2-3 | Geologic Map | 2-3 |
| 2-4 | Generalized Cross-Section Through Plant Site | 2-3 |
| 2-5 | 1980 Philadelphia Census Tracts - TSP Attainment Status | 2-16 |
| 2-6 | 1980 Philadelphia Census Tracts - Sulfur Dioxide Attainment Status | 2-16 |
| 2-7 | 1980 Philadelphia Census Tracts - Census Tracts Examined in Detail | 2-31 |
| 2-8 | Coastal Zone Classification of the Plant Site | 2-33 |
| 2-9 | Existing Land Use in the Vicinity of the Plant Site | 2-34 |
| 2-10 | Estimated Average Daily Traffic Volumes, 1978-1979 | 2-37 |
| 3-1 | Permit and Licensing Schedule | 3-3 |



FRONTISPIECE

EXECUTIVE SUMMARY

INTRODUCTION

The energy crisis and the loss of industries in the City of Philadelphia have been the driving forces behind this project to build a central coal gasification facility in the city for producing medium-Btu gas for industrial usage.

The energy crisis has created a situation in which low sulfur fuel oil has become scarce and expensive. Domestic natural gas has also become scarce and has either not been available to large industrial consumers of energy or has been available on an inconvenient and interruptible basis.

The City of Philadelphia has been losing jobs because industry is moving away from the area for a variety of reasons, including the difficulty in obtaining a clean burning fuel. The making of a fuel, such as environmentally acceptable coal gas, available to industries would be a factor helping to allow for industrial expansion and enticing new industries to the area.

The Industrial Fuel Use Act of 1978 was enacted to prohibit, with exceptions, the use of petroleum and natural gas in new, large industrial and utility boilers and provided for possible extension to other industrial processes. The U.S. Department of Energy developed a major national policy of conversion from fuel oil and natural gas to the more abundant coal resources.

Although there are numerous low- and medium-Btu gasification plants operating overseas, there are only limited commercial users of low-Btu coal gas and no medium-Btu commercial plants in the United States today. Modern technology has resulted in the coal gasification process available today which can manufacture clean burning coal-derived gas in an environmentally acceptable manner.

On March 15, 1979, the United States Department of Energy released a Program Interest Notice (PIN) on a low/medium-Btu coal gasification assessment program for potential users in order to reach a "realistic assessment of the feasibility (from the owner/user's point of view) of utilizing low- or medium-Btu gas from coal in a variety of industrial applications and/or commercial gasification systems."

Because Philadelphia Gas Works is vitally interested in exploring the feasibility of using environmentally acceptable coal gas to help meet their charter for satisfying the city's demands for gas, they responded to the PIN and were awarded funds for a Phase I feasibility study in October 1979.

The feasibility study addressed market-analysis considerations, preliminary economic/operational analysis, heating value considerations, conceptual design of the gasification plant, and recommended economic/operational trade-offs.

The year-long study which culminated in a final report which was released in February 1981 concluded that the potential range of gas costs compared

favorably with No. 6 fuel oil as an energy source; however, the cost was very dependent on coal costs.

Additional funds were awarded to PGW in October 1980 from the U.S. DOE under Public Law 96-126 for a 12-month study to define the means by which they would proceed toward construction and operation, considering the following factors:

- a. Technical and economic feasibility,
- b. Financing alternatives,
- c. Resource assessment and availability, and
- d. Ability to construct and operate a commercial plant in an environmentally acceptable manner on a selected site.

As part of the feasibility study and in accordance with the National Environmental Policy Act which stipulates that an environmental assessment shall be prepared for Federally funded projects, an environmental assessment of the project was prepared to evaluate the positive and negative impacts, and when potentially negative impacts could occur, to explain the mitigative measures which would be taken to avoid or minimize them. This document, which describes the results of the environmental assessment, contains the following sections: (1) Project Description; (2) Description of the Environment; (3) Environmental Impacts of the Proposed Project; (4) Alternatives to the Proposed Action and Their Impacts; (5) Agencies and Companies Contacted; and an Appendix which contains letters of endorsement from agencies and companies contacted.

PROJECT PHILOSOPHY

The underlying philosophy behind the project is to design a coal gasification plant in Philadelphia using state-of-the-art pollution control technology and process equipment for producing a clean medium-Btu gas which can be both produced by the facility and burned by industrial users in an environmentally acceptable manner by complying with all applicable Philadelphia, Pennsylvania, and Federal environmental regulations. The coal gas will replace 198,388 gpd of No. 6 fuel oil which the industries would otherwise use as fuel. An architectural rendering of the proposed facility is shown in the frontispiece.

ENVIRONMENTAL IMPACTS

The overall environmental impact of the project is a positive one. The facility will have the capacity to produce 20.58×10^9 Btu per day of clean burning medium-Btu gas (HHV = 290 Btu per cu ft). This will replace 198,388 gpd of low sulfur No. 6 fuel oil which the industries would otherwise use as fuel. The project will have a stimulatory impact on the economy. Plant construction will boost total city employment by a high of 715 jobs in 1984. Plant operation will increase total city employment to 105 jobs. The major economic effects of the plant will begin to occur in 1987, as a result of the retention of the 1,500 manufacturing jobs. After accounting for ripple effects, city employment will be higher by 2,262 in 1987 and by 2,695 in 1990 because of the coal gasification plant. By 1990, the gross city product will be increased by \$110.85 million annually, personal income will be increased by

\$47 million, and the city wage and earnings tax will be increased by \$2.3 million. During the construction period, an estimated 500 construction jobs created by the project will have a positive effect on the Philadelphia economy for several calendar quarters. The operating facility is projected to provide 105 full time jobs. The increased demand on the Pennsylvania coal industry to supply 329,376 tpy of coal will benefit that industry. Philadelphia industries which are presently operating on fuel oil or interruptable natural gas would potentially close down or move away from the city if their conventional sources of energy were to become unavailable or too expensive. This trend could severely impact the city's economy at a time when there is an active program to attract new industry to Philadelphia. The facility will provide a reliable source of fuel to these industries.

The coal gasification plant will occupy a 43-acre site, known as the Riverside Site, which is located along the Delaware River next to Port Richmond between the Betsy Ross and Benjamin Franklin Bridges. The cleared site was previously used for industrial purposes and has a G-2 industrial zoning.

Adverse impacts during the construction phase of the project are not expected to be significantly different than those occurring during any major industrial construction project. Adverse impacts will be avoided or minimized whenever possible through the use of good engineering practices.

During operation of the coal gasification facility, specific mitigative measures have been designed into the facility to avoid adverse environmental impacts wherever possible. In addition to these extensive engineering safeguards, elaborate monitoring and control instrumentation shall be used.

The GKT entrained bed, oxygen-blown gasification process provided by Krupp/Koppers was selected because it is a commercially proven system and because of its positive environmental characteristics such as its ability to gasify many coal types and the fact that it does not produce tars, phenols, or ammonia. During gasification of the coal, pollutants such as heavy metals in the coal are concentrated into the slag and ash. None of these pollutants are found in the product gas.

The facility will produce 250 tpd of non-hazardous slag and fly ash. The proportion of this which is fly ash will be reduced to a minimum by returning to the gasifier a portion of the unburned carbon in the recovered fly ash. The combined slag and fly ash will occupy 347 cubic yards per day of landfill volume. Available haulers and landfills have been identified. Other methods for solid waste disposal, including returning the solid waste to the mines from which the coal came, are being explored.

Process water requirements (1,396,000 gpd) will be supplied directly from the Delaware River. This is a very small percentage of the total flow of the river. Cooling tower blowdown, treated wastewater, and treated coal pile runoff (360,000 gpd) will be returned to the river. Twenty-five percent of the water removed from the river will be returned to the river. The total quantity of Delaware River water consumed because of evaporation and process utilization will be 1,057,300 gpd. City of Philadelphia water will be used at the rate of 11,000 gpd for potable, sanitary, and miscellaneous uses and then returned to the city sanitary system.

The K-T gasifier has an uninterrupted history of safe operation. In an emergency such as loss of the coal feed system or a change in oxygen pressure the gasifiers can be shut down almost instantaneously.

A sophisticated health and safety program shall be required by the operator of the facility. This will include appropriate monitoring instruments for CO, H₂, H₂S, polynuclear aromatic hydrocarbons, organic compounds, and coal dust.

Air emissions from operation of the coal gasification plant are not considered significant. During start-up, product gas will be flared. Overall air impacts of the facility have been examined by comparing air emissions which would result if the four industries were to burn medium-Btu gas and No. 6 fuel oil (0.5 percent S). Sulfur dioxide emissions resulting from burning low sulfur oil and medium-Btu gas will be approximately the same; and, less than 70 percent of the maximum permitted by city air quality standards for burning the quantity of fuel which will be produced. None of the proposed industrial users of the medium-Btu gas is in a non-attainment area for SO₂.

Conversion to medium-Btu gas will result in a decrease in both nitrogen dioxide and particulate emissions. Nitrogen dioxide emissions will decrease from 10,667 lbs per day to 4,600 lbs per day, and particulates will decrease from 3,067 lbs per day to 360 lbs per day.

Conversion to burning of the medium-Btu gas from fuel oil by the four industrial users should cause a decrease of 283 tons per year of total suspended particulate emissions and a decrease of 1,001 tons per year of nitrogen oxide emissions.

Air emissions from the cooling tower will consist of water vapor. The cooling towers will make a minimal contribution to the water vapor already in the atmosphere and will cause no additional fogging or icing conditions in the vicinity of the plant. Air emissions from the plant flare and from vents located on various process units will consist primarily of water, air, and possible trace amounts of other gases which should neither be able to be smelled beyond the immediate area of the vents nor create a health or safety hazard to workers or the community.

Dust control systems have been designed into the facility to minimize fugitive dust emissions so that they comply with the City of Philadelphia air regulations for fugitive and nuisance dusting. Water and polymer sprays shall be utilized to control dust at the coal piles. A wind, time-activated spray system shall be used on the reserve coal pile. At other points where coal dust could be generated, such as at the delumpers, silos, and pneumatic conveyors, highly efficient fabric filters shall be used to prevent coal dust particles larger than 0.04 microns from entering the atmosphere. All coal conveyors shall be shrouded. Slag and ash shall be stored in covered hoppers and a spray system shall be used to minimize dusting when the material is transferred to covered trucks.

Other than medium-Btu gas the only recycleable by-products which will be recovered from the facility will be saleable elemental sulfur, and slag and fly ash which may be saleable. Buyers for the sulfur have been identified.

The Stretford plant, used to recover sulfur from the raw product gas, will use a Nittetu reductive incineration process to decompose the purge stream which would otherwise constitute a wastewater disposal problem.

Noise from operating the gasification facility will be minimized by using acoustical insulation and noise is not expected to be discernible among the background of industrial and highway noises already heard at the residential areas near the site.

Rail traffic through Port Richmond will increase by one 70-car train per week which will unload during a two or three day period. Thirteen 23-ton truck loads of slag/ash will leave the facility five days per week. The train traffic resulting from supplying coal to the gasification facility is less than three percent of the traffic which will be generated from the scheduled expansion of adjacent Port Richmond so that it can serve as a major coal exporting yard.

Quick access to Interstate Route 95 from the site should not cause a discernible increase in either traffic or noise in the area. Increased traffic because of employees is also not expected to cause a substantial difference in traffic flow near the site. On-site parking will be provided.

ALTERNATIVES

Several alternatives were considered in the study. The Riverside site was selected from more than 16 sites examined because it was the only available environmentally acceptable site of sufficient size for the facility near potential users of the gas within the City of Philadelphia.

Medium-Btu gas was selected as the coal derived fuel of choice because it can be transported a short distance to designated industrial users from a central plant in Philadelphia at a price which is projected to be lower than the price of No. 6 fuel oil in 1985, minimal retrofit expense is required by industrial users of the gas, and environmental considerations are restricted to a single facility.

The KT gasifier was selected from three alternative gasifiers because it is commercially proven and because of its unique ability to gasify many coals and because of the fact that it does not produce tars, phenols, or ammonia and is, therefore, an environmentally cleaner plant.

A Stretford desulfurization unit was selected from alternative systems because of its low capital cost for small capacity plants. The molten sulfur configuration was selected because it produces a saleable product and results in no solid or liquid waste.

The alternative of taking no action was rejected at the start of the feasibility study whose purpose was to explore the use of coal gas as a substitute for fuel oil and natural gas.

AGENCIES AND COMPANIES CONTACTED

The following agencies or companies have been contacted concerning the project and in some cases have already provided letters supporting the project:

Delaware River Basin Commission,
Pennsylvania Department of Environmental Resources,
Philadelphia Department of Licenses and Inspection,
Philadelphia Air Management Services,
Philadelphia Water Department,
Philadelphia Port Corporation,
Philadelphia Industrial Development Corporation,
Philadelphia Planning Commission,
United States Environmental Protection Agency,
U.S. Army Corps of Engineers,
U.S. Energy Management Agency,
Conrail,
Danella Bros., Inc.
Lanchester Corporation,
Arco Chemical Co., and
Essex Chemical Corporation.

1.0 PROJECT DESCRIPTION

1.1 INTRODUCTION

The energy crisis and the loss of industries in the City of Philadelphia have been the driving forces behind this project to build a central coal gasification facility in the city for producing medium-Btu gas for industrial usage.

The energy crisis has created a situation in which low sulfur fuel oil has become scarce and expensive. Domestic natural gas has also become scarce and has either not been available to large industrial consumers of energy or has been inconveniently available on an interruptible basis.

The City of Philadelphia has been losing jobs because industry is moving away from the area for a variety of reasons, including the inability to obtain a clean burning fuel. The making of a fuel, such as environmentally acceptable coal gas, available to industries would be a factor in helping to allow for industrial expansion and enticing new industries to the area.

The Industrial Fuel Use Act of 1978 was enacted to prohibit, with exception, the use of petroleum and natural gas in new large industrial and utility boilers and provided for possible extension to other industrial processes. The U.S. Department of Energy developed a major national policy of conversion from fuel oil and natural gas to the more abundant coal resources.

Although there are numerous low and medium-Btu gasification plants operating overseas, there are only limited commercial users of low-Btu coal gas and no medium-Btu commercial plants in the United States today. Gas derived from coal lit the streets of Philadelphia before natural gas became available; however, the process used to produce the gas then would not be acceptable with today's strict

environmental standards. Modern technology has resulted in the coal gasification process available today which can manufacture clean burning coal-derived gas in an environmentally acceptable manner. Other, larger coal gasification plants using technology similar to that proposed for the Philadelphia project are being planned by the Tennessee Valley Authority in Murphy Hill, Alabama, and by the City of Memphis, Tennessee.

On March 15, 1979, the United States Department of Energy released a Program Interest Notice (PIN) on a low/medium-Btu coal gasification assessment program for potential users in order to reach a "realistic assessment of the feasibility (from the owner/user's point of view) of utilizing low or medium Btu gas from coal in a variety of industrial applications and/or commercial gasification systems."

Because the Philadelphia Gas Works is vitally interested in exploring the feasibility of using environmentally acceptable coal gas to help meet their charter for satisfying the city's demands for gas they responded to the PIN and were awarded funds for the Phase I feasibility study in October of 1978.

The feasibility study addressed market-analysis considerations, preliminary economic/operational analysis, heating value considerations, conceptual design of the gasification plant, and recommended economic/operational trade-offs.

The year long study that culminated in a final report, which was released in February 1981, concluded that the potential range of gas costs compared favorably with No. 6 fuel oil as an energy source; however, the cost was very dependent on coal costs.

Additional funds were awarded to PGW in October 1980 under Public Law 96-126 from the U.S. DOE for a 12-month study to define the

means by which they would proceed toward construction and operation, considering:

- a. Technical and economic feasibility,
- b. Financing alternatives,
- c. Resource assessment and availability, and
- d. Ability to construct and operate a commercial plant in an environmentally acceptable manner on a selected site.

As part of the feasibility study and in accordance with the National Environmental Policy Act an Environmental Assessment contained in the following document was prepared to demonstrate how the facility will be constructed and operated in an environmentally acceptable manner.

1.2 BASIS FOR DESIGN

The underlying philosophy behind the project is to design a coal gasification plant in Philadelphia using state-of-the-art pollution control technology and process equipment for producing a medium-Btu gas which can be both produced by the facility and burned by industrial users in an environmentally acceptable manner. The coal gas will replace 198,388 gpd of No. 6 fuel oil which the industries would otherwise use as fuel. Specific features of the project are listed as follows:

Type of Plant: Coal gasification plant producing medium-Btu gas for industrial users.

Plant Site: City of Philadelphia on the Delaware River at the Riverside site located between the Benjamin Franklin and Betsy Ross Bridges.

Plant Size: Two gasifiers with a capacity of producing 20.58×10^9 Btu/day of medium-Btu gas for distribution to industry.

Coal Feed: 1,128 tpd (329,376 tpy) of Pittsburgh No. 8 and/or other eastern bituminous coals. Characteristics of the coal are shown in Table 1-1.

Coal Storage: Live storage; 10,000 tons. Dead storage; 56,000 tons.

Gasification Process: GKT gasification process provided by Krupp/Koppers.

Sulfur Removal and Recovery: Stretford plant designed to remove essentially all H_2S from product gas. COS is not removed from gas, resulting in 0.1 mole percent sulfur in product gas. 27.2 tons per day of pure elemental molten sulfur will be produced for sale to the chemical market.

Maks-up Water Supply: Potable water (11,000 gpd) is to be supplied from the City of Philadelphia Water Department. Plant water requirements (1,396,000 gpd) are supplied directly from the Delaware River.

Wastewater Disposal: Sanitary wastewater (11,000 gpd) discharged to the City of Philadelphia Sanitary System; cooling water blowdown, treated wastewater, and treated coal pile runoff (360,000 gpd) discharged into the Delaware River. Twenty-five percent of the water removed from the river will be returned to the river at the facility.

Solid Waste Disposal: Non-hazardous fly ash from gas scrubbing (202 tpd) and slag from gasifier bottoms (48 tpd) picked up at the plant gate by a contracted hauler and transported to a licensed landfill. The volume of solid waste produced will be 347 cubic yards per day.

Health and Safety: A health safety program for worker protection includes monitors and alarms for H₂S, CO, H₂, dust, polynuclear aromatic hydrocarbons, and organic compounds. Almost instantaneous shutdown of the gasifier is possible in the event of an emergency such as loss of the coal feed system or a change in oxygen pressure.


Dust Control: Dust control and filters, sprays, and enclosed structures used to control dust during storage and handling of coal, ash, and slag.

Noise: Enclosed buildings, accoustical shrouding, and insulation specified at major sources of noise such as at the coal unloading area and coal crushers.

1.3 OVERALL PROCESS DESCRIPTION

The preliminary design completed during Phase II of the PGW Coal Gasification Project is based on the gasification process offered by GKT. The GKT Gasification Unit consists of two parallel gasification and clean-up trains. No spare trains are provided in the present design. An overall process block diagram of the PGW gasification plant is shown in Figure I-1. The gasification plant basically consists of the following units:

| <u>Unit No.</u> | |
|-----------------|--------------------------------|
| 10 | Coal Receiving and Handling |
| 15 | Coal Dust Supression |
| 20 | Coal Preparation and Conveying |
| 30 | GKT Gasification |
| 40 | Sulfur Removal and Recovery |
| 42 | Stretford Desulfurization |
| 44 | Nittetu Incineration |
| 50 | Air Separation |






FIGURE 1-1

| | |
|--|----------------------|
| 087551008 | |
| PRELIMINARY NOT FOR CONSTRUCTION | |
| DESIGNED BY | DATE |
| CONSTRUCTED BY | RELEASED FOR |
| DATE | EXCISE |
| PHILADELPHIA GAS WORKS COAL GASIFICATION PLANT PHILADELPHIA, PA GASIFICATION PLANT BLACK FLUX STAGES | |
| SILBERT ASSOCIATES, INC. ENGINEERS AND ARCHITECTS PHILADELPHIA, PA | |
| PROJECT NO. | 08 8276 ER-671-002 A |
| DATE | 08/15/68 |

Unit No.

| | |
|----|-----------------------------------|
| 60 | Product Gas Handling |
| 62 | Gas Compression |
| 64 | Gas Dehydration |
| 70 | Water Treatment |
| 72 | GKT Wash Water |
| 74 | Waste Water |
| 80 | Utilities |
| 81 | Cooling Water |
| 82 | Steam, BFW, and Condensate Return |
| 83 | Firewater |
| 84 | Plant & Potable Water |
| 85 | Plant and Instrument Air |
| 86 | Sewer and Sanitary Drain |
| 87 | Boiler |
| 90 | Offsites |
| 91 | Main Process Flare & Relief |
| 92 | Fly Ash Removal and Storage |
| 94 | Slag Removal and Storage |

For the GKT gasification plant 2.0 in. by 0 in. sized coal is delivered by unit train via in-plant tracks to the Coal Receiving and Handling Unit. In this unit the coal is unloaded from the unit train to the storage area, where a stock pile is formed by a lowering well. From the storage area, belt conveyors deliver the coal to bunkers for coal preparation at the rate of approximately 1200 tons per day (as received, without loss).

In the Coal Preparation and Conveying Unit the coal is fed from the bunkers to pulverizers where the coal is dried and pulverized to the following GKT gasifier feed requirements:

- o Size - 90 percent through 170 mesh and 70 percent through 200 mesh
- o Moisture Content - one percent

An air heater which uses medium-Btu product gas is used to heat air for the purpose of reducing the coal inlet moisture to one percent in the pulverizer. The heated air pneumatically carries the coal from the pulverizer to a particulate removal system. Coal dust (pulverized coal) from the removal system is collected and pneumatically conveyed via by-product nitrogen from an air separation plant to service bins within the GKT Gasification Unit battery limits.

In the entrained bed gasifiers, the coal dust is oxidized by oxygen in the presence of steam. Coal, oxygen, and steam are brought together and distributed to four gasifier burner heads which are 90° apart. Reaction temperature at the burner head discharge is 3300-3500°F and the operating pressure is slightly above atmospheric. The coal is gasified almost completely and immediately. Under the process conditions prevailing in the gasifier, carbon and hydrocarbons contained in the coal are converted to carbon monoxide, hydrogen, and carbon dioxide.

The gasifier is a refractory lined steel shell equipped with a water jacket for producing low-pressure process steam at 28 psig. The low pressure steam from the jacket is more than enough to meet the gasifier's needs.

Oxygen for the gasification reaction is provided by an air separation plant. The air separation plant will be a turnkey facility, and engineering and design services will be furnished by a contractor experienced in this field. The oxygen purity for the plant is 98 vol percent with 2 percent inerts (mostly argon). By-product nitrogen (98 vol percent purity) from the plant is used for coal dust conveying and gasification system purging and blanketing.

In the gasifier, approximately 30 percent of the coal ash particles coalesce and drop out as slag into a slag quench and removal system.

The slag is removed by belt conveyor to temporary slag storage facilities (Unit 94) prior to rail loading for disposal.

The remaining 70 percent of the fine ash particulates are carried overhead out of the gasifier as fly ash entrained with unburned carbon and are removed downstream by the gas clean-up train.

The medium-Btu product exits the gasifier at approximately 2700°F. The gas passes through a waste heat boiler which produces 925 psig saturated steam. At the exit of the waste heat boiler the gas temperature is reduced to 600°F. The gas then passes through a clean-up train where the temperature of the gas is subsequently reduced to 95°F and the majority of the entrained fly ash and carbon particulates are removed.

In the clean-up train the fly ash is removed via a circulating wash water system which scrubs the gas. The wash water stream laden with fly ash and unburned carbon is sent to the GKT Wash Water Treatment (Unit 72). In the wash water treatment the entering wash water stream is sent to two rectangular settling ponds. The fly ash sludge from the settling ponds is sent to a common thickener. The underflow of the thickener is pumped to rotary vacuum filter where the moisture is reduced to 50 percent. The fly ash filter cake is then sent via belt conveyor to temporary storage facilities (Unit 92) prior to disposal by rail or truck. The amount of fly ash to disposal for a typical Pittsburgh No. 8 coal at the plant design production rate is 345 tpd.

To reduce the sludge disposal problems, and also to reutilize some of the carbon in the fly ash cake, recycling of up to 50 percent of the sludge cake to the gasifiers is incorporated in the present design. Recycle of 50 percent of the fly ash cake will increase the gasifier carbon conversion from 88.0 to 93.6 percent while reducing the raw coal feed by 6 percent. The recycle of sludge to the gasifier is limited to 50 percent, since the pulverizer and air

heater design is currently limited to a maximum of 12 percent moisture. Recycle of 50 percent of the sludge cake to the gasifier will not significantly affect the gasifier gas production or composition, since the hydrogen, oxygen, nitrogen, and sulfur to carbon ratios in the mixed feed are essentially the same as the raw coal feed.

Summarized in Table 1-1 is the material balance for the recycle of sludge cake cases. The material balance represents a product gas production rate of 20.58 billion Btu/day at the plant battery limits (high heating value, no sensible heat credit basis).

Downstream of the gas clean-up train the two gasification trains join together to form a single train. The gas then passes through a gas holder and an electrostatic precipitator for final particulate removal before exiting the GKT battery limits. The composition and conditions of the product gas exiting the GKT battery limits are shown below:

| <u>Component</u> | <u>Mole%</u> |
|--------------------|--------------|
| H ₂ | 27.29 |
| N ₂ | 0.92 |
| Ar | 0.57 |
| CO ₂ | 6.36 |
| CO | 58.61 |
| CH ₄ | 0.01 |
| H ₂ S | 0.85 |
| COS | 0.09 |
| HCN | 75 PPMV |
| H ₂ O | <u>5.30</u> |
| TOTAL | 100.00 |
| Temperature, °F | 95 |
| Pressure, in. W.C. | 22 |

TABLE 1-1

PCW GASIFICATION PLANT OVERALL MATERIAL BALANCE
DESIGN PRODUCT GAS PRODUCTION (20.58 ± 10³ BTU/DAY), ASH RECYCLE CASK

| STREAM NO. (1) | 1 | | 2 | | 3 | | 4 | | 5 | | 6 | |
|--------------------------|-------------------------|--------------------------------------|----------------------------|---|--|---|--|---------|---|--|---|--|
| | COAL FED TO GKT UNIT | DRIED COAL FED TO (1189.6 TPD) | OXYGEN FEED TO GKT UNIT | L.P. STEAM INPUT TO GKT GASIFIERS | PRODUCT GAS OUTLET GKT BATTERY LIMITS | FUEL GAS FROM NITREX INGENERATION | PRODUCT GAS INLET STRETFORD UNIT | | | | | |
| | 99,137 | (1189.6 TPD) | 94,910 (1139 TPD) | 8843 | 179,794 | 7,420 | 186,069 | | | | | |
| | | | 18,662 | | 52,781 | 1,581 | 53,958 | | | | | |
| | | | 32.16 | | 21.54 | 29.69 | 21.81 | | | | | |
| TEMPERATURE, °F | 60 | | 100 | 274 | 95 | 120 | 101 | | | | | |
| PRESSURE, PSIG (IN W.C.) | ATM | | 0.4 (12) | 28 | 0.8 (22) | 0.8 (22) | 5.8 | | | | | |
| COMPONENTS | LB/HR | WT % | LB/HR | MOLE % | LB/HR | MOLE % | LB/HR | MOLE % | | | | |
| S | 2,370 | 2.39 | | | | | | | | | | |
| C | 74,180 | 74.83 | | | 4,556 | 27.29 | 4,578 | 26.82 | | | | |
| H ₂ | 4,739 | 4.78 | | | 2,150 | 0.92 | 5,538 | 2.32 | | | | |
| O ₂ | 4,250 | 4.29 | 92,556 | 98.00 | 1,900 | 0.57 | 1,900 | 0.56 | | | | |
| N ₂ | 1,279 | 1.30 | 2,354 | 2.00 | 23,358 | 6.36 | 26,035 | 6.93 | | | | |
| Ar | | | | | 136,980 | 58.61 | 137,652 | 57.62 | | | | |
| CO ₂ | | | | | 13 | 0.01 | 13 | 0.01 | | | | |
| CO | | | | | 2,417 | 0.85 | 2,554 | 0.88 | | | | |
| CH ₄ | | | | | 451 | 0.09 | 451 | 0.09 | | | | |
| H ₂ S | | | | | 17 | 75 PPMV | 17 | 74 PPMV | | | | |
| COB | | | | | 7,952 | 5.30 | 7,331 | 4.77 | | | | |
| HCH | | | | | | | | | | | | |
| H ₂ O | 995 | 1.00 | | 8843 | | | | | | | | |
| STRETFORD SOLN. | | | | | | | | | | | | |
| ASH | 11,324 | 11.42 | | | | | | | | | | |
| SLAG | | | | | | | | | | | | |
| TOTAL | 99,137 | 100.00 | 94,910 | 100.00 | 179,794 | 100.00 | 186,069 | 100.00 | | | | |

(1) Stream numbers correspond to those shown on Gasification Block Flow Diagram, Figure 1-1.

TABLE 1-1 (Cont'd)

| STREAM NO. | STREAM DESCRIPTION | 7 | | 8 | | 9 | | 10 | | 11 | | 12 | |
|------------------|--------------------------|-------------------------------------|---|------------------------------|-----------------------------------|---|---|---------|--------|-------|--------|---------|--------|
| | | PRODUCT (GAS OUTLET STRETFORD UNIT) | PRODUCT GAS OUTLET GAS COMPRESSION UNIT | FLARE PRODUCT FUEL GAS USAGE | PRODUCT GAS DERIVATION UNIT INLET | PRODUCT GAS PLANT BATTERY LIMITS OUTLET | PRODUCT FUEL GAS TO NITRYL INCINERATION | | | | | | |
| | TOTAL FLOW, LB/HR | 186,150 | 178,188 | 5,147 | 173,041 | 170,683 | 2,935 | | | | | | |
| | VAPOR FLOW, SCFH | 54,517 | 51,719 | 1,485 | 50,234 | 49,385 | 832 | | | | | | |
| | LIQUID FLOW, GPH | | | | | | | | | | | | |
| | VAPOR MOLECULAR WT. | 21.60 | 21.79 | 21.78 | 21.78 | 21.85 | 21.78 | | | | | | |
| | TEMPERATURE, OF | 105 | 100 | 100 | 100 | 160 | 100 | | | | | | |
| | PRESSURE, PSIG (IN H.G.) | 1.5 (41.6) | 40.3 | 40.3 | 40.3 | 35.3 | 40.3 | | | | | | |
| | COMPONENTS | | | | | | | | | | | | |
| B | | 4,375 | 26.53 | | | | | | | | | | |
| C | | | | | | | | | | | | | |
| H ₂ | | | | 129 | 27.98 | 4,446 | 27.98 | 4,446 | 28.45 | 74 | 27.98 | | |
| O ₂ | | | | | | | | | | | | | |
| N ₂ | | 5,538 | 2.29 | | | | | | | | | | |
| Ar | | 1,900 | 0.55 | 177 | 2.41 | 5,361 | 2.41 | 5,361 | 2.45 | 101 | 2.41 | | |
| CO ₂ | | 25,549 | 6.74 | 58 | 0.58 | 1,842 | 0.58 | 1,842 | 0.59 | 33 | 0.58 | | |
| CO | | 137,565 | 56.99 | 733 | 7.10 | 24,616 | 7.10 | 24,616 | 7.22 | 418 | 7.10 | | |
| CH ₄ | | 13 | 0.01 | 3,949 | 60.07 | 133,616 | 60.07 | 133,616 | 61.08 | 2,251 | 60.07 | | |
| H ₂ S | | | | | | 13 | 0.01 | 13 | 0.01 | | | | |
| COS | | 451 | 0.09 | | | | | | | | | | |
| H ₂ O | | 6 | 27 PPMV | 25 | 0.09 | 1 | 28 PPMV | 426 | 0.09 | 14 | 0.09 | | |
| STRETFORD SOLW. | | 10,553 | 6.80 | 75 | 1.76 | 2,516 | 1.76 | 2,516 | 1.76 | 158 | 0.11 | | |
| ASH | | | | | | | | | | | | | |
| SLAG | | | | | | | | | | | | | |
| TOTAL | | 186,150 | 100.00 | 5,147 | 100.00 | 173,041 | 100.00 | 170,683 | 100.00 | 2,935 | 100.00 | 2,934.6 | 100.00 |

TABLE I-1 (Cont'd)

| STREAM NO. | 13 | 14 | 15 | 16 | 17 | 18 | 19 |
|--------------------------|--------------------------------------|---|---|----------------------------|----------------------------|---------------------------|---|
| STREAM DESCRIPTION | PRODUCT FUEL GAS TO COAL PREPARATION | GKT GASIFICATION L.P. STEAM TO DISTRIBUTION | GKT GASIFICATION H.P. STEAM TO DISTRIBUTION | GKT UNIT WASH WATER SUPPLY | GKT UNIT WASH WATER RETURN | GKT UNIT SLAG TO DISPOSAL | PURGING/BLANKETING NITROGEN TO GKT UNIT |
| TOTAL FLOW, LB/HR | 2,212 | 101,062 | 111,093 | 2,088,407 | 2,090,143 | 3,997 (48 TPD) | 10,990 |
| VAPOR FLOW, SCFH | 642 | - | - | - | - | - | 2,482 |
| LIQUID FLOW, GPM | - | - | - | 4,178 | 4,182 | - | - |
| VAPOR MOLECULAR WT. | 21.78 | - | - | - | - | - | 28 |
| TEMPERATURE, OF | 100 | 274 | 453 | 113 | 158 | 70 | 100 |
| PRESSURE, PSIG (IN W.C.) | 40.3 | 28 | 925 | 100 | 10 | ATH | 10 |
| COMPONENTS | LB/HR MOLE % | LB/HR | LB/HR | LB/HR | LB/HR | LB/HR WT% | LB/HR |
| S | - | - | - | - | - | - | - |
| C | - | - | - | - | - | - | - |
| H ₂ | 55 | - | - | - | - | - | - |
| O ₂ | - | - | - | - | - | - | - |
| N ₂ | 76 | - | - | - | - | - | - |
| Ar | 25 | - | - | - | - | - | - |
| CO ₂ | 315 | - | - | - | - | - | - |
| CO | 1,698 | - | - | - | - | - | - |
| CH ₄ | - | - | - | - | - | - | - |
| H ₂ S | - | - | - | - | - | - | - |
| COS | 11 | - | - | - | - | - | - |
| HCN | 0.4 | - | - | - | - | - | - |
| H ₂ O | 28 | 101,062 | 111,093 | 2,088,407 | 2,090,143 | 600 | 15.00 |
| STRETFORD SOLN. | 32 | - | - | - | - | - | - |
| ASH | - | - | - | - | - | 3,397 | 85.00 |
| SLAG | - | - | - | - | - | - | - |
| TOTAL | 2,212.4 | 101,062 | 111,093 | 2,088,407 | 2,090,143 | 3,997 | 10,990 |

TABLE 1-1 (Cont'd)

| STREAM NO. | 20 | 21 | 22 | 23 | 24 |
|--------------------------|---|---|--|---------------------|--|
| STREAM DESCRIPTION | EMERGENCY SHUTDOWN NITROGEN TO CRT UNIT | CONVEYING NITROGEN TO COAL PREPARATION UNIT | RAW COAL FEED TO COAL PREPARATION UNIT | FLY ASH TO DISPOSAL | FLY ASH RECYCLE TO COAL PREPARATION UNIT |
| TOTAL FLOW, LB/HR | 65,940 | 13,736 | 2,000,000 (1000 TPH)(1) | 16,826 (201.9 TPD) | 16,826 (201.9 TPD) |
| VAPOR FLOW, SCFH | 14,891 | 3,102 | | | |
| LIQUID FLOW, GPH | | | | | |
| VAPOR MOLECULAR WT. | 28 | 28 | | | |
| TEMPERATURE, °F | 100 | 100 | | | |
| PRESSURE, PSIG (IN H.C.) | 15 | 35 | | | |
| COMPONENTS | | | 60 | 70 | 70 |
| S | | | ATM | ATM | ATM |
| C | | | LB/HR | LB/HR | LB/HR |
| E ₂ | | | 50,400 | | |
| O ₂ | | | 1,483,000 | | |
| N ₂ | | | 100,800 | 4,452 | 4,452 |
| Ar | | | 90,400 | | |
| CO ₂ | | | 27,200 | | |
| CO | | | | | |
| CH ₄ | | | | | |
| H ₂ S | | | | | |
| CS ₂ | | | | | |
| HCl | | | | | |
| H ₂ O | | | | | |
| STRETFORD SOLN. | | | | | |
| ASH | | | 91,600 | 8,413 | 8,413 |
| SLAG | | | 156,600 | 3,961 | 3,961 |
| TOTAL | 65,940 | 13,736 | 2,000,000 | 16,826 | 16,826 |
| | | | 100.00 | 100.00 | 100.00 |
| | | | | 23.34 | 23.6 |
| | | | | 50.00 | 50.0 |
| | | | | | 26.6 |

(1) Maximum 1 shift per day operation

From the GKT Gasification Unit the gas is compressed to approximately 6 psig prior to entering the Desulfurization Unit. The desulfurization unit is a Stretford process which removes H₂S present in the raw gas by converting it to recoverable elemental sulfur. The Stretford process is a low temperature absorption-direct oxidation desulfurization process. The raw gas from the GKT gasifier contains about 0.90 and 0.09 percent of H₂S and COS, respectively, on a dry gas volume basis. To comply with the EPA environmental regulations set by the City of Philadelphia (500 PPMV or 0.86 lb SO₂/10⁶ Btu input), the raw gas must be cleaned before being utilized in the boilers. The Stretford desulfurization process removes almost all H₂S from the gas. COS in the gas is not removed; however, its content is low and burning the gas will produce only 350 PPMV SO₂.

The Stretford process basically consists of an absorber, oxidizers, a sulfur removal system, an incineration unit for handling Stretford purge solution, and associated pumps, air blowers, and solution makeup equipment. Removal of H₂S occurs in the Stretford absorber mixer and reaction vessel where the product gas stream contacts the lean Stretford solution. The clean gas exiting the reaction vessel is delivered to the Gas Compression and Dehydration Units at 1050F and 2 psig.

The sulfur removal system employed for the Stretford process produces a saleable molten sulfur product. The molten sulfur is stored in a storage pit prior to rail loading. The molten sulfur produced at design gasification plant capacity for a typical Pittsburgh No. 8 coal is 27.3 TPD.

In the Stretford process, salts (Na₂SO₄, Na₂S₂O₃, & NaSCN) are produced during the absorption and oxidation steps. The salts accumulate in the Stretford solution and the free alkali portion of the working solution is suppressed. To remedy this, a purge stream from the Stretford solution containing salts formed during the

process is sent to a Nittetu Incineration Plant (Unit 44) to decompose the salts via reductive incineration. In the Nittetu unit the purge solution is vaporized and the salts decomposed in a furnace. Reformed molten salts are then quenched and the solution returned to the Stretford process. Decomposed gases (containing H_2S) formed during the quench operation are sent to the inlet of the Stretford absorber where they are mixed with the raw product gas from the GKT plant.

From the Desulfurization Unit the desulfurized product gas is compressed to 35 psig in a set of parallel compressors. The two compressors are centrifugal machines with aftercoolers and are driven by condensing steam turbines using excess low pressure steam from the gasifier jacket. A third compressor driven by electric motor will provide a 50 percent standby capability for startup and emergency situations.

From the Gas Compression Unit (Unit 62) the product gas enters the Gas Dehydration Unit. In the gas dehydration unit, excess water from the compressed gas (40 psig) is removed to meet the selected product gas water content. Most natural gas pipelines specifications require a water content not to exceed 7.0 lb H_2O /MM SCF due to long pipeline distances and pressures up to 1000 psia. The PGW application requires transmission distances of only five miles and a discharge pressure of 35 psig. Therefore, a low gas water content specification is not necessary and economic considerations have led to the selection of 53.3 lb H_2O /MM SCF (or 20°F dew point). The wet compressed gas at 40 psig and dew point of 100°F has a water content of 851.1 lb/MM SCF. The dehydration unit will remove the excess water (797.8 lb/MM SCF) to prevent gas freeze-ups and gas transmission problems such as pipe line corrosion. A standard triethylene glycol system is employed for the Dehydration Unit (Unit 64).

From the gas dehydration unit the product gas is metered prior to exiting the plant battery limits and entering the product gas distribution system. The composition and conditions of the product gas exiting the plant battery limits are shown below:

| <u>Component</u> | <u>Mole%</u> |
|------------------|--------------|
| H ₂ | 28.45 |
| N ₂ | 2.45 |
| Ar | 0.59 |
| CO ₂ | 7.22 |
| CO | 61.08 |
| CH ₄ | 0.01 |
| H ₂ S | - |
| COS | 0.09 |
| HCN | 26 PPMV |
| H ₂ O | <u>0.11</u> |
| | 100.00 |
| Temperature, °F | 160 |
| Pressure, psig | 35 |
| HHV, Btu/SCF | 289.5 |

The design heat duty of the medium Btu gas delivered from the gasification battery limits to the users is 20.58 billion Btu/day (HHV basis). The cold gas efficiency is 66.7% based on the following definition:

$$\text{Cold Gas Efficiency, \%} = \frac{(\text{HHV of Product Gas at } 60^{\circ}\text{F at GKT battery limits})}{(\text{HHV of A.R. Coal Feed})} \times 100$$

1.4

COAL RECEIVING AND HANDLING

Complete coal handling facilities are provided for receiving and storing coal delivered by rail and transferring the coal to the plant. Two trains are provided for coal unloading, and one train for stacking, reclaiming and conveying equipment. A process flow

diagram for the Coal Receiving and Handling Unit (Unit 10) is shown in Figure 1-2. Although the receiving and handling facilities are designed for Pittsburgh No. 8, the storage and conveying facilities are capable of handling other eastern bituminous coals selected as possible candidates.

Coal Receiving

Washed coal is delivered to the plant by unit trains consisting of seventy 100-ton bottom dump cars (or their equivalent). The design coal has a nominal size of 2-inches x 0-inches, weighs 50 pounds per cubic foot, and has an angle of repose of 38 degrees. Allowance is made, however, for accepting reasonable variations in these parameters.

Coal is received at two parallel track unloading hoppers. An enclosure is provided over each hopper, incorporating thaw shed and a manually operated car shaker to assist in unloading wet or frozen coal. Dust suppression and collection systems are provided to control the fugitive dust emissions generated by the unloading operation (Unit 15).

Each unloading hopper with a capacity of 100 tons has manually operated shutoff gate and four vibrating feeders. The vibrating feeders discharge to the two parallel unloading conveyors, each 48 inches wide. Coal unloading from the unit train is completed in two days, based on one shift (8 hours) per day.

Conveying to Storage, Weighing, and Sampling

The hooded coal unloading transfer conveyor is 48 inches wide and has a capacity of 1000 TPH. It conveys coal from the hopper unloading conveyors to a live storage pile (10,000 tons) via a lowering well (stacking tube).

As the conveyor leaves the unloading hopper tunnel, at a point just above grade elevation, a self-contained weigh scale is provided. The weigh scale is capable of determining flow rate and total integrated accumulated flow, and has provisions for periodic calibration.

The unloading transfer conveyor head pulley is located in the sampling system enclosure. A magnetic separator is provided to remove tramp iron from the coal stream. The rejects are chuted outside of the sampling enclosure to a tote box at grade. Periodic truck removal of tramp iron is made.

A sampling system is installed to collect coal samples for laboratory analysis and coal supplier's use. The system enclosure is ventilated, and dust suppression and collection systems are also installed (Unit 15).

Coal Storage

The coal is stored as a long pile, which is capable of storing 66,000 tons of coal. The coal storage area is sized for approximately 60 day supply of coal. About 10,000 tons of coal or 10 days supply is placed in "live storage". The live storage pile is formed by a lowering well at one end of the pile, fed by the transfer conveyor.

Underneath the live pile are three reclaim hoppers, from which a belt conveyor of 200 TPH capacity and 30 inches wide conveys the coal to the two coal storage silos. Each storage silo is 25 feet diameter and has a live capacity of 600 tons. The top of each silo is at an elevation of approximately 123 feet above grade. The bottom of each silo has a power operated shutoff gate and a vibrating feeder with a variable capacity up to 50 TPH. The vibrating feeders discharge directly into the pulverizer assemblies.

The "dead storage" section of the pile (56,000 tons) is formed by moving the coal with a bulldozer. This coal is used only in case of supply interruptions. The pile is compacted and sprayed with an organic polymer crusting agent to minimize both dusting and rain erosion problems. The entire coal pile is diked and lined with a clay base to prevent seepage. Contaminated rainfall runoff is collected in a lined settling pond. Settled particles are periodically removed and sent back to the coal pile. The water from the pond is pumped to a waste treatment facility and neutralized before being discharged to the river.

1.5 COAL PREPARATION AND CONVEYING

In the coal preparation unit the bunker coal or a mixture of the bunker coal and recycled fly ash sludge cake (50 percent moisture from the GKT coal gasification plant) is dried and pulverized to the following GKT gasifier feed requirements:

- o Size - 90 percent through 170 mesh and 70 percent through 200 mesh
- o Moisture content - One percent

Pneumatic conveyors transport the dried and pulverized coal from the pulverized coal storage bin to the gasifier service bins. Compressed nitrogen from the air separation plant is used as the conveying medium.

It should be noted that the fly ash has a high carbon content and the recycle approach is selected for a higher carbon utilization. For the design coal (Pittsburgh No. 8) 50 percent of the filter cake recovered in the GKT gasification plant is recycled. However, depending upon the coal being processed, overall moisture removal and heat duty required in the pulverizer, the recycle rate can be varied. The equipment is designed to provide this flexibility. More discussion of the recycle of the filter cake and its effect on overall carbon utilization is given in Appendix B.

The complete system as shown in Figure 1-2 is designed to provide maximum in safety, reliability, and flexibility. Each train is designed to process 25 tph (600 TPD) of pulverized coal/filter cake mixture (dry basis).

The coal preparation unit consists of two 50 percent roller mills, and two 50-percent trains of associated ancilliary equipment such as bag collector, recycle fan and air heater. The pulverized coal conveying unit has two trains, each consisting of a storage silo, pneumatic pump and a conveying line feeding to the gasifier service bins.

The roller mills are designed to process coal with a Hardgrove Grindability Index of 50, and a maximum moisture content of 12.0 percent. Provisions are made to recycle up to 50 percent of the fly ash cake from the GKT unit with the base coal. For higher ash coals a smaller recycle percentage is recommended. For the design coal (4.6 percent moisture) with 50 percent filter cake recycle, the heating load required for the pulverizer heater is about 20.5 MM Btu/hr. For a 12 percent moisture raw coal feed the heating load increases to about 34.4 MM Btu/hr. A small portion of the clean product gas from the gasification unit will be utilized in a heater for producing the hot air for the pulverizers.

Each mill and its associated equipment, with the exception of the bag collector, are designed for 50 psig in accordance with the NFPA code. The bag type dust collector is suitably equipped with an explosion door which reseals - to prevent the infiltration of ambient air into the system after relieving. In addition, partial recirculation of gases from the clean side of the collector back to the roller mill further increases the safety and reliability of the pulverizing circuit. This recycle loop, containing less than 0.02 grains of particulate per actual cubic foot, insures a sufficiently low oxygen content in the system gases, which minimizes the hazardous nature of the finely pulverized coal. Each baghouse is sized for 36,000 ACFM and has an air/cloth ratio of 4.5/1.0.

Pulverized coal from each baghouse goes to a 15-ton capacity pulverized coal storage bin, which is 10 feet in diameter. The top of the bin is at an elevation of approximately 28 feet above grade. The bottom of the bin has rotary air lock and discharges directly into the pneumatic pump inlet hopper. Compressed nitrogen (98 percent purity) at 35 psig is supplied from the air separation plant. The coal is conveyed via a carbon steel conveying pipe to the gasifier service bins through a 4-way splitter.

1.6 GKT COAL GASIFICATION AND WASH WATER TREATMENT

For the production of medium-Btu gas from coal, GKT's entrained bed coal gasification process has been selected for the PWG plant. Coal dust pulverized and conditioned to 70 percent through 200 mesh size and one percent water content from the Coal Preparation and Conveying Unit is processed through the gasifier and partially oxidized under exothermic conditions at pressures slightly above atmospheric. Process flow diagrams for the GKT Unit (Unit 30) are shown in Figures 1-3 and 1-4. The GKT Wash Water Treatment Unit (Unit 72) is shown in Figure 1-5.

To produce approximately 20 billion Btu per day of medium Btu gas from a typical bituminous coal, two four-headed GKT gasifiers are required. As feedstock to the gasifier, in principle, any kind of coal can be used. The efficiency, however, defined by the overall carbon conversion and the output of useful gas (carbon monoxide plus hydrogen) is to a certain degree dependent on the type and quality of the feedstock. For the PGW plant, a typical Pittsburgh No. 8 coal has been used as the design coal for the plant design. Enough flexibility, however, has been added to the gasification plant design to accommodate a variety of eastern bituminous coals.

The material balance for the GKT plant is shown in Table 1-2. The gasification plant is designed to handle 1200 tpd as-received coal (2 in. by 0 in.). Raw coal is dried and ground to the required size

TABLE 1-2 (Cont'd)


| STREAM NO. | 7 | 8 | 9 | 10 | 11 | 12 |
|---|---|---|--------------------------------|---|---|-------------------------------------|
| STREAM DESCRIPTION | L.P. STEAM GENERATION FM GASIFIER NO. 1 | H.P. STEAM GENERATION FM GASIFIER NO. 1 | QUENCH WATER TO GASIFIER NO. 1 | PURGING/BLANKETING NITROGEN TO GASIFIER NO. 1 | EMERGENCY SHUTDOWN NITROGEN TO GASIFIER NO. 1 | PRODUCT GAS FM RAN GAS BLOWER NO. 1 |
| TOTAL FLOW, LB/HR | 54,953 | 55,546 | 23,320 | 5,495 | 32,970 | 89,897 |
| VAPOR FLOW, SCFH | - | - | - | 1,241 | 7,446 | 26,391 |
| LIQUID FLOW, GPM | - | - | 46.6 | - | - | - |
| VAPOR MOLECULAR | - | - | - | 28 | 28 | 21.54 |
| TEMPERATURE OF PRESSURE, PSIG (IN W.C.) | 274 | 453 | 70 | 100 | 100 | 95 |
| | 28 | 925 | 40 | 10 | 15 | 1.5 (42) |
| COMPONENTS | LB/HR | LB/HR | LB/HR | LB/HR | LB/HR | LB/HR MOLE % |
| S | - | - | - | - | - | - |
| C | - | - | - | - | - | - |
| H ₂ | - | - | - | - | - | 2,278 27.29 |
| O ₂ | - | - | - | - | - | - |
| N ₂ | - | - | - | - | - | 1,075 0.92 |
| Ar | - | - | - | - | - | 930 0.57 |
| CO ₂ | - | - | - | - | - | 11,679 6.36 |
| CO | - | - | - | - | - | 68,490 58.61 |
| CH ₄ | - | - | - | - | - | 7 0.01 |
| H ₂ S | - | - | - | - | - | 1,208 0.85 |
| CS ₂ | - | - | - | - | - | 226 0.09 |
| H ₂ O | 54,953 | 55,546 | 23,320 | - | - | 8 75 PFRV |
| STRETFORD SOLN. | - | - | - | - | - | 3,976 5.30 |
| ASH | - | - | - | - | - | - |
| SLAG | - | - | - | - | - | - |
| TOTAL | 54,953 | 55,546 | 23,320 | 5,495 | 32,970 | 89,897 100.00 |


TABLE 1-2(Cont'd)

| STREAM NO. | 13 | 14 | 15 | 16 | 17 | 18 |
|--|---------------|----------------|-----------|-----------|------------|--|
| PRODUCT GAS FM RAW GAS FLOWER NO. 2 | 89,897 | 179,794 | 2,090,143 | 2,088,407 | NORMALLY 0 | EXCESS WASH WATER TO DISPOSAL |
| TOTAL FLOW, LB/HR | 26,391 | 52,781 | 4,182 | 4,178 | | 5,470 |
| VAPOUR FLOW, SCFH | 21.54 | 21.54 | | | | 10.9 |
| LIQUID FLOW, GPM | | | | | | |
| TEMPERATURE, °F | 95 | 95 | 158 | 113 | | 158 |
| TEMPERATURE, °C (IN. W.C.) | 1.5 (42) | 0.8 (22) | 10 | 100 | | |
| WASH WATER FM GKT WASH COOLERS - TRAINS 1 & 2 | | | | | | |
| WASH WATER RETURN TO GKT WASH COOLERS - TRAINS 1 & 2 | | | | | | |
| WASH WATER MAKE-UP TO SETTLING BASINS | | | | | | |
| WASH WATER EXCESS TO DISPOSAL | | | | | | |
| PRODUCT GAS FM GKT UNIT- TRAIN 1 & 2 | 179,794 | 179,794 | 2,090,143 | 2,088,407 | 0 | 5,470 |
| PRODUCT GAS FM GKT UNIT- TRAIN 1 & 2 | 52,781 | 52,781 | 4,182 | 4,178 | | |
| PRODUCT GAS FM GKT UNIT- TRAIN 1 & 2 | 21.54 | 21.54 | | | | |
| TEMPERATURE, °F | 95 | 95 | 158 | 113 | | 158 |
| TEMPERATURE, °C (IN. W.C.) | 1.5 (42) | 0.8 (22) | 10 | 100 | | |
| COMPONENTS | LB/HR MOLE % | LB/HR MOLE % | LB/HR | LB/HR | LB/HR | LB/HR |
| S | | | | | | |
| C | | | | | | |
| H ₂ | 2,278 | 27.29 | | | | |
| O ₂ | | | | | | |
| N ₂ | 1,075 | 0.92 | 4,556 | | | |
| Ar | 950 | 0.57 | 2,150 | | | |
| CO ₂ | 11,679 | 6.36 | 1,900 | | | |
| CO | 68,490 | 58.61 | 23,358 | | | |
| CH ₄ | 7 | 0.01 | 136,980 | | | |
| H ₂ S | 1,208 | 0.85 | 13 | | | |
| COS | 226 | 0.09 | 2,417 | | | |
| H ₂ O | 8 | 75 PPMV | 431 | | | |
| ASH | 3,976 | 5.30 | 17 | | | |
| SLAG | | | 7,952 | | | |
| TOTAL | 89,897 100.00 | 179,794 100.00 | 2,090,143 | 2,088,407 | 0 | 5,470 |

TABLE 1-2(Cont'd)

| STREAM NO. | 19 | 20 | | |
|--------------------------|--|-------------------------------|--------|--------|
| | FLY ASH SLUDGE TO ROTARY FILTERS | FLY ASH SLUDGE TO DISPOSAL | | |
| TOTAL FLOW, LB/HR | 56,816 | 28,750 (345 TPD) | | |
| VAPOR FLOW, SCFH | - | - | | |
| LIQUID FLOW, GPH | - | - | | |
| VAPOR MOLECULAR | - | - | | |
| TEMPERATURE, OF | 70 | 70 | | |
| PRESSURE, PSIG (IN W.G.) | - | - | | |
| COMPONENTS | LB/HR | WT % | LB/HR | WT % |
| S | - | - | - | - |
| C | 8,721 | 15.35 | 8,892 | 30.93 |
| H ₂ | - | - | - | - |
| O ₂ | - | - | - | - |
| N ₂ | - | - | - | - |
| Ar | - | - | - | - |
| CO ₂ | - | - | - | - |
| CO | - | - | - | - |
| CH ₄ | - | - | - | - |
| H ₂ S | - | - | - | - |
| CS ₂ | - | - | - | - |
| HCl | - | - | - | - |
| H ₂ O | 42,612 | 75.00 | 14,375 | 50.00 |
| STEELFORD SOLN. | - | - | - | - |
| ASH | 5,483 | 9.65 | 5,483 | 19.07 |
| GLAG | - | - | - | - |
| TOTAL | 56,816 | 100.00 | 28,750 | 100.00 |





NOTE:
1. ONE WASH WATER TREATMENT TRAIN REQUIRED PER TWO G&T GASIFICATION TRAINS

FIGURE 1-5

| REV | DATE | BY | CHKD | APP | DATE |
|---|------|--------------|-----------|-------|------|
| REVISIONS | | | | | |
| CONSTRUCTION | | | | | |
| PRELIMINARY NOT FOR CONSTRUCTION | | | | | |
| BIDDING PURPOSES | | | | | |
| | | | | | |
| DATE | | RELEASED FOR | | ENGR. | |
| PHILADELPHIA GAS WORKS COAL GASIFICATION PLANT PHILADELPHIA, PA | | | | | |
| PROCESS FLOW DIAGRAM G&T WASH WATER TREATMENT | | | | | |
| UNIT 72 | | | | | |
| GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA | | | | | |
| ENGINEERING INTERFACES | | | | | |
| SCALE | DATE | BY | CHKD | APP | DATE |
| NONE | 08 | 8276 | C-671-006 | A | |
| DRAWING NUMBER | | | | | |

| REV | DATE | BY | CHKD | APP | DATE |
|-----------|------|-----|------|-----|------|
| REVISIONS | | | | | |
| 9-4-81 | | | | | |
| UPDATED | A | ALA | | | |

in the Coal Preparation Unit. Pulverized coal is then pneumatically transported from the Coal Preparation Unit to the GKT gasifier trains via conveying nitrogen supplied from the Air Separation Unit. The pulverized coal is routed via a flow splitter to service bins within the GKT battery limits. The conveying nitrogen is vented to the atmosphere through filters at the service bins. Pulverized coal flows by gravity from the service bins to the feed bins. Four service bins and four feed bins are provided for each gasifier. The service bins and feed bins provide a guaranteed supply of coal to the gasifiers in the event of an upstream emergency shut-down. The service and feed bins provide a total of approximately 15 minutes of storage for the gasifiers at design usage rates.

Controls regulate the intermittent feeding of coal from the service bins to the feed bins which are connected to twin variable-speed coal screw feeders. Four double coal screw feeders are provided per gasifier to supply pulverized coal to each burner head. The pulverized coal is continuously discharged from the twin screws into mixing nozzles where it is entrained in oxygen and low pressure steam. For each gasifier 48,230 lb/hr (579 TPD) of Pittsburgh No. 8 coal react with 47,455 lb/hr (569.5 TPD) of oxygen and 4422 lb/hr of steam for the production of 10 billion Btu per day of medium Btu gas (lower heating value basis). The mixture is then delivered through twin blow pipes to each burner head. Moderate temperature and high burner velocity prevents the reaction of coal and oxygen until they enter the gasification zone.

Oxygen/steam mixers are provided to insure complete mixing before injection into the blow pipes. Two oxygen/steam mixers are provided per gasifier. The normal oxygen/ coal ratio for a typical Pittsburgh No. 8 coal is 0.98 lb/lb and the normal steam/coal ratio is 0.09 lb/lb. The oxygen required for the partial oxidation reaction is provided at 98 vol. percent purity from an air separation plant. Approximately 54,950 lb/hr of low pressure steam at 28 psig is generated from each gasifier jacket.

In the gasifier, the coal dust is oxidized by oxygen in presence of steam. Under the process conditions prevailing in the gasifier, carbon and hydrocarbons contained in the coal are converted to carbon monoxide, hydrogen, and carbon dioxide. Besides these components, sulfur compounds in accordance with the sulfur content of the feedstock, and nitrogen resulting from the impurity of the oxygen and the feedstock, are contained in the generated gas. Traces of methane, not exceeding 0.01 percent by volume, are also produced. However, no hydrocarbons, phenols, aromatics, or any other organic compounds are generated in the GKT gasification process.

The gasification reaction (partial oxidation) of the coal is carried out in two four-headed gasifiers, each of which is connected to a waste heat recovery system for generation of high pressure steam (925 psig). The gasifier itself is a double-shell reactor, lined with refractory, and generates low-pressure steam (28 psig) within its shell. Endothermic reactions, occurring in the gasifier between carbon and steam, and radiation to the refractory walls substantially reduce the flame temperature from 3500°F to 2700°F.

Ash in the coal feed is liquified in the gasifier high temperature zone. Approximately 30 percent of the ash is dropped out of the gasifier as molten slag and is quenched and collected in a water seal type slag quench tank and recovery system at the bottom of the gasifier. The recovered granular slag is transported from the bottom of the slag recovery system, via a slag extractor (drag chain conveyor), where the slag is dewatered and delivered to a belt conveyor. Belt conveyors, in turn, deliver the slag to an on-site storage area prior to disposal.

The remainder of the ash and the unreacted carbon are entrained in the gas exiting the gasifier. Water sprays quench the gas to reduce the temperature below the ash fusion temperature to prevent slag particules from adhering to the tubes of the waste heat boiler mounted over the gasifier.

The raw gas from the gasifier passes through the waste heat boiler where 55,550 lb/hr of high pressure, saturated steam (925 psig) is generated per gasifier. After leaving the waste heat boiler, the gas at 600°F is cleaned and cooled in a gas clean-up system. The system consists of a cooling washer which removes the largest particulates and cools the gas to 100°F, followed by a "disintegrator" type scrubber which reduces the particulate content of the gas to approximately 0.004 grains per standard cubic feet.

To reduce the water droplets carried with the raw gas, a separator is linked downstream to the disintegrator by which the majority of the water is recovered. The collected water is recycled to the cooling washer. After leaving the separator, the gas passes through a second separator for final treatment and is routed to the raw gas blower which feeds a gas holder and an electrostatic precipitator. The gas blower pressurizes the raw product gas to a delivery pressure at the GKT Gasification Unit battery limits (downstream of electrostatic precipitator) to approximately 22 inches of water.

Downstream of the raw gas blowers the two gasification trains join together to form a single train. The combined pressurized raw product gas passes into a single gas holder. The capacity of the gas holder is approximately 1.117 MMSCF of raw product gas. The gas holder provides approximately 20 minutes of storage capacity at the design usage rate in the event of a short term upstream gasification system failure. The gas holder also helps to smooth out the product gas user demand fluctuations. From the gas holder the gas is discharged to an electrostatic precipitator which removes the remaining fine particles before the gas enters the Desulfurization Unit for final clean-up.

Particulate-laden water from the GKT gas cleaning and cooling system is channeled to settling basins in the GKT Wash Water Treatment Unit (Unit 72). A portion of the fly ash carried over from the gasifier will be collected at the fly ash sump and pumped as slurry to the

waste water treatment settling basins. The major portion of the particles, however, are channeled with the circulating waste water which, after leaving the wash cooler, flows to settling basins for particulate removal.

In the Wash Water Treatment Unit, two 33 ft by 197 ft settling basins are provided to separate the ash and carbon particles entrained in the wash water from the GKT Gasification Unit. The settling basins are designed with adequate residence time to allow the settling of particles to the bottom of the settling basins, from which they are pushed by scrapers to a collecting sump adjacent to the settling basins. The ash slurry from the collection sump is pumped to a thickener. From the underflow of the thickener, a slurry pump transports the ash sludge to rotary vacuum filters for water removal. Two rotary vacuum filters are provided to reduce the sludge water content to 50 percent.

The fly ash sludge from the rotary filters is transported to the ash storage area via belt conveyors for temporary on-site storage. For Pittsburgh No. 8 coal with an ash content of 7.83 percent this would result in an ash sludge production rate of 345 tpd at design capacity. To reduce the ash disposal problem the GKT gasification plant has been designed with the capability of recycling a maximum of 50 percent of the ash sludge to the pulverizers. (The recycled sludge cake is transported to the pulverizers in the Coal Preparation Unit via belt conveyors). The sludge, at 50 percent recycle, contains approximately 26 percent unused carbon and will increase the gasifier carbon conversion from 88.0 to 93.6 percent while reducing the raw coal feed by 6 percent. The mixed feed would contain approximately 11.5 percent moisture compared to 4.6 percent for the Pittsburgh No. 8 fresh feed coal. The pulverizer and the pulverizer air heater are sized to handle the ash recycle operation.

During start-up of the gasifiers, the off-spec product gas will be routed to start-up flares provided within the GKT battery limits. A start-up flare is provided for each GKT gasifier train. Product gas is diverted upstream of the raw gas blowers to each flare. The start-up of a gasifier from ambient to design conditions takes a maximum of ten hours. Restart of the gasifier after a short shut-down period (about one hour), however, takes only 30 minutes.

A single GKT gasifier can be turned down to approximately 70% of its full load capacity within a few minutes. The product gas output from the two-gasifier GKT plant can therefore be adjusted in the range of 35-100 percent.

1.7 SULFUR REMOVAL AND RECOVERY

The sulfur removal and recovery system consists of two units. The first unit consists of a Stretford desulfurization plant (Unit 42) which removes H_2S present in the raw gas by converting it to recoverable elemental sulfur. The Stretford plant generates a purge liquor stream containing insoluble Na_2SO_4 , $Na_2S_2O_3$, and $NaSCN$ salts. The purge stream has a high COD value and is decomposed in the second unit, the Nittetu reductive incineration plant (Unit 44). Part of the clean product gas from the Stretford plant is burned with substoichiometric air in the Nittetu plant to produce the hot reduced gas necessary for the decomposition of the salts. Sodium vanadate, a component of Stretford Solution, is recovered with caustic alkali in the Nittetu plant and is recycled to the Stretford plant. The decomposed gas produced in the Nittetu plant contains H_2S and is recycled to the Stretford plant to combine with the raw gas from GKT gasification plant for sulfur removal.

1.7.1 Stretford Desulfurization


The Stretford desulfurization process developed by the British Gas Board is a direct oxidation process. The Stretford Plant is

designed to remove 90 percent of the sulfur contained in the product gas produced from the gasification of Pittsburgh No. 8 coal, which contains 2.64 percent sulfur by weight (dry basis). The product gas from the GRT gasification plant contains 0.90 percent H₂S and 0.09 percent COS on a dry volume basis. The Stretford plant removes almost all H₂S. COS is not removed from the gas; however, when burned it will produce only 350 ppmv SO₂ or 0.60 lb. SO₂/10⁶ Btu heat input which is well below the 500 ppmv or 0.86 lb. SO₂/10⁶ Btu limit set by the City of Philadelphia.

The Stretford plant can be designed to produce either filter cake or molten sulfur. The selection depends on the plant capacity, environmental restrictions, by-product sulfur credit and the filter cake disposal costs. The molten sulfur configuration generates a purge liquor stream which requires either on-site treatment by reductive incineration or disposal by hauling it to a hazardous waste treatment facility. Again the selection between the two depends on the size of the plant and economics. An economic evaluation of the above options was performed (see Appendix C) and the results favored the selection of the molten sulfur option with on-site reductive incineration.

Process Chemistry

The Stretford solution is an aqueous mixture of anthraquinonedisulfonic acid (ADA), sodium metavanadate, and sodium carbonate. The removal of H₂S and its conversion to elemental sulfur are represented by the following idealized reactions:



where ADA(H₂) represents the reduced form of ADA. Ionized forms of the reactants in aqueous solution are usually involved. The sum of the foregoing reactions gives the overall reaction



In this sequence of reactions, the hydrosulfide reaction product is oxidized to free elemental sulfur by reduction of vanadium from the pentavalent to the quadrivalent oxidation state, and the reduced vanadium is reoxidized by reduction of ADA. Air is blown through the solution in the oxidizer vessel to reoxidize the reduced ADA. Although the rate of H₂S absorption increases with the alkalinity of the solution, pH values above 9.5 are unfavorable for conversion to elemental sulfur.

Process Description

For the design coal (2.64 percent S, dry basis) the Stratford plant capacity is 27.3 tpd sulfur. Equipment sizing for the process is governed by the total quantity of sulfur in the fuel gas from the GKT gasification plant. The present design conservatively assumes that all the sulfur present in the coal appears in the gas. However, in the actual operation, some sulfur is retained in the ash. This allows a margin for using a higher sulfur coal.

Figure 1-6 shows the process flow and Table 1-3 gives the material balance for the Stratford plant. The raw gas from the GKT gasification plant at 95°F and 15.5 psia, and the decomposed gas from the Nittetu plant at 120°F and 15.5 psia are combined and compressed in the blower. The combined gas is cooled and washed in static mixers with the oxidized Stratford solution. The gas and the solution from the static mixers discharge into the reaction vessel which is sized to allow sufficient residence time for the sulfur forming reaction mechanism to go to completion.

TABLE 1-3

FCM GASIFICATION PROJECT
STRETFORD PLANT PROCESS
MATERIAL AND ENERGY BALANCE

| STREAM NO. | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 | 11 | 12 | 13 |
|------------------------------|---------|--------|--------|-------|---------|---------|---------|---------|---------|---------|---------|---------|---------|
| Temp, °F | 95.0 | 120.0 | 135.0 | 105.2 | 101.0 | 105.2 | 105.2 | 105.2 | 91.0 | 304.1 | 105.2 | 105.2 | 105.2 |
| Press, psia | 15.5 | 15.5 | 44.7 | 124.7 | 20.5 | 46.7 | 16.2 | 16.7 | 14.7 | 35.86 | 14.7 | 14.7 | 14.7 |
| Total Flow, lbs/hr | 179794 | 7424 | 3540 | 3500 | 186069 | 6574634 | 186224 | 6583454 | 37974 | 37974 | 38542 | 31626 | 6578417 |
| Liquid, gpm | | 0.0594 | 6.1 | 6.17 | 10117 | 10.831 | | 10132 | | | | 47.49 | 10124 |
| Flowing, lbs/gal | | 8.25 | 9.67 | 9.45 | 694.83 | 10.831 | | 10.83 | | | | 11.10 | 10.83 |
| Vapor Flow, ACFB | 889.49 | 27.75 | | | 0.0744 | | 895.20 | | 151.3 | 84.28 | 157.12 | | |
| Flowing, lbs/ft ³ | 0.0561 | 0.0743 | | | 0.0744 | | 0.0578 | | 0.070 | 0.125 | 0.068 | | |
| Vapor Mol. Wt | 21.54 | 26.69 | | | 21.81 | | 21.60 | | 28.55 | 28.55 | 28.05 | | |
| AMA Soln (lbs/hr) | | | 3540 | 3500 | | 6574634 | | 6580669 | | | | 29347 | 6578417 |
| Sulfur (lbs/hr) | | | | | | | | 2279 | | | | 2279 | |
| CO ₂ | 530.87 | 60.84 | | | 591.71 | | 580.66 | | | | 11.05 | | |
| CO | 4892.16 | 23.99 | | | 4916.15 | | 4913.04 | | | | 3.11 | | |
| H ₂ | 2277.89 | 11.13 | | | 2289.02 | | 2287.61 | | | | 1.41 | | |
| H ₂ S | 70.95 | 4.02 | | | 47.97 | | | | | | | | |
| COS | 7.51 | | | | 7.51 | | | | | | | | |
| H ₂ N | 0.63 | | | | 0.63 | | | 0.40 | | | | | |
| H ₂ | 76.79 | 120.99 | | | 197.78 | | | | 1023.04 | 1023.04 | 1023.04 | | |
| Ar | 47.57 | | | | 47.57 | | | | | | | | |
| CH ₄ | 0.83 | | | | 0.83 | | | | | | | | |
| H ₂ O | 441.77 | 29.10 | 154.15 | 138.0 | 407.03 | 346995 | 586.26 | 347331 | 34.8 | 34.8 | 103.56 | 1547.74 | 347159 |
| Sulfur | | | | | | | | 71.22 | | | | 71.22 | |
| O ₂ | | | | | | | | | | | | | |
| H ₂ SB | | | 4.30 | | | | | | | | | | |
| TOTAL | 8346.97 | 250.07 | 158.45 | 138.0 | 8533.20 | 346995 | 8621.49 | 347418 | 1329.79 | 1329.79 | 1374.05 | 1618.66 | 347159 |

TABLE I-3 (Cont'd)

| STREAM NO. | 14 | 15 | 16 | 17 | 18 | 19 | 20 | 21 | 22 | 23 | 24 | 25 | 26 |
|-------------------------------|---------|---------|--------|-------|--------|--------|--------|-------|----------|---------|---------|-------|--------|
| Temp, °F | 105.2 | 105.2 | 105.2 | 86.0 | 105.2 | 280 | 280 | 280 | 105.2 | 105.2 | 95.4 | 86.0 | |
| Press, psia | 30.0 | 64.7 | 30.0 | 64.7 | 79.7 | 74.7 | 16.7 | 14.7 | 124.7 | 100.0 | 30.0 | 64.7 | |
| Total Flow, lbs/hr | 27118.3 | 31644.9 | 4507.7 | | 7450.7 | 7450.7 | 5171.7 | 2279 | 85271.74 | 1949040 | 1936210 | 12542 | |
| Liquid, gpm | 41.73 | 47.3 | 5.71 | 5.9 | 11.49 | 12.13 | | 2.55 | 13123 | 3000 | 2974 | 25.1 | |
| Flowing, lbs/gal | 10.83 | 11.1 | 13.15 | | 10.65 | 10.08 | | 14.9 | 10.83 | 10.83 | 10.85 | 8.33 | |
| Vapor Flow, ACFS | | | | | | | | | | | | | |
| Flowing, lbs/ft ³ | | | | | | | | | | | | | |
| Vapor Mol. Wt | | | | | | | | | | | | | |
| ADA Soln (lbs/hr) | 21778.3 | 29365.9 | 2207.3 | | 5171.7 | 5171.7 | 5171.7 | 2279 | | | | | 91160 |
| Sulfur (lbs/hr) | | | | | | | | | | | | | |
| CO ₂ | | | | | | | | | | | | | |
| CO | | | | | | | | | | | | | |
| H ₂ | | | | | | | | | | | | | |
| H ₂ S | | | | | | | | | | | | | |
| CO ₂ | | | | | | | | | | | | | |
| H ₂ | | | | | | | | | | | | | |
| Ar | | | | | | | | | | | | | |
| CH ₄ | | | | | | | | | | | | | |
| H ₂ O | 1431.24 | 1548.74 | 116.50 | 163.5 | 281.16 | 281.16 | 281.16 | 71.22 | 450063 | 102910 | 102197 | 696.8 | 2848.8 |
| Sulfur | | | | | | | | | | | | | |
| O ₂ | | | | | | | | | | | | | |
| N ₂ | | | | | | | | | | | | | |
| N ₂ H ₄ | | | | | | | | | | | | | |
| TOTAL | 1431.24 | 1619.96 | 187.72 | 163.5 | 352.38 | 352.38 | 281.16 | 71.22 | 450063 | 102910 | 102197 | 696.8 | 2848.8 |

The treated gas exits the top of the reaction vessel and enters the gas compression and dehydration units. The solution from the reaction zone in the reaction vessel flows to an oxidizer tank where an aerator disperses air supplied by the air blower. Sulfur slurry overflows from the oxidizer tank into the sulfur slurry tank by gravity. The oxidized solution is recycled from the pump tank to the static mixers. A cooling tower and circulating pump are provided with the pump tank to maintain the heat and water balance in the unit.

The sulfur slurry which flows to the slurry tank is agitated and, thus, deaerated. Slurry from the slurry tank is then pumped to a centrifuge. The recovered solution in the centrifuge goes back to the oxidizer tank and the 50 percent concentrated sulfur cake passes to the reslurry tank. The concentrated sulfur slurry is mixed with water to a 30 percent slurry, which is pumped to the sulfur melter by a reslurry pump. The sulfur melter consists of a steam-heated exchanger where the temperature of the slurry is raised above the melting point of the sulfur at a pressure sufficiently high to prevent the solution from boiling. Separation of the molten sulfur and the hot solution occurs in the sulfur separator due to large difference in specific gravity. The molten sulfur passes to the sulfur storage pit with the hot solution being returned to the reaction vessel. A chemical mix tank is required for preparing fresh Stretford solution and adding makeup chemicals.

A purge stream from the recirculating Stretford solution stream is sent to the Nittetu incineration plant.

1.7.2 Nittetu Incineration

The stretford plant purge liquor (containing sodium salts) has high COD value and cannot be biodegraded. The Nittetu reductive incineration process is designed to decompose the purge liquor under high temperature and reducing atmosphere in which accumulated inert

compounds such as Na_2SO_4 , $\text{Na}_2\text{S}_2\text{O}_3$ and NaSCN in the solution are converted to the active components Na_2CO_3 , NaHCO_3 and NaHS . Also, sodium vanadate is recovered with caustic alkali. Decomposed gas containing H_2S is recycled back to the Stretford plant.

The Nittetu process is shown in Figure 1-7, and Table 1-4 gives the material balance. The purge liquor from the Stretford process, containing about 70 percent water, is fed to an evaporator at the operating conditions of about 140°F and 100-200 mm Hg abs, where it is concentrated by use of decomposed gas as a heat source. Vaporized water from the evaporator is sent to a surface condenser, where it is condensed and recycled to the quench tank. The concentrated waste, with a total solid content of 40 to 45 wt percent, is fed to a furnace using spray nozzles. At the upper section of the furnace, a hot gas generator burns the product fuel-gas with substoichiometric air to produce hot reducing gas. In the furnace, water is vaporized from the waste liquor and the inactive salts are decomposed under the reducing atmosphere. These salts are in molten state. Some are carried over by hot decomposed gases and some flow along the refractory-lined wall to the quench tank located below the furnace. Here the gases are cooled quickly and the salts are collected and dissolved in the liquid. Hot decomposed gases are injected into the liquid through a downcomer tube and rise through an annular section between tube and weir where they are contacted intimately with water. The recovered solution is collected in the recovered solution tank and pumped back to the Stretford plant. The decomposed gas leaving the quench tank is first sent to the evaporator heat exchanger for heat recovery and finally to a gas cooler. The decomposed gas containing H_2S is sent back to the Stretford plant to be mixed with the raw gas from the GKT gasification plant.




TABLE 1-4

MATERIAL BALANCE FOR NITTETU INGENERATION PLANT

| <u>STREAM NUMBER</u> | <u>1</u> | <u>2</u> | <u>3</u> | <u>4</u> |
|------------------------------|---------------|---------------|---------------|--------------|
| Temperature, OF | 105 | 120 | 195 | 105.2 |
| Pressure, psia | 16.2 | 15.5 | 44.7 | 124.7 |
| Total Flow, lbs/hr | 1892 | 7424 | 3540 | 3500 |
| Liquid, gpm | - | .0594 | 6.1 | 6.17 |
| Flowing, lbs/gal | - | 8.25 | 9.67 | 9.45 |
| Vapor Flow, ACFS | 13.6 | 27.70 | - | - |
| Flowing, lbs/ft ³ | 0.0591 | 0.0743 | - | - |
| Vapor Mol. Wt. | 21.6 | 29.77 | - | - |
| ADA Solution, lb/hr | | | 3540 | 3500 |
| CO ₂ | 9.02 | 60.84 | - | - |
| CO | 76.33 | 23.99 | - | - |
| H ₂ | 35.53 | 11.13 | - | - |
| COS | 0.12 | - | - | - |
| N ₂ | 3.07 | 120.99 | - | - |
| Ar | 0.74 | - | - | - |
| CH ₄ | 0.01 | - | - | - |
| H ₂ O | 9.11 | 29.10 | 154.15 | 138.0 |
| H ₂ S | - | 4.02 | - | - |
| NaHS | - | - | 4.30 | - |
| TOTAL | 133.93 | 250.07 | 158.45 | 138.0 |

1.8

AIR SEPARATION

A 1200 TPD air separation plant is required to provide oxygen for the GKT Gasification Unit. The by-product nitrogen from the air separation plant is utilized for pneumatic conveying of pulverized coal from the coal preparation area to the gasification unit and for gasifier unit purging and blanketing.

The oxygen purity specified for the plant is 98 vol. percent with 2 percent inerts (mostly argon). The by-product nitrogen contains a maximum of 2 percent oxygen and is bone-dry. The required pressures for the oxygen and by-product nitrogen at the air separation plant battery limits are 1 psig and 40 psig, respectively. The oxygen product piped from the air separation plant is compressed to approximately 15 psig by a compressor within the GKT battery limits. The by-product nitrogen available at 40 psig from the air separation cold box will be adequate for the GKT gasification unit conveying and purging requirements.

The total normal nitrogen requirement for GKT gasification plant conveying and purging is shown below. The conveying nitrogen estimate is based on 7.0 lbs. of coal conveyed per lb of nitrogen. In addition to the normal nitrogen requirements, the nitrogen requirement for gasifier system emergency shutdown purging is also shown.

| | |
|----------------------------|---------------------------------|
| Conveying | 186,140 Scf/hr (35 psig) |
| Purging & Blanketing | <u>148,900 Scf/hr (25 psig)</u> |
| Total Normal | 335,040 Scf/hr |
| Emergency Shutdown Purging | 893,470 Scf/hr (15 psig) |

The air separation plant (Unit 50) is a turnkey facility. Engineering and design will be furnished by a contractor experienced in this field.


The basic process for separating oxygen from air is a distillation operation that takes place at low temperatures under moderate pressure in which air is reduced to the liquid state and the components are separated by fractionation. The cryogenic temperatures are achieved by special heat exchange equipment and expansion turbines that efficiently transfer heat and energy between feed and products to make the operation economically practical.

In a simplified form, the main process steps to produce oxygen and by-product nitrogen in an air separation plant include: air compression, water and carbon dioxide removal, cooling to liquid air temperature, gas expansion to produce refrigeration, separation of air by distillation, product heating by heat exchange with the incoming air, and compression of oxygen to the required pressure. Figure 1-8 depicts a typical low pressure cycle oxygen plant with liquid oxygen and nitrogen storage.

In the air separation plant the refrigeration process used to reach liquid air temperatures is regenerative. Warm process air entering the plant is cooled by the separated products as they leave in a reversing heat exchanger. The heat recovery is incomplete, however, so refrigeration must continuously be added.


Air also contains variable quantities of dust, water, carbon dioxide and hydrocarbons. These impurities must be removed from the system to insure a safe, efficient operation. In the process, dust is removed by a filter on the inlet of the main air compressors. The dust that goes by, along with other contaminants, is removed in a water wash tower.

For reliability and flexibility in turndown, two 50 percent air separation trains (600 tpd each) will be provided. In addition, there will be two main air compressors - one driven by an electric motor, the other by a steam turbine. Approximately 93,000 lb/hr of saturated steam at 925 psig is available for use by the air



• DU 1002-D





NOTES:
 LIQUID OXYGEN STORAGE TANK NO.1 PRESSURE IS 5 PSIG. LIQUID OXYGEN STORAGE TANK NO.2 PRESSURE IS 15 PSIG.

FIGURE 1-8

| REV | DATE | BY | APP'D | DATE |
|---|--------------------------|-------|-------|------|
| REVISIONS | | | | |
| CONSTRUCTION | | | | |
| PRELIMINARY NOT FOR CONSTRUCTION | | | | |
| BIDDING PURPOSES | | | | |
| DATE | RELEASED FOR | ENGR. | | |
| PHILADELPHIA GAS WORKS COAL GASIFICATION PLANT PHILADELPHIA, PA | | | | |
| PROCESS FLOW DIAGRAM AIR SEPARATION PLANT (UNIT 80) | | | | |
| GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS SEASIDE, PA | | | | |
| QUANTITY INTERFACES | | | | |
| DRAYING | CHILLED | | | |
| SCALE | NONE 08 8276 G-671-009 A | | | |
| P.A. | 088276-800 | | | |
| DRAWING NUMBER | | | | |

| REV | DATE | BY | APP'D | DATE |
|-----------|---------|----|-------|------|
| REVISIONS | | | | |
| UPDATED | 9-11-81 | A | JLE | |

compressor steam turbine. This is approximately 65 percent of the total compressor power requirement. The electric driven compressor is sized to provide 50 percent of the air compressor requirement.

Compressed air from the main air compressors enters the base of water wash tower and is cooled by a countercurrent direct contact with water sprayed into the top of the tower. The warmer water is returned to the cooling water system by process air pressure. Air leaves at the top of the tower at near ambient temperature and flows to the reversing heat exchangers.

Compressed process air is cooled to liquid air temperatures in reversing heat exchangers by the outgoing streams. During this process, contained water and carbon dioxide are frozen and deposited as solids inside the exchanger.

At regular intervals, the air and the waste nitrogen stream, which is the largest effluent stream, are interchanged. Both continue to flow in the same direction, across the same temperature gradient, but the passages through which they flow are switched. As a result, the water and carbon dioxide deposited by the air before reversal is evaporated completely and removed from the plant by waste nitrogen. Switching is accomplished by an automatic system of timers, warm-end reversing valves, and cold-end check valves.

Slightly superheated air leaves the reversing exchanger, enter the high pressure column and is separated into an oxygen rich liquid at the bottom, pure liquid nitrogen at the top, and impure liquid nitrogen part way up the column.

Pure nitrogen gas from the top of the high pressure column is condensed in the reboiler by boiling pure liquid oxygen in the low pressure column. The returning liquid nitrogen serves as reflux for the high pressure column.

Further down the high pressure column, impure liquid nitrogen is withdrawn and subcooled, part of it providing reflux for the low pressure column and part of it acting as a subcooling medium for liquid oxygen product in the product subcooler, if required. Waste nitrogen vapor is withdrawn from the top of the low pressure column.

Rich liquid oxygen is taken from the base of the high pressure column, subcooled via the waste nitrogen stream, purified in the rich liquid filter, and passed to the feed entry tray of the low pressure column.

Provisions for nitrogen drawn off the top of the high pressure column will be made in two places. First is the pure liquid nitrogen stream sent to a nitrogen flash separator where resulting liquid is sent to nitrogen storage. The flash from the separator is combined with the effluent gas of the turbo expander and sent through the reversing exchangers for recovery of its refrigeration, then on to product usage, otherwise it goes out as waste nitrogen through the silencer. The operator will control just how much liquid nitrogen is withdrawn, from the high pressure column.

The other stream, cold pure nitrogen gas, is sent to the reversing exchanger. Part of this gas is drawn off at the midpoint and sent to the expander. Expander exhaust along with the possible flash from the separator is sent back to the reversing exchanger as described above.

Final separation of oxygen takes place in the low pressure column. Provisions for liquid oxygen to be taken from the base of low pressure column, passed through liquid oxygen guard absorber, subcooled in product subcooler, and then sent to storage will be made. The subcooling medium would be impure nitrogen from the high pressure column.

Product oxygen gas is taken off just above the bottom of the low pressure column and sent through air liquefier exchanger, where it may be superheated by a slipstream of condensing air, and then to the reversing exchangers for the recovery of the rest of its refrigeration, and finally to delivery to the GKT Gasification Unit battery limits.

Liquid oxygen and nitrogen storage facilities are required to provide 24 hours of back-up product oxygen and nitrogen during an emergency shutdown. Since the oxygen plant is dual train and has the capability of operating one train on either steam or electricity, it is expected that a shutdown would only reduce oxygen production by 50 percent. For this reason, the liquid storage requirement is 50 percent of design capacity for 24 hours, i.e., 600 tons.

The liquid oxygen storage consists of a main 600 ton liquid oxygen storage tank at 5 psig and a 25 ton liquid oxygen tank at 15 psig. Two 100 percent liquid oxygen pumps are provided to pump liquid oxygen from the 600 ton tank to the 25 ton tank. A vaporizer at the discharge of the 25 ton tank vaporizes the liquid oxygen for delivery to the GKT battery limits. The minimum delivery pressure of gaseous oxygen to the GKT battery limits is 1 psig. This system will insure that fluctuation of the oxygen pressure does not occur in the event that response time of the air separation unit is slow relative to the oxygen demand rate of the gasifiers.

The liquid nitrogen storage system consists of a 275 ton storage tank at 40 psig and a vaporizer which provides the normal nitrogen required for conveying and purging in the event of an air separation plant shutdown. The storage system will be capable of supplying nitrogen gas at 40 psig at a design withdrawal rate of 6000 SCFM. For gasification system emergency shutdown purging, a high pressure nitrogen tube trailer (rental) is provided. The high pressure tube trailer will provide an instantaneous supply of nitrogen for

gasifier system purging. The tube trailer will be designed for a maximum withdrawal rate of 15,000 SCFM for 15 minutes, i.e. 225,000 SCF storage capacity.

1.9 PRODUCT GAS HANDLING

1.9.1 Gas Compression

The clean fuel gas from the Stretford plant is compressed to 40 psig and cooled to 100°F prior to dehydration and distribution. The product gas leaves the Stretford absorber at 105°F and 1.5 psig saturated with water vapor. The gas is compressed in a set of parallel compressors. The compressors are centrifugal machines with aftercoolers.

The compressors will be driven by condensing steam turbines using excess low pressure steam from the gasifier jackets. The steam is superheated prior to entering the turbines at 25 psig and 322°F (55°F superheat). There is sufficient steam to provide 100 percent of the compression duty. Because of the high specific volume of the steam, two turbines will be needed to handle the steam available. A third compressor driven by electric motor will provide 50 percent of the plant output and will be used for startup and standby duty.

The outlet gas from the compressor will be cooled in a shell and tube heat exchanger to 100°F with cooling water in order to condense as much water as possible. It is intended to minimize the load on the dehydration unit. The condensate from the compressor aftercoolers will be used as make-up to the plant main cooling tower.

1.9.2 Gas Dehydration

In the gas dehydration unit (Unit 64), excess water from the desulfurized and compressed gas (40 psig) is removed to meet the