

HIGH TEMPERATURE EXPANDER LIFE, HAS BEEN MAJOR UNCERTAINTY.

TURBINE EXPANDER LIFE AFFECTED BY:

QUANTITY OF BED EFFLUX

SIZE DISTRIBUTION

CHEMICAL COMPOSITION

PARTICLE HARDNESS & STICKINESS

HOT-GAS CLEANUP EFFICIENCY

MATERIALS OF CONSTRUCTION & TEMPERATURE

1000 HR PFB TURBINE CASCADE TESTS CONDUCTED ~1979

FACILITY


CASCADES

EXXON


GE

CURL


GE & STA LAVAL



STA-LAVAL CASCADE



(a)



(b)

GE CASCADE




Fig. 4. Exxon PFBC System Schematic.
 1 lb/s, 9000 ppm loading,
 $d_{50} = 20-25 \mu\text{m}$




Fig. 5. CURL PFBC System Schematic for Stream 1.
 2 lb/s, 11000 ppm loading, $d_{50} = 25-40 \mu\text{m}$

NOMINAL PFB CONDITIONS FOR 1000 HR CASCADE TESTS

<u>EXXON</u>	<u>CONDITION</u>	<u>CURL (GE)</u>
ILL#6	COAL	OHIO GLEN BROOK
PFIZER #1337	DOLOMITE	OHIO PLUM RUN
1700° -1770°F	BED TEMPERATURE	1560° -1585°F
10 ATMS	PRESSURE	5 ATMS
6 FT./SEC.	SUPERFICIAL FLUIDIZING VELOCITY	3 FT./SEC.
~1.8 SEC.	BED RESIDENCE TIME	~2.8 SEC.
3 CYCLONES	PARTICLE SEPARATORS	3 CYCLONES + SKIMMER
35-860 PPM	PARTICLE LOADING	~250 PPM
95% < 10 μm	PARTICLE SIZE	99.2% < 10 μm
1500° -1590°F	SPECIMEN TEMPERATURE	1350° -1475°F
900 FT./SEC.	MAXIMUM SPECIMEN INLET VELOCITY	1400 FT./SEC.

CASCADE TEST IMPACT

GE FINDINGS


EXXON CORROSION AND EROSION SIGNIFICANTLY HIGHER
DIFFERENCES DUE TO GAS/METAL TEMPERATURES
DEPOSITION NOT A PROBLEM
LONG TURBINE LIFE APPEARS POSSIBLE

STA-LAVAL FINDINGS

NO MEASURABLE EROSION OF BLADE MATERIAL
NO MEASURABLE SIGNIFICANT CORROSION ATTACK
MINIMAL DEPOSITION
ECONOMICAL TURBINE LIFE APPEARS POSSIBLE

AEP/STA-LAVAL BELIEVE PFB READY FOR DEMONSTRATION


170 MW TIDD PLANT PRELIMINARY DESIGN
15 MW_T CTF MALMO SWEDEN
FULL SCALE 1/36TH SLICE OF TIDD
3 STAGES OF PROPOSED CYCLONES
GAS TURBINE-NO LOAD UNIT
STEAM TO PLANT TURBINE
SHAKEDOWN STARTED FALL 82



AEP 170MW PFB DEMOPLANT (TIDD)

EXXON MINIPLANT

Particulate Concentration in Cyclone Gas Outlet



CATCRACKER-PFB CYCLE COMPARISON

CATCRACKER POWER RECOVERY EXPANDERS-4 ATM/1350°F

CATCRACKER ELUTRIATION RATES MUCH HIGHER

CATALYST HARDER AND MORE EROSIIVE

3 STAGES OF CYCLONES PROTECT EXPANDER

EXPANDERS COMMERCIALY GUARANTEED-120 PPM/.06 GR/SCF

AVERAGE TIME BETWEEN BLADING 35000 HRS (IR)

EXPANDER MATERIALS RESISTANT TO ALKALI ATTACK @ 1350-1400°F


LOW RISK PFB CYCLE

1650°F PFB

FREEBOARD COOLING TUBES

1400°F EXPANDER INLET

INGERSOL-RAND EXPANDER



CROSSSECTIONAL VIEW OF
INGERSOLL-RAND 2-STAGE EXPANDER

GILBERT/COMMONWEALTH ANALYSIS OF LOW RISK PFB CYCLES.

TABLE II
CYCLE PERFORMANCE SUMMARY

	Conventional Coal Fired Power Plant	Steam Cooled PFBC		Air Cooled PFBC
		Gas Turbine	Expander	Gas Turbine
Gross Power, MWe	533.8	446.7	506.6	501.9
Auxiliary Power, MWe	36.2	7.1	9.5	9.9
Net Power, MWe	497.6	439.6	497.1	492.0
Heat Rate, Btu/kWh	9665	8446	8979	8929
Plant Efficiency, %	35.3	40.4	38.0	38.2

TABLE III
CAPITAL COST SUMMARY
(Costs in millions of 1980 Dollars)

Description	Conventional Coal Fired Power Plant 498 MWe	Steam Cooled PFBC		Air Cooled PFBC
		Gas Turbine 439 MWe	Expander 497 MWe	Gas Turbine 492 MWe
Land & Land Rights	1.0	1.0	1.0	1.0
Structures & Improvements	28.5	21.6	25.5	23.5
Boiler Plant Equipment	161.3	111.0	133.8	212.6
Gas Turbine/Expander Gen.	-	22.0	31.3	65.8
Steam Turbine Generator Unit	56.7	42.6	50.4	34.5
Accessory Electrical Equipment	16.5	21.0	22.6	23.9
Misc. Power Plant Equipment	3.2	4.0	4.0	3.8
Station Equip./Transmission	6.0	6.0	6.0	6.4
Total Direct Cost	273.2	229.2	274.8	371.5
Indirect Costs	297.7	242.1	287.5	353.9
Total Capital Cost	570.9	471.3	562.3	725.4
\$/kW	1146	1074	1131	1474

TABLE IV
COST OF ELECTRICITY COMPARISON
(Costs in mills/kWh, 1980 Dollars)

Levelized Busbar Costs	Conventional Coal Fired Power Plant 498 MWe	Steam Cooled PFBC		Air Cooled PFBC
		Gas Turbine 439 MWe	Expander 497 MWe	Gas Turbine 492 MWe
Capital Cost	33.6	31.5	33.2	43.2
Fuel Cost	42.8	37.3	39.7	39.5
Fixed O&M	6.7	6.1	6.4	9.4
Variable O&M	5.3	8.0	8.3	5.6
Reliability Penalty	5.4	4.6	4.6	3.4
Total COE	93.7	87.5	92.2	101.1

BROWN BOVERI-EPRI STUDY

CYCLE	BED COOLANT	PRESSURE (ATM)	GAS TURBINE TEMP. (°F)	EFFICIENCY %	COMMENTS
A	WATER/ STEAM	10	1560	40.0	
B	WATER/ STEAM	5	1300	38.6	CAT CRACKER TYPE EXPANDER
C	AIR	7	1600	33.6	
E	WATER/ STEAM	10	770	38.0	SELF SUSTAINING

SELF SUSTAINING/TURBO CHARGED PFB HAS LOWEST CAPITAL COSTS AND
LOWEST RISK

MINIMUM HOT GAS VOLUMETRIC FLOW


HOT GAS PIPING AND CLEAN UP CONVENTIONAL

MINIMUM GAS TURBINE OVER SPEED PROTECTION


No HRSG

TURBO CHARGED PFB COE 10% LOWER THAN HIGH TEMPERATURE CYCLES

EPRI TO AWARD CONTRACT FOR MORE DETAILED STUDY




250 MW PFB STEAM GENERATOR




ELEVATION

250 MW PFB SUPERHEATER-REHEATER



36' OD-400 TON CATCRACKER REGENERATOR AB-291



125MW SHOP ASSEMBLED PFB BARGE SHIPMENT

GRIMETHORPE PFB

75 MW_T EXPERIMENTAL FACILITY-COMPLETED 1980

BED CONDITIONS

6'-7" SQUARE
6-12 ATM
1470-1750°F
8. FT/SEC. NOMINAL

TUBE BANK "A" - 858 HRS OPERATION OCT.-DEC. 81
1-1/4" OD ON 3-1/8" TP
11'-6" TALL (14 1/2% PACKING DENSITY)
6.7 FT/SEC.
240°F ΔT - BED HEIGHT 12.8 FT
ERATIC COAL FEED - ROTARY VALVES $\pm 27^\circ\text{F}$

TUBE BANK "C" - 469 HRS OPERATION JUNE-SEPT. 82
1-5/16" OD ON 3-1/8" Vx7" H
10'-6" TALL (6.3% PACKING DENSITY)
4.9-6.6 FT/SEC.
NO ΔT PROBLEM (15.4' BED DEPTH)
SEVERE EROSION BOTTOMMOST TUBES

CURL/LEATHERHEAD

COAL-WATER SLURRY TESTS SUCCESSFUL

25-35% WATER

99% COMBUSTION EFFICIENCY

87% SRE @ 1.8 CA/S AND 1 SEC.

30% WATER .7% CYCLE EFFICIENCY REDUCTION

20 ATM PFB TESTS

SLIGHT INCREASE IN COMBUSTION EFFICIENCY

SRE NOT SENSITIVE

NO_x EMISSION NOT SENSITIVE

RUN OF MINE COAL

98 TO 99-1/2% COMBUSTION EFFICIENCY

85% SRE @ 1.5 CA/S AND 1 SEC.

4% BED CARBON CONTENT

LARGE STONE ACCUMULATION



HOT GAS CLEANUP

AT THE PRESENT, CYCLONE SEPARATORS REPRESENT THE ONLY COMMERCIAL TECHNOLOGY FOR REMOVING PFB PARTICULATES.


ADVANCED DEVICES ARE UNDER DEVELOPMENT:

CERAMIC BAGHOUSE FILTERS
CERAMIC BLOCK FILTERS
ELECTROSTATIC PRECIPITATORS
ELECTRO CYCLONES
GRANULAR BED FILTERS

PRESENTATION ON
CURTISS-WRIGHT
PRESSURIZED FLUIDIZED BED PILOT PLANT



500 MW PFB - COMBINED CYCLE PLANT MODULAR ARRANGEMENT



AB-299

PFB-III-687A

**COMMERCIAL PLANT
NOMINAL PERFORMANCE**

Heat Rate 8600 BTU/KW HR
Coal Pile to Busbar Efficiency 40%

Modular Plant Design


- 3 Gas Turbine Modules 3 x 110 MW
Each Containing, 2 PFB, 2 GT,
1 Alternator
- 1 Steam Turbine 180 MW
510 MW

BENEFITS OF AIR HEATER FBC SYSTEMS

- FUEL FLEXIBILITY
- HIGHER PLANT EFFICIENCY
- REDUCED WATER REQUIREMENTS
- LOWER SO₂ AND NO_x EMISSIONS
- EASIER TO DISPOSE ASH
- LOWER CAPITAL COST
- LOWER COST OF ELECTRICITY
- MODULAR SYSTEM
 - SHORTER CONSTRUCTION CYCLE
 - HIGHER AVAILABILITY
 - OPERATING FLEXIBILITY
- WIDER APPLICATIONS
 - BASE AND INTERMEDIATE
 - PEAKING
 - COGENERATION

PFB-III-639A


COMBINED CYCLE POWER PLANT SIMPLIFIED FLOW DIAGRAM




PFB-I-554C

TECHNOLOGY SUPPORT TESTS

TECHNOLOGY UNIT



SMALL GAS TURBINE RIG DISTRIBUTOR AND HEAT EXCHANGER ASSEMBLY



AB-309

PFB-I-555

HEAT EXCHANGER TUBES BEING INSERTED IN PFB COMBUSTOR




AB-310

PFB-III-640

PFB HEAT EXCHANGER TUBE MATERIALS SUMMARY OF RESULTS


2000 HOUR EXPOSURE OF COUPONS IN SGT/PFB COMBUSTOR

ALLOY




PFB-111-346D



ROVER STATOR AND ROTOR AFTER COMPLETION
OF THE 1000 HOUR TEST



PHOTOMICROGRAPH OF Fe Cr Al-Y COATING ON ROVER VANE
After 1000 Hour Test






PFB COMBINED CYCLE EMISSION SUMMARY



PFD-111-645

HOT GAS CLEANUP SYSTEMS



GENERAL ELECTRIC

RESEARCH COTTRELL

ACUREX

PFB-P-57

TEST PLANT ACCOMPLISHMENTS

- Over 3500 Hours of Coal Fired PFB Operation
- Over 1300 Hours of PFB/Gas Turbine Operation
- Verified Design Parameters/Material Selections
- Demonstrated High Combustion Efficiency (>99%)
- Demonstrated High Sulfur Capture (>95%, <0.3 lb/mm Btu)
- Demonstrated Low NO_x Production (<0.2 lb/mm Btu)
- Demonstrated Acceptability of Heat Exchanger Materials
- Developed Reliable Coal/Dolomite Feed Systems
- Developed Adequate Hot Gas Cleanup System for Turbine Protection

PFB-III-603

PFB PILOT PLANT




PFB PILOT PLANT DESIGN POINT


EQUIVALENT ELECTRIC POWER FROM G.T.	7150 KW
EQUIVALENT ELECTRIC POWER FROM STEAM	6470 KW
EQUIVALENT HEAT RATE	8725 BTU/KW/HR
COAL FLOW	10,240 PPH
AIRFLOW	120 PPS
STEAM GENERATED AT 175 PSIG	58,000 PPH

PFB-II-384B

WOOD-RIDGE FACILITY
CURTISS-WRIGHT CORPORATION




**C-W TOTAL ENERGY SYSTEM
(OVERALL VIEW)**



PFB-1-537

PFB AND CONTROL BUILDING STEEL STRUCTURE - LOOKING WEST



AB-322

PFB-III-821

PFB COMBUSTION PROCESS COMPONENTS





Figure 2.34


PFB COMBUSTOR VESSEL AND LOWER HEAD



CIRCUMFERENTIAL SEAM WELDING


PFB-III-567A

PFB PILOT PLANT COMBUSTOR




PFB-III-822

AB-325



PFB COMBUSTOR WINDBOX AND HEAT EXCHANGER SUPPORT


PFB-III-823



PFB PILOT PLANT HEAT EXCHANGER TUBE ASSEMBLIES

PFB-III-819

PFB PILOT PLANT COMBUSTOR AIR EXCHANGE HOUSING




PFB-III-826


AB-328

ALTERNATIVE CONCEPTS FOR AIR COOLED PFB

FLOW DIAGRAM OF COMPRESSED AIR ENERGY STORAGE (CAES)
WITH COAL FIRED PFB



PFB AIR HEATER DESIGN WITH SUPPLEMENTARY FIRING



CURTIS WRIGHT CORP.

SUPPLEMENTARY FIRED AIR CYCLE PFB

Supplementary Firing

	C-W Commercial PFB Plant	Current Turbine Cooling	Supplementary Firing		Combined Cycle Repowering
			HTT	HTT	
Turbine Inlet °F	1594 (mixed)				
Clean Turbine		2200	2750		2066
Dirty Turbine		1450	1650		1450
Mw/Module	85.1	213.9	236.7		181
Airflow/Module lb/sec	696	1074	1023		1061
Thermal η (HHV)	39.1	44.3	48.0		39.5
Heat Rate (HHV)	8728	7703	7110		8640
MM BTU Fuel/Hr					
Coal	743	1147	724		984
Oil	-	495	957		530
*Fuel Cost Mills/Kwhr	17.81	20.51	22.94		23.18
Bed Dia/Bed Height Ft	30.75/16	38.2/16	28/24		34.4/18.5

*Coal @ \$2.04/MM Btu; Oil @ \$4.13/MM Btu

APPENDIX AB-9-3

PRESSURIZED FLUIDIZED COAL COMBUSTION PROGRAM

AT NEW YORK UNIVERSITY

Presented At


Coal Combustion and Applications Working Group

December 9, 1982

Livingston, New Jersey

by

DR. VICTOR ZAKKAY



THE WORK REPORTED HEREIN WAS SUPPORTED BY
THE DEPARTMENT OF ENERGY UNDER CONTRACT
NO. DE-AS21-80MC-14322

NEW YORK UNIVERSITY
FACULTY OF ARTS AND SCIENCE
DEPARTMENT OF APPLIED SCIENCE

AB-334

A D V A N T A G E S O F P . F . B . C .

- 1) SUPERIOR ENVIRONMENTAL PERFORMANCE - REMOVE SO₂ AS A DRY SOLID
- 2) ELIMINATING THE NECESSITY FOR ADD-ON SULFUR REMOVAL UNITS
- 3) REDUCED EMISSIONS OF OXIDES OF NITROGEN (NO_x) - LOWER OPERATING TEMPERATURES
- 4) SUBSTANTIAL IMPROVEMENT IN THE HEAT TRANSFER FILM COEFFICIENT (AS MUCH AS 20 TIMES THAT OF EXISTING COAL COMBUSTIONS)
- 5) INCREASED SYSTEM EFFICIENCIES BY INCORPORATING A GAS TURBINE TO RECOVER ENERGY FROM THE PRESSURIZED PRODUCTS OF COMBUSTION
 - A) WATER/STEAM - COOLED TUBES IN BED
 - B) AIR-COOLED TUBES IN BED
 - C) NO IN-BED TUBES, WITH ALL HEAT REMOVAL BY AIR BLOWER THROUGH THE BED
- 6) WIDE RANGE OF FUELS POSSIBLE, COAL OF ALL RANKS

M A J O R P . F . B . C . F A C I L I T I E S

POWER GENERATING UNITS

	<u>CURTISS-WRIGHT CORPORATION</u>	<u>AEP STAL LAVAL</u>	<u>GRIMETHORPE</u>
BED CROSS SECTION	12' DIA	3' x 6.5' TOP 3' x 3' BOTTOM	6' x 6' SQUARE
BED HEIGHT, FT	7	13	16
BED TEMPERATURE, °F	1650	1560	1560
BED PRESSURE, ATA	6.8	16	10
FLUIDIZATION VELOCITY, FT/S	2.7	3	8.2
POWER OUTPUT	13 MW _E	15 MW _{TH}	80 MW _{TH}

R & D UNITS

	<u>NYU</u>	<u>CURTISS-WRIGHT CORPORATION</u>	<u>GENERAL ELECTRIC</u>	<u>LEATHERHEAD</u>
BED CROSS SECTION	3' DIA	3' DIA	1' DIA	1' DIA
BED HEIGHT, FT	10'	16	5.2	8
BED TEMPERATURE, °F	1600	1650	1400-1750	1650
BED PRESSURE, ATA	7-10	6.8	10	20
FLUIDIZATION VELOCITY, FT/S	4	2.7	3	3
POWER INPUT, MW _{TH}	3.2	2.2	0.5	1.0

SULFUR RETENTION AND CALCINATION

- A) CALCINATION PROCESS IN P. F. B. C.
- B) EFFECT OF PRESSURE ON CALCINATION PROCESS, WITH REGARD TO:
 - 1) LIMESTONE (CA CO₃)
 - 2) DOLOMITE (CA CO₃ Mg CO₃)
- C) EFFECT OF TEMPERATURE
- D) EFFECT OF PARTICLE DIAMETER
- E) EFFECT OF EXCESS AIR

COAL ANALYSIS

<u>ULTIMATE ANALYSIS</u>	<u>BITUMINOUS COAL</u>		<u>LIGNITE</u>	
	<u>DRY BASIS %</u>	<u>WET BASIS %</u>	<u>DRY BASIS %</u>	<u>WET BASIS %</u>
Carbon	75.72	73.44	63.51	41.05
Hydrogen	5.50	5.34	3.26	6.03
Nitrogen	1.50	1.46	3.85	0.55
Sulphur	3.22	3.12	1.49	0.97
Oxygen	6.29	6.10	18.60	8.00
Chlorine	0.09	0.087	--	--
Ash	7.68	7.45	12.30	8.00
Moisture	--	3.00	---	35.40
Heating Value	13,800 Btu/lb		10,417 Btu/lb	

SORBENT ANALYSIS

	<u>DOLOMITE</u>	<u>LIMESTONE</u>
Calcium Carbonate	54.60%	94.04%
Magnesium Carbonate	44.70%	1.46%
Silicon Dioxide	0.40%	1.16%
Aluminum Oxide	0.35%	0.24%
Iron Oxide	0.05%	--
Moisture	--	3.00%

FUTURE PROGRAMS AT NYU IN PRESSURIZED FLUIDIZED BED COMBUSTION

- 1) TESTS WITH LIGNITE AND LIGNITE WATER SLURRY
- 2) TESTS WITH EROSION IN EROSION OF HEAT EXCHANGER TUBES
IN SUPPORT OF THE GRIMETHORPE PROJECT
- 3) ELECTROSTATIC GRANULAR BED TESTS - JOINT PROJECT
WITH GENERAL ELECTRIC
- 4) ADVANCED MODULAR CELLS PFBC CONCEPT
- 5 GAS TURBINE STUDIES TO PROVIDE ADDITIONAL SUPPORT.
FOR NYU FACILITY

TECHNICAL UNCERTAINTIES

- 1) HOT GAS CLEANUP/TURBINE PERFORMANCE
 - A) TURBINE EROSION
 - B) TURBINE DEPOSITION
 - C) PRESENCE OF ALKALI METALS, AND SULFUR OXIDES
- 2) MATERIAL PROBLEM FOR RELIABILITY IN BED TUBE EROSION
- 3) SULFUR RETENTION AT HIGH PRESSURE
- 4) FEED WITH RUN OF THE MINE COAL





FIGURE III.1 NYU-DOE PRESSURIZED FLUIDIZED BED COMBUSTOR FACILITY






FIGURE 5-2. EGB-PFB FILTER INTEGRATION




Figure 2-3. Schematic of EGB Filter Element




Figure 2-1. Pressurized Fluidized Bed Powerplant Schematic





EXHIBIT II-1

NYU's ADVANCED MODULAR-CELL PFBC CONCEPT

GAS PREHEAT SYSTEM - (Scheme)




- PGV - PILOT GAS VALVE
- PGR - PILOT GAS REGULATOR
- PGS - PILOT GAS SOLENOID
- PAGR - PILOT AIR/GAS REGULATOR
- PM - PILOT MIKER
- PAV, PAR, PAS - AS ABOVE - (AIR SIDE)
- MGO - METERING GAS ORIFICE
- LOV - LIMITING ORIFICE VALVE
- SGV - SOLENOID GAS VALVE
- AGR - AIR/GAS REGULATOR
- MRGV - MAIN GAS PRESSURE RESET
- LGPS - LOW GAS PRESSURE SWITCH
- MRGV - MANUAL RESET GAS VALVE
- MACV - MANUAL AIR CONTACT VALVE
- CAV - COMBUSTION AIR VALVE

DRAWN: SC

FIGURE III.4 GAS PREHEAT SYSTEM

KEROSENE INJECTION SYSTEM - (Scheme)



- F - FILTER
- U - UNION
- N.V. - NEEDLE VALVE
- P - PRESSURE GAUGE
- Ch.V. - CHECK VALVE
- B.V. - BALL VALVE
- PRV - PRES. REL. VALVE
- 2WSV - 2 WAY SOL. VALVE
- 3WSV - 3 WAY SOL. VALVE

DRAWN: SC

FIGURE III.5 KEROSENE PREHEAT SYSTEM





FIGURE III.6 HEAT EXCHANGER BUNDLE





FIGURE III.7 HEAT EXCHANGER LOCATION
AB-350





FIGURE III.10 DISTRIBUTOR PLATE, TOP AND BOTTOM VIEWS

AB-351





FIGURE III.12 SORBENT FEED SYSTEM


GOALS OF THE BATTELLE MSFB PROGRAM

- **ENABLE EXPANDED USE OF SOLID FUELS OF ALL TYPES**
- **DEVELOP HIGH PERFORMANCE COMBUSTION SYSTEM TO MEET CURRENT AND PROJECTED EMISSION STANDARDS**
- **PROVIDE A TECHNICAL BASIS FOR SYSTEM DESIGN**
- **COMMERCIALIZE THROUGH LICENSES**


BATTELLE MULTISOLID FLUIDIZED BED COMBUSTOR



BATTELLE MULTISOLID FLUIDIZED BED COMBUSTOR




MSFB-0.4 PILOT PLANT (0.4 x 10⁶ BTU/HR)



DM POWERS

SOLIDS RESIDENCE TIME TESTS



FUELS TESTED IN MSFBC

- COAL
- KRAFT LIQUOR
- WOOD WASTE
- MUNICIPAL WASTE
- SEWAGE SLUDGE
- DELAYED COKE
- FLUID COKE
- CHAR
- ROCK CONTAINING BITUMEN


AB-358




Development Corporation

VARIETY
APPL.

SULFUR CAPTURE IN MSFBC—EFFECT OF ENTRAINED BED RECYCLE (R)





PRIMARY AIR/STOICHIOMETRIC AIR RATIO

FIGURE 7. EFFECT OF PRIMARY AIR ON NITROGEN OXIDES EMISSION (COAL)

1/15/76
CONTROL

ALI F. 4
JAPAN

RES THE
AT TEMP.
OV

EFFECT OF STAGED COMBUSTION ON NO_x AND SO₂ EMISSIONS (DELAYED COKE)

	<u>MSFB-0.4</u>	<u>MSFB-1</u>
Total Air/Stoi- chiometric Air	1.14	1.28
Primary Air/ Stoichiometric Air	0.51	0.76
NO _x , ppm*	100	76
Ca/S Ratio	2.9	3.2
SO ₂ , ppm*	91	82
CO, ppm*	412	162

*Corrected to 18% excess air.



Development Corporation

ACT. C
D.C.
F.C.

ENTER
LINE
LARGER
UNIT

AB-362

COMBUSTION EFFICIENCY IN MSFBC: EFFECT OF FUEL REACTIVITY

Carbon Utilization*

Fuel	MSFB-1	MSFB-0.4
Coal	99	97
Delayed Coke	97	96
Fluid Coke	95	91

*Without ash recycle.





Development Corporation

SUMMARY OF KEY TECHNICAL FEATURES

FEATURE	BENEFIT
INCREASED SOLIDS RESIDENCE TIME	HIGH UTILIZATION OF FUEL AND SORBENT
TURBULENT MIXING	FEWER FEED POINTS; SCALE-UP CONFIDENCE
MINIMUM TREATMENT OF LARGE SIZE FUEL	USE AVAILABLE/LOW COST FUELS
FUEL FLEXIBILITY	USE AVAILABLE/LOW COST FUELS
LIMESTONE FLEXIBILITY	MINIMIZE SUPPLY AND DISPOSAL COSTS
ENVIRONMENTAL CAPABILITY	COMPLY WITH STRINGENT EMISSIONS REGULATIONS
DESIGN FLEXIBILITY	OPTIMIZE COMBUSTION, SORPTION AND HEAT EXCHANGE; GOOD LOAD RESPONSE

MSFBC SIMPLIFIED PROCESS FLOW DIAGRAM FOR STEAM FLOOD GENERATOR





AB-365

PERFORMANCE HIGHLIGHTS OF CONOCO MSFB STEAM GENERATOR

- STARTUP, JANUARY, 1982
- BURN AS-RECEIVED 2" X 0 COAL AND PETROLEUM COKE
LIMESTONE 1/8" X 0
- OVERBED FUEL FEEDING THROUGH DROP PIPE
- 96 PERCENT SULFUR RETENTION AT Ca/S = 3.0
(SULFUR CONTENT OF COAL = 1.50%, COKE = 7.08%)
- CARBON BURNUP > 97%
- BOILER EFFICIENCY, 84.4%
- NO_x AND CO EMISSIONS < 100 PPMV
- 55 DAYS OF CONTINUOUS OPERATION IN LAST TEST RUN



MSFB LICENSES, AND NEGOTIATIONS UNDER WAY

STRUTHERS WELLS

- ENHANCED OIL RECOVERY—EXCLUSIVE WORLDWIDE
- PROCESS HEATERS (NONSTEAM)—NONEXCLUSIVE WORLDWIDE
- INDUSTRIAL AND PROCESS STEAM BOILERS—NONEXCLUSIVE FOR EUROPE, AFRICA, USSR, INDIA, AND NORTH/SOUTH/CENTRAL AMERICA [FOR PETROLEUM FUELS ONLY]
- AIR HEATING FOR GAS TURBINE POWER GENERATION—EXCLUSIVE WORLDWIDE

FOSTER WHEELER POWER PRODUCTS (VK)

- INDUSTRIAL AND PROCESS STEAM BOILERS—EXCLUSIVE FOR EUROPE, AFRICA, INDIA, AND USSR WITH STRUTHERS WELLS EXCEPTION

RILEY STOKER

- INDUSTRIAL AND PROCESS STEAM BOILERS—EXCLUSIVE FOR NORTH/SOUTH/CENTRAL AMERICA WITH STRUTHERS WELLS EXCEPTION
- UTILITY STEAM BOILERS—EXCLUSIVE FOR NORTH/SOUTH/CENTRAL AMERICA

FOSTER WHEELER

Industrial Fluidized Bed Cogeneration System at the Shell Nederland Raffinaderij Europoort Tank Farm

W. R. Kelly
Manager

Contract Operations

J. M. Rourke
Project Manager

Contract Operations

S. R. Moore
Manager

Start-Up Operation

Foster Wheeler Boiler Corporation


In recent years development work and pilot plant studies into the concept of fluidized bed combustion have given way to ever larger and more ambitious commercial projects. The rapid movement of this technology from the laboratory into industrial application has been fueled by the two primary advantages of fluidized bed combustion: (a) the ability to burn low grade inexpensive fuel and (b) burn it in an environmentally acceptable manner.

In a major contribution to the commercialization of fluidized bed technology, Shell Nederland Raffinaderij (SNR) awarded a contract to Foster Wheeler (FW) for the design, fabrication and erection management of the world's first commercial cogeneration, coal-fired atmospheric fluidized bed boiler ca-

pable of generating superheated steam. The fluidized bed steam generator facility is located at the SNR's Europoort Tank Farm near Rotterdam in the Netherlands. It is designed as a cogeneration facility in which high pressure steam passes to a back-pressure turbine which generates 6.6 MW of electricity (refer to Figure 1). The 7 bar (103 psig) back-pressure steam is then fed to twin heat exchangers, which provide 37 MW of thermal heat energy via medium-pressure hot water to satisfy the heat demand of the tank farm.

This paper will describe the design of the steam generator and subsystems, as well as indicate where specific design features have been modified from previous units' designs to improve performance and reliability.

FIGURE 1 WATER AND STEAM CYCLE



Process Description

A fluidized bed is a mixture of granular limestone or other material supported by a nonsifting grid through which an upward flow of air passes that lifts and fluidizes the bed material. This results in a turbulent mixture of the bed particles, which assume the free flowing property of a liquid and provide an environment for stable combustion. When coal is introduced into this turbulent mixture and burned, the sulfur dioxide released by the burning coal is chemically captured by the limestone. This eliminates the need for an external flue-gas desulfurization system as used on conventional steam generators.

Since the fluidized bed operates at low combustion temperatures (about 850°C, 1560°F) the formation of nitrogen oxides (NO_x) is also held to a minimum. Another advantage of fluidized bed combustion is that boilers can be designed to tolerate and effectively burn a very broad range of fuel qualities, including low grade, high ash coals and solid or liquid waste materials.

Slagging, fouling and corrosion of steam generator surfaces is essentially eliminated because the fluidized bed operates at temperatures which are below the ash softening temperatures of coal fuels. Residue from the system is a dry, granular material suited for easy handling.

The SNR unit represents a considerable refinement of the basic concepts just described. In order to evaluate those refinements, a system-by-system review of the SNR unit is provided in the sequence listed below:

- 1) Steam Generator
- 2) Air and Gas System (including Gridplate Design)
- 3) Material Handling Systems
 - a) Coal Feed
 - b) Limestone Feed
 - c) Spent Bed and Inert Material Handling
 - d) Flyash Capture and Reinjection
- 4) Controls and Load Change Capability
- 5) Start-Up

The steam generator designed for the FBC Europoort project is a natural circulation, single drum, balanced draft design. At its maximum continuous firing rate the boiler is capable of producing 50 metric tons per hour (110,250 lb/hr) of superheated steam at 495°C (923°F) and 82 bar gage (1174 psig)

pressure. Steam generator efficiency of approximately 85% is predicted while maintaining a 90% sulfur dioxide capture rate. Additional information concerning design parameters is given in Table 1. Power consumption for the operation of accessory equipment is estimated at 1850 KW. The unit is top supported and consists of two adjacent fluidized bed combustion cells (refer to Figure 2).

Boiler feedwater enters at 145°C (293°F) through a bare tube economizer located within the boiler waterwalls as convection surface above Cell B. Water flows upward in two passes through horizontal tube runs in a counterflow arrangement with downflowing flue gas. This maximizes surface effectiveness and insures stable waterside flow. Water exiting the econ-

TABLE 1

STEAM FLOW	110,250 lb/hr (50 tonnes/hr)
STEAM PRESSURE	1174 psig (82 Bar)
STEAM TEMPERATURE	923°F (495°C)
FEEDWATER	293°F (145°C)
BED DIMENSIONS CELL A	8' x 16' 4" (2.44m x 4.99m)
BED DIMENSIONS CELL B	7' 6" x 16' 4" (2.29m x 4.99m)
BED HEIGHT (EXPANDED)	4' (1.22m)
BED TEMPERATURE	1650°F (899°C)
FLUIDIZING VELOCITY	9 ft/s (2.74 m/s)
FREEBOARD HEIGHT	15' (4.57m)
CALCIUM/SULFUR (MOLAR RATIO)	3
COAL FLOW	14,071 lb/hr (6381 Kg/hr)
DESIGN COAL	BITUMINOUS
HEATING VALUE	11,138 Btu/lb (25,810 KJ/Kg)
ASH	14.0% by wt.
MOISTURE	7.7% by wt.
VOLATILE MATTER	23.0% by wt.
FIXED CARBON	55.3% by wt.
SULFUR	0.50%
EFFICIENCY	84.9%

} Proximate
Analysis

FIGURE 2 BOILER PLANT GENERAL ARRANGEMENT





FIGURE 3 AIR AND FLUE GAS SYSTEM



omizer is transported to the steam drum to mix with water circulating through the steam generating circuitry.

Steam generating circuitry consists of vertical finned tube waterwalls (MONO-WALL[®]) construction which enclose the steam generator, a finned tube partition wall which separates Cell A from Cell B, a finned tube partition wall which separates Cell B from the convection pass above it, and sloped in-bed tubes in each cell. Water from the steam drum is supplied to inlet headers for each circuit using two downcomers and multiple feeders. The steam/water mixture leaving each heated circuit is returned to the steam drum through unheated risers. Flow is by natural circulation due to the difference in density between steam-free saturated water in the downcomers and feeders and the steam/water mixture in the heated tubes and unheated risers.

The steam collected in the drum is directed to the first stage primary superheater (PSH 1) located in bed A. Steam enters the lower header and passes upward through horizontal coils to the outlet header. Upflow circuitry permits the hottest tubes to be exposed above the fluidized bed during turndown conditions, thereby subjecting them to lower heat transfer rates and correspondingly lower metal temperatures. A high mass flow rate is maintained at full load to insure adequate cooling of the tubes during low load and start-up conditions. Steam leaving PSH 1 is transferred to the second stage primary superheater (PSH 2) located in bed B.

An emergency spray is located in the transfer line between the first and second stage primary superheaters. This spray station is normally not used, but is provided to protect the second stage primary superheater if required during upset operating transients.

Final superheat is obtained in the convection finishing superheater located above the freeboard in Cell A. Steam enters the upper header and flows downward through horizontal coils counterflow to the upflowing flue gas. The finishing superheater (and economizer) are divided into two banks to provide space for sootblowers (not installed) in the event they are required for some future alternate fuel.

Steam temperature at the finishing superheater outlet is controlled by spray attemperation in the transfer line between the second stage primary superheater and finishing super-

heater. Water for spray attemperation is taken from the discharge of the boiler feed pump.

Superheater sizing and location in the boiler represents an optimization for achieving a relatively flat temperature profile over the predicted operating range of 30% to 100% load while minimizing superheater spray requirements. Steam leaving the finishing superheater at 1174 psig enters a backpressure turbine/generator and is exhausted at about 100 psig. It then flows through heat exchangers to heat the circulating water used for oil tank heating. Condensate from the heat exchangers flows to the deaerator and back to the economizer and boiler via the boiler feedpumps. This arrangement provides an energy-efficient, closed-loop system.

Air & Gas System and Gridplate Design

Air enters this system through an inlet screen and venturi and feeds the forced draft fans which are equipped with inlet vane control and discharge isolation dampers (refer to Figure 3). Air from the FD fans is routed to a tubular air heater. An air heater air bypass is provided to control the average cold end temperature of the tubular air heater and to protect the baghouse from low gas temperatures during part-load operation. During start-up, all air is bypassed around the air heater to facilitate rapid warming of the baghouse.

Air leaving the tubular air heater and air heater air bypass recombines and then passes through parallel paths to Cell A and Cell B. Each path contains an air flow measurement device and air flow control damper. After leaving the control damper the air flow is again split to provide combustion air to each segment of each cell. The path leading to the first segment to be started in each cell contains an in-duct burner which is used during start-up to warm the unit and ignite the coal. The path leading to the other segment in each cell contains a shut-off damper. This arrangement of air inlet ducts provides a mechanically simple design requiring no high temperature dampers or special start-up ducts and dampers. It is designed to provide easy transfer from start-up to segmental fluidization and from segmental fluidization to full cell operation while maintaining air flow measurement to each cell during all operating modes.