

3.6 Piping & Electrical

3.6.1 Piping Systems; Approximate Flows & Conditions:

Cold Reheat Steam Supply to & from HRSG/Ft Martin

This line will carry 10,000 lb/hr 850-950psig/600-650°F superheated steam approximately 1,800 ft. to the GPIF for startup, or up to 90,000 lb/hr steam at 850-950psig/600-650°F to the Ft. Martin Unit No. 2's No. 7 feed-water heater. It shall be ground supported on pre-fabricated concrete supports (sunk below frost line) within easy reach from the ground (approximately 3 ft. above grade).

Condensate & Make-up Feed-water from Ft. Martin (Includes Rental Equipment System)

This line will carry up to 100,000 lb/hr (222 gpm) of 150-200 psig, 110-170°F, condensate approximately 1,000 ft. from Ft. Martin to the GPIF. It shall be ground supported on pre-fabricated concrete supports (sunk below frost line) within easy reach from the ground (approximately 3 ft. above grade) and anchored in shallow drilled pier foundations.

Cooling Water to Gasifier Vessel

This line will carry approximately 2,000 gpm of cooling water from the Ft. Martin cooling tower sump approximately 500 ft. to the PyGas™ gasifier vessel and then back to the cooling tower via a common circulating cooling water header. It shall be ground supported on pre-fabricated concrete supports (sunk below frost line) within easy reach from the ground (approximately 3 ft. above grade).

Cooling Water to Air Compressor Intercoolers

This line will carry cooling water from the Ft. Martin cooling tower sump approximately 500 ft. to the air compressor intercoolers and then back to the cooling tower via a common circulating cooling water header. It shall be ground supported on pre-fabricated concrete supports (sunk below frost line) within easy reach from the ground (approximately 3 ft. above grade) and anchored in shallow drilled pier foundations.

Process Water to Hot Gas Outlet Temperature Control

This line will carry 20 gpm of cooling water from the Ft. Martin service water interface approximately 1,200 ft. to the hot gas outlet from the PyGas™ gasifier via a process water line common to it and the wet oxidation system. It shall be ground supported on pre-fabricated concrete supports (sunk below frost line) within easy reach from the ground (approximately 3 ft. above grade) and anchored in shallow drilled pier foundations.

Process Water to Wet Oxidation System Makeup

This line will carry 2 gpm of makeup water from the Ft. Martin filtered process water interface approximately 1,200 ft. to the wet oxidation system from the PyGas™ gasifier via a process water line common to it and the hot gas outlet temperature control system. It shall be ground supported on pre-fabricated concrete supports (sunk below frost line) within easy reach from the ground (approximately 3 ft. above grade) and anchored in shallow drilled pier foundations.

Potable Water to Laboratory, Lavatory & Showers

A 1-inch PVC gravity fed at approximately 120 psig line will be tied into the existing Ft. Martin 3-inch PVC line such that 1-GPM can be bled during off-use

hours to a 5,000 gallon storage tank on the GPIF site for test facility use. It shall be ground supported on pre-fabricated concrete supports (sunk below frost line) within easy reach from the ground (approximately 3 ft. above grade) and anchored in shallow drilled pier foundations.

Fire Protection Around GPIF Facility

The primary firefighting water source will be from the existing two lagoons at the Ft. Martin site and shall be independent of the existing Ft. Martin firefighting water system. Lagoon water will be piped over the existing dikes to serve the GPIF's needs using horizontal shaft self-priming pumps with diesel backup.

A backup line will tie into the GPIF primary line and be tied into the existing Ft. Martin firefighting system at a point between their existing cooling tower and lagoon located approximately 200 ft from the GPIF. Up to 1,200 gpm at 85 psig is available from this source, however, the fire protection line should be sized to meet code requirements for the GPIF.

Rain Water & Spill Sump to Ft. Martin Water Treatment System

The stormwater holding sump located adjacent to the coal storage area will be provided with submersible solids handling capable, wastewater pumps. The pumps and forcemain will be sized for a maximum of 25 GPM, and shall carry the stormwater runoff to the Fort Martin wastewater treatment tank approximately 1200 feet away. The force main shall be routed below ground to the utility bridge. It will then be carried above ground, along the proposed utility sleepers as shown on the site plans to treatment.

Nitrogen Inerting to Air Compressor Intake

This line will convey low pressure nitrogen from storage tanks approximately 150 ft. to the air compressor intakes via a conditioning system for emergency system inerting.

Nitrogen from Tank Farm to Shaft Seals

This line will convey nitrogen to approximately 7 shaft seals all located at the PyGas™ gasifier within 150 ft. of the nitrogen tank farm.

Air Compressor to Dense Phase Pressurization Locks

This 4 inch diameter line will convey compressed air from the air compressor room to the vicinity of the gasifier.

Dense Phase Transfer to Pyrolyzer

This 4 inch diameter line will convey compressed air from the pressure locks to the pyrolyzer section of the PyGas™ gasifier.

HRSG to Pyrolyzer Steam Injection

This 1/2 inch diameter line will convey steam from the HRSG approximately 30 ft. to the pyrolyzer section of the PyGas™ gasifier.

Compressor to Gasifier Top Freeboard Compressed Air

This 4 inch diameter line will convey compressed air from the air compressor room approximately 50 ft. to the top of the PyGas™ gasifier.

HRSG to Gasifier Top Freeboard Steam

This 1/2 inch diameter line will convey steam from the HRSG approximately 30 ft. to the top of the PyGas™ gasifier.

Undergrate Compressed Air to Three Grate Zones

This 4 inch diameter line will convey compressed air from the air compressor room approximately 50 ft. to the under-grate section of the PyGas™ gasifier.

HRSG to Undergrate Steam to Three Grate Zones

This 3 inch diameter line will convey steam from the HRSG approximately 30 ft. to the undergrate section of the PyGas™ gasifier.

Hot Raw Coal Gas from Gasifier to HRSG

This 4-inch diameter line will convey hot raw low Btu coal gas at 600 psig/1400°F from the outlet of the PyGas™ gasifier approximately 40 ft. to the HRSG burner by way of the hot cyclone.

Hot Cyclone Solid Waste Dense Phase Transfer System

This 1-inch line will convey solid waste granules from the hot cyclone outlet hopper approximately 60 ft. to the ash silo.

HRSG to Gasifier Ash Depressurization Lock Hopper Steam Admission

This 1-incl line will allow 600 psig saturated steam admission to fill the ash depressurization lock from the HRSG approximately 40 ft. away.

Gasifier Ash Depressurization Lock Hopper Steam Vent to HRSG

This 1-incl line will allow 600 psig saturated steam to vent from the ash depressurization lock to the HRSG firing chamber approximately 40 ft. away.

Coal Crusher Vent Air to Filter

This 4-inch low pressure line (may even be round duct) vents dusty air in the vicinity of the coal crusher to its vent filter.

No. 2 Oil Main Line

This 3-inch line feeds light oil from the fuel oil main tie at the Ft. Martin interface point at Unit #2 approximately 1800 ft to the GPIF.

No. 2 Oil Coal Dryer

This 1-inch line feeds light oil from the fuel oil main tie at the GPIF approximately 100 ft from the fuel oil to the coal dryer burner.

No. 2 Oil Pyrolyzer Preheat

This 1-inch line feeds light oil from the fuel oil main tie at the GPIF approximately 100 ft to the pyrolyzer preheat burner located at the ash hopper level of the PyGas™ gasifier.

No. 2 Oil HRSG Ignitor & Support Flame

This 2-inch line feeds light oil from the fuel oil main tie at the GPIF approximately 80 ft to the HRSG burner.

Ash Silo Outlet Water Conditioning

This 1/2-inch line feeds the ash conditioning screw to minimize dusting under the ash silo from the filtered process water circulating header located approximately 50 ft. away.

Ash Silo Vent Air to Filter

This 4-inch low pressure line (may even be round duct) vents dusty air inside the ash silo to its vent filter located atop the silo.

Wet Oxidation System Slurry Transfer

This 3/4-inch low pressure line feeds filtered process water from the process water header located approximately 30 ft. away, to the wet oxidation system makeup tank.

Wet Oxidation System Vacuum Pump Vent to Atmosphere

This low pressure 3/4-inch vent line to atmosphere is approximately 20 ft. long and is located in the vicinity of the wet oxidation system on the third floor of the GPIF building.

HRSG Flue Gas Duct to Ft. Martin

This 42 inch diameter spiral wound duct will convey flue gas approximately 1,200 ft. from the fired HRSG outlet, via an induced draft booster fan, to the Ft. Martin Unit. No. 2 electrostatic precipitator inlet breeching. It shall be top of ground supported on pre-fabricated concrete supports within easy reach from the ground (approximately 3 ft. above grade), and protected by screen for personnel protection and insulated so as to maintain gas above dew point.

Instrument Dry Compressed Air

This 1/2-inch line is to provide dry compressed air from the compressor room dryers approximately 50 ft. to various instruments located in the vicinity of the PyGas™ coal gasifier reactor vessel.

HRSG Steam Sampling

This 1/4-inch line for HRSG steam sampling runs from the HRSG steam drum with a valved branch at the superheater outlet to the laboratory room located approximately 80 ft. away on the second floor.

CEM Sampling

This 1/4-inch line is located in the HRSG outlet flue gas line to the Ft. Martin Unit No. 2 electrostatic precipitator inlet breeching approximately 10-diameters downstream in a straight run of flue gas pipe (or round duct). The approximately length of line involved is 100 ft. from the sampling point in the flue gas duct to the GPIF laboratory room.

PyGas™ Reactor Products Sampling

This 1/4-inch line is located at several sampling points of the PyGas™ gasifier, and runs approximately 80 ft. to the GPIF laboratory room.

NH3 Monitor Sampling

This 1/4-inch line is located at several sampling points of the PyGas™ gasifier, and runs approximately 80 ft. to the GPIF laboratory room. It is similar but separate from the products sampling line.

3.6.2 Electrical System

General Requirements

Load Profile - New Gasification Plant

4160 V. Load

2.85 MVA.

Total Load

3.4 MVA.

Project Concept

The Project concept is to supply existing Fort Martin Generating Station with steam from the proposed gasification plant. This plant is to be a stand alone satellite facility to be located in the vicinity of the generating station. Utility scope of work ends at the 1200 amp 11.5 kV breaker inside the power station.

Codes and Standards

Except where noted, all electrical systems shall be designed, fabricated and installed in accordance with the latest edition of the National Electrical Code, and applicable ANSI, ICEA, NEMA, NESC, IEEE Standards as defined in the RFP (exceptions taken will be defined). Components that are UL listed and labeled shall be provided if required by local authorities.

Electrical Equipment

Selection and design of all electrical components and systems shall be in accordance with the applicable codes and standards. Reliability of operation shall be the primary consideration in the facility design. The Preliminary single line diagram will serve as a typical basis of supply (CRSS Drawing SK-E-001).

The electrical equipment shall include the following, located in the facility building:

MEDIUM VOLTAGE SWITCH GEAR HV-1
LOW VOLTAGE SWITCHGEAR LVSWG-1
1750 HP STARTER WYE DELTA
2 (400HP) COMPRESSOR WYE DELTA
1200A NON-SEGREGATED BUS
MCC-001-GPIF
STATION BATTERY AND CHARGERS
"UPS" UNINTERRUPTABLE POWER SUPPLY

15 kV Pole Line

A 15 kV pole line feeder with parallel overhead ACSR conductors will interconnect the GPIF with the existing facility's 11.5 kV breaker. This feeder line will be used to cold start the GPIF.

Plant's Primary Transformer

The plant's primary transformer "T1" will be 5 MVA, outdoor, oil filled, 11.5 kV delta to 4.16 kV resistance-grounded wye, standard impedance, equipped with special winding and cooling fans to permit temporary overloading and allow for future growth.

BUS DUCT.

The bus ducts shall be 5 kV, 1200 A, 3-phase, 3-wire plus ground, non-segregated phase type, rated to accommodate maximum design operating voltage. The rated momentary current will be based on the maximum three-phase fault current to which the bus can be subjected.

Coal Gasification Electric Power System (parasitic loads)

The electrical power system will perform the following functions:

Provide a reliable source of electrical power for plant auxiliaries during all operating conditions.

Provide rapid isolation of any faulted equipment without unnecessary loss of supply to other equipment.

Provide satisfactory motor starting and bus voltage regulation.

Medium Voltage Distribution Switchgear HVSWG-1
(4.16 KV, Vacuum Type, 350 MVA).

The circuit breaker and metering portions of the medium voltage switchgear will be a non-drawout, metal-clad, dead front, with each breaker cubicle isolated from the adjacent cubicle by a metal barrier. The interrupting ratings will be selected in accordance with ANSI Standard C37.010 making full allowances for asymmetrical symmetrical current ratios. Incoming breaker and internal bus continuous current ratings will be chosen to be greater than the maximum expected loading.

Medium Voltage Motor Controllers:

Motor controllers portion of the medium voltage switchgear will be of the draw-out full-voltage across-the-line or reduced vacuum type (as indicated on the single line diagram), rated a minimum of 400 MVA, double-stacked wherever possible.

The controller and the bus will be adequately rated for the voltage class, the continuous current and the available short circuit level.

The protective fuses will be ANSI Class "R" for motor starting duty, and class "E" for transformer feeder duty. Single-phase protection will be provided to open contactors whenever any fuse blows.

Overload, under-voltage, single-phasing and ground fault protection will be provided.

Control voltage will be 120 V AC.

Each controller will have an ammeter and an ammeter switch.

All motors shall have motor circuit protection.

The switchgear lineup will include provisions for future bus extension on one end.

Switchgear rooms will be mechanically cooled and pressurized with filtered air to prevent the entrance of dust and dirt. Switchgear rooms will have at least two exits to assure safe personnel egress.

Secondary Unit Substations.

The 480 volt systems will be 4-wire, 3-phase, wye connected, and solidly grounded at the transformer neutral.

Transformer "T2" shall be an indoor dry-type, cast-coil, standard impedance, rated 1000 kVA.

For ease of maintenance, the 480 volt switchgear will be located indoors in pressurized switchgear rooms or other clean areas. Cast-coil, dry type transformers will be used indoors.

Transformer cooling fans will be provided to allow for future load growth and permit temporary overloading. The unit substations will be physically arranged to allow future switchgear additions, and to allow for transformer removal and replacement.

Main circuit breakers will be fully-rated, manually-operated withdrawable, air-break, stored energy spring operated, dead-front type, complete with solid-state overcurrent and ground fault trip devices.

Bus shall be fully rated to supply a continuous load of 1600 A.

Loads supplied directly from unit substations will include motor control centers, and other 480 volt loads larger than 100 amperes.

Motor Control Centers and AC Distribution Panels.

MCC's will have NEMA Type 1A enclosures with gaskets on doors and filler plates, or NEMA Type 12 in Water Treatment Area. Locations will be chosen with care to avoid damp, dirty, or hot areas and to allow adequate front and rear access.

Motor control centers will utilize standard modules factory assembled in suitable shipping lengths.

Motor control centers will be rated 65,000 A.S.C. and have NEMA Class I, Type B wiring rated 600 volts for 480 volt service. The upper limit of motor size supplied from MCC starters will be 200 hp where application is continuous duty with infrequent starting. Larger motors may be controlled by MCC starters where the application involves intermittent duty. Dual mounted molded case circuit breaker feeder units will also be provided in MCC's to supply 480 volt unit-related loads that do not require remote control.

Bus shall be fully rated to supply a continuous load as shown on the drawings and specifications.

Each fully rated combination starter unit will be complete with a molded case circuit breaker having adjustable magnetic trips only, magnetic contactor, three bimetallic overloads, auxiliary contacts, control power transformer, and control wiring terminal block. Control power transformers will be adequately sized to power the motor starter as well as the auxiliary control devices. Starter controls will be 120 volt AC with a coil seal-in contact.

The breakers will have 65,000 A interrupting capacity adequate for the available short circuit current.

All motor starters will be of the same manufacturer to ensure interchangeability of parts and to minimize stocking of spare parts. In addition, circuit breaker distribution panels will be provided at selected locations, as required, to serve small loads.

A minimum of 20% fully equipped space shall be provided in the motor control center for future additions.

DC Battery Powered Systems (breaker control).

125 VDC battery system with an energy storage capacity of four (4) hour minimum will include a lead-calcium, solid state rectifier-battery chargers, and main DC distribution panels.

The battery capacities will be adequate to supply all associated loads for the required sequence, duration, and combinations that occur when each breaker unit must be operated with no other power sources available.

The battery nominal voltage, float voltage and end of discharge voltage will allow operation over a voltage range acceptable to standard NEMA equipment with only occasional need for recharging.

The battery chargers will be sized to supply those DC loads that exist continuously during normal unit operation while simultaneously recharging a fully discharged battery. The maximum battery recharge period will be 12 hours. Chargers must be capable of operation without the battery.

A circuit breaker DC distribution panel will be provided adjacent to the batteries to minimize the length and maximize the security of the battery feeder cables. The circuit breakers will have thermal-magnetic overload trips, except for circuits feeding emergency auxiliary motors, which will have magnetic trips only.

DC battery powered emergency lighting system shall be furnished similar to the above in all respects.

Grounding System.

In general, grounding system will be in accordance with the National Electrical Code and IEEE recommendations.

Instrument Grounding System.

A separate insulated grounding system will be provided for the computer and other noise sensitive electronic equipment. This will be a radial system, without loops and will be connected to the plant ground grid at one point only.

Instrument cable shields will be grounded at the load side only, leaving the sensor end ungrounded and insulated with the exception of thermocouples which are to be grounded at the instrument end.

Lightning Protection.

The lightning protection system will be designed in accordance with the National Fire Protection Association Lightning Protection Code (NFPA 78) Class I or Class II systems, UL96A, the National Electrical Code, IEEE Standards and the Lightning Protection Institute - Installation Code (LPI-175).

Electrical Heat Tracing.

Freeze protection and process heating systems will be provided for outdoor pipes, pumps, vessels and instrument sensing lines requiring process heating or freeze protection. The freeze protection system will automatically operate whenever the ambient falls below 40°F and will provide sufficient heat to prevent water freezing when the ambient temperature falls to 5°F less than the lowest ambient temperature recorded at the site. Control and monitoring systems for freeze protection will be centralized.

Lighting Systems.

Plant lighting will consist of normal lighting and self contained DC operated emergency lights.

Normal lighting will provide illumination during normal operating conditions.

Facility indoor lighting distribution will be three-phase, four-wire. A 480/277 volt system will be used. Facility outdoor lighting distribution will be 480 volt, three-phase, three-wire with phase-to-phase connected loads.

Indoor lighting circuits will be distributed through three-phase, four-wire lighting panels, which will be located centered to and near their respective loads to minimize voltage drops.

Distribution will be designed so that failure of any single lighting panel will not totally black out any floor or single large area.

Lighting equipment selection will be based on the requirements of specific areas. Incandescent, fluorescent, and high pressure sodium sources with appropriate luminaries will be used depending on the application and the needs of each location. High pressure sodium lighting will be used for outdoor installations.

Generally, the illumination levels for facility areas will be those recommended by the Illuminating Engineering Society.

Lighting circuits will be switched at their distribution panels. Rooms and small buildings will have light switches at each doorway. Outdoor lighting will be photoelectrically controlled with provisions for manual override.

Loop road lighting will be in accordance with recommendations of the National Illuminating Engineers Society. These fixtures shall be suspended from building structural walls or members.

Emergency AC and lighting system will be provided for purposes of personnel egress and continuation of critical activities during emergency conditions.

Design illumination levels for egress lighting will be those required by applicable Federal, state, or local fire codes.

Communication Systems.

Telephones will be provided in the control room, in the offices and electrical switchgear room.

A facility paging and two-party communication system, complete with amplifying equipment, handset stations and speakers will be provided.

UPS System.

UPS System shall be 30 KVA with two 200 A, 3 ph., 4W outputs plus isolated ground for process controls and system architecture power supplies, with 15 minute ride-through and lead-acid battery racks as required.

Emergency Process Equipment.

The compressed air, auxiliary boiler and gasifier jacket cooling water feed systems shall be capable of automatic switchover to the auxiliary DC power source in the event of AC power source failure for equipment protection against overheating.

Life Safety System (fire alarms).

The zone panel shall be stand alone and report to a central command station located in the Engineer's Office. Total number of zones shall be at least 8 active with four spares.

Fire Protection System.

The GPIF fire protection system shall be tied into the existing Ft Martin lagoon.

The existing 460 volt electric source from Fort Martin Generating Station shall be utilized to power a dedicated fire pump serving the GPIF area.

3.7 Provisions for Disposal of Fuel Gas

A GPIF on-site fired Heat Recovery Steam Generator (HRSG) shall be provided to both incinerate the coal gas produced during testing and to generate useful steam for Ft. Martin use from the available heat.

The HRSG will be provided with an "NFPA Class 1" continuous ignitor capable of providing steam for startup, and coal gas firing ignition stability, continuously if necessary.

The flue gas produced from the combustion of coal fuel gas and No. 2 oil (or natural gas) ignition support will then be boosted by an induced draft fan and ducted to the inlet of the existing Ft. Martin electrostatic precipitator.

3.8 Emissions Control System

Continuous Emission Monitoring System (CEM)

Emissions monitoring equipment will be provided on the HRSG flue gas outlet to measure CO, NO_x, and SO₂. These measurements are not required for Federal and State emissions requirements since the HRSG emissions are combined with the Ft. Martin Station flue gas prior to the Ft. Martin emissions monitoring equipment. These signals will be indicated on the DCS system for information and historical data collection. The system will not require certification.

3.9 Process Steam Characterization

The steam conditions required for transport back to Ft. Martin are 850-950psig/600-650°F superheated steam.

The process steam conditions required for injection into the GPIF gasifier are up to 10,000 lb/hr at only 650 psig/500°F.

Because of the apparent high cost of boiler feed make-up water to the HRSG, it may be more economical to install a second steam loop to produce a lower quality steam to be used exclusively as feed to the gasifier.

The Ft. Martin specifications for the GPIF return steam requires a maximum conductivity of 0.1 micromhos, a requirement for very high-pressure steam turbines normally resulting in expensive water treatment.

The process steam for the GPIF gasifier need not be that "clean" since it is only injected into the dirty gasification process.

The water treatment associated with making a lower grade steam is only a relatively inexpensive zeolite type water softener.

To effect such a dual steam conditions output, a secondary steam loop would be required, consisting of a small steam drum, feed pump, dearator, and associated controls. To properly evaluate these schemes, the additional capital cost of this additional equipment should be compared with the make-up condensate water cost from Ft. Martin during that Task 6 detailed design.

3.10 Process Control and Monitoring System

General

The Gasifier Product Improvement Facility will be equipped with a microprocessor based Distributed Control System for the primary control of the process from a central control room. The system will provide CRT based operator interface terminals for the data acquisition, monitoring, reporting, and control functions required to safely operate the process equipment. These terminals will be located in the operator control room. Various subsystems (such as the HRSG flame safety system) will be controlled by equipment vendor supplied Programmable Logic Controllers (PLC's) or other dedicated function control systems. These PLC controlled subsystems will have interfaces to the DCS so that the DCS is the operator's primary window of information to the process. Some startup and infrequent operations and monitoring will require attention local at the process. Field instrumentation and control devices will be installed to provide the information to the DCS/PLC's and to receive signals from the DCS/PLC's to regulate and control the process. This type control system provides flexibility for making control strategy modifications due to the programmable nature of the equipment.

Process Systems to be Controlled

1. Coal and Limestone Storage

The coal reclaim and storage and the limestone storage which consists of coal conveyors, storage bins, and dust collectors will have local controls independent of the DCS system. This will allow the limestone unloading and coal reclaiming to be operated by personnel at the equipment.

2. Coal and Limestone Feed System

The coal and limestone feed systems from the storage bins to the gasifier will be operated and controlled by the DCS. Any vendor supplied control subsystems will be integrated into the overall control system to the extent that the subsystem can be started and stopped from the DCS and the status indicated on the DCS.

3. Gasifier

The gasifier system including the air and steam flows to the gasifier and the cyclone will be controlled from the DCS. The flame safety system logic for the oil fired startup burner will be implemented in a PLC which will be interfaced to the DCS for the purpose of monitoring and controlling the safe firing of the oil. The gasifier system will include a gas analyzer to monitor the concentration of CO, CO₂, CH₄, and H₂.

4. Coal Gas Combustion in the HRSG

Regulatory control of the fuel flows, steam and water systems, and air and flue gas systems will be from the DCS. The coal gas and fuel oil burners are expected to be equipped with a vendor supplied PLC based flame safety system containing a

complete package of instruments, safety shutoff valves, flame scanners and other required control devices to comply with the NFPA requirements for coal fired burners. The flame safety system will be connected to the DCS via a digital interface or hardwired connections and will be controlled and monitored from the CRT operator stations. Interlocks and permissives between this system and the Ft. Martin utility boiler's flame safety system will be provided. These will be hardwired signals between the two systems. Remote indication of coal gas combustion and steam generation status will be provided by a DCS connected terminal to be located in the existing Fort Martin Station control room. The sootblowers on the HRSG will be controlled from an independent vendor supplied control system.

5. Air Compressor System

The air compressor will have a vendor supplied local control system for the control of the inlet valve, bypass valve, and the motors. Local monitoring and indication will also be provided. A single alarm contact will be wired to the DCS to indicate the presence of an alarm condition at the compressor.

6. Flare Stack System

It is anticipated that the flare stack will have a vendor supplied control package for controlling and monitoring the flare. Connections will be provided so that the DCS system will have the capability to start-stop the flare and monitor the status.

7. Deaerator and Boiler Feed Pump

The feedwater system including the deaerator and the feedwater pump will be controlled and monitored from the DCS.

8. Miscellaneous Distribution Systems

The fuel oil distribution system, compressed air distribution system, auxiliary water distribution system, steam distribution system, waste water distribution system, and the solids waste treatment system will all be operated and controlled from the DCS.

9. Nitrogen Vaporization System

The nitrogen system will have a vendor supplied local control system.

DCS System Description -- See Figure 16

The DCS will include dynamic controllers, I/O racks, communication devices, and operator stations. The operator stations will have color CRT's and keyboards which will be programmed with color graphic displays and operator functions.

The DCS controllers will be configured to implement the GPIF control strategies using the DCS vendor supplied algorithms. This configuration will reside in non-volatile or battery backed memory so that the configuration will be retained on a power failure. Redundancy will be provided for power supplies, controller files, and DCS communication data highways to minimize the effect of single component or module failures. If the primary control processor were to fail, the secondary




Figure 16
System Controls & Communications

processor operating in the hot standby mode would assume bumpless control of the process to keep the process under uninterrupted automatic control from the DCS system.

There will be communications to the PLC systems through digital serial interfaces to the DCS. This will allow selected operation and monitoring of the PLC controlled processes from the DCS.

The DCS will collect process information for trending displays on the operator stations and for historical data collection and storage.

A PC based display station will be connected to the DCS data highway and located in the Ft. Martin control room to provide information to the Ft. Martin personnel concerning the operating status of the GPIF.

An engineering function station will allow personnel to configure the operator consoles and the controllers. The software package will enable the engineer to design, configure, monitor, trend, tune, modify and document process activities. Graphic symbols and function codes will be used to build the control strategies on the screen. The engineering station will be used to initially implement the configuration, to de-bug and startup during the commissioning stage and to maintain, troubleshoot, and re-configure the system as required once the facility is operational.

The DCS will be field maintainable and configurable by the Owner's personnel after appropriate training.

The following DCS equipment/functions will be provided:

1. One operator station with two CRT's
2. One engineering station (PC based)
3. Historical Data Collection unit
4. One operator station (PC based) to be located in the Ft. Martin control room
5. Alarm and graphics printers with capability to print from operator or engineer station.
6. DCS rack cabinets containing controllers, power supplies, process I/O, and communication interfaces to the PLC's.

Our preliminary evaluation of the system control requirements indicates that the DCS should be able to support (approximately) the following quantity of I/O:

Table 28

Analog Inputs (TC's, RTD's, 4-20mA)	313
Analog Outputs (4-20 mA)	107
Digital Inputs	263
Digital Outputs	137

PLC System Description

Certain process equipment (such as the HRSG burners) will be supplied with PLC based controls. The various PLC systems will be connected to a common communication highway. A PC with programming software will be supplied for troubleshooting and maintaining the PLC programming. A printer will be supplied for printing the ladders and documentation.

Control Room Operator Panel

A control panel will be installed in the control room for equipment and functions that are not consistent with a DCS interface because of code requirements or accepted engineering practices. This will include hardwired safety trip functions (such as boiler trip buttons) and dedicated indications (such as HRSG drum level). The dedicated sootblower controls may be in this panel.

The DCS will be field maintainable and configurable by the owners personnel after appropriate training.

Conceptualized Scope of Work

- A. The Gasifier Product Improvement Facility will be equipped with microprocessor based Distributed Digital Control (DCS), Programmable Logic Controllers (PLC), and Instrumentation System. This type of equipment provides a high level of reliability and availability. Because of the experimental nature of this facility requiring higher visibility for operating and testing personal and multiple control strategies where the exact process characteristics are unclear or require special attention, certain added capacity is provided in Controllers, Process I/O, Data Storage and Reporting. The capability to easily make changes in control strategy and displays is enhanced by the separate engineers work station.

The DCS Communications (Data Highway) and controller power supplies will, because of their vulnerability, will be redundant.

The primary operating position will be in the central control room from the DCS Dual CRT/KB Operation Station. (See referenced diagram) The DCS will integrate the subsystem controls providing this common interface. A second position, which in normal operation is used by the testing personal, provides for an assistant to operate during start-ups, shutdown, and during process upsets. It also provides a back-up operator interface. A panel containing certain hardwired trip and safety functions will also be located in the Control Room. Some start-up and infrequent operations will require attention local to the process.

The process systems are controlled and/or interfaced by partitioning them into logical functional groupings which fit conveniently into each DCS Controller's capability. The system is divided into four (4) groups.

1. Coal and Limestone handling, compressed air and ash systems.
2. Dense phase injection, coal gasification, and flare ignition.
3. Coal gas clean-up system and utilities..

4. Heat recovery steam generator and steam, water and electrical distribution systems.

In addition to these major partitions certain control subsystems will be specified and furnished with process equipment. They will be interfaced to the appropriate DCS Controller by communication links or I/O wiring. There will be four (4) such subsystems:

1. Coal dense phase pressurization system.
2. Multi-stage process air compressor system
3. Gasifier starting burner management
4. HRSG support burner management

A DCS communications will be established with the Fort Martin Power Plant to provide certain signals specified by Fort Martin. A terminal will be provided to be placed in the Fort Martin Control Room on which certain configured displays may be invoked via a keyboard.

B. Control Room Operating Equipment:

1. Operator Station - Dual CRT with keyboard, trackball and alarm printer.
2. Test Operation Station - Same as Operator Station. (Start-up/back-up Operator Station).
3. Control Panel - Special instruments and safety trip functions hardwired.
4. Sequence of Event Recorder Operator Station based with printer or part of the Logging station.
5. Logging Station - PC or Operator Station based (may be same as event recorder)
6. Color Video Graphics Printer with switch to print from operator, testing, and engineer station
7. Process Data Historian - PC or special processor including on line storage and removable archive media.

C. Rack Area (Process I/O) adjacent to Operating area will include the following.

1. DCS Engineer Work Station - PC with mouse and laser printer.
2. PLC Programmers Terminal - PC with mouse and switch for laser printer.

3. DCS rack cabinets containing controllers, communication links, interfaces to subsystems and Process I/O, including sequence of event special DCS input hardware or separate processor linked to a controller. Some I/O may be remote mounted in MCC rooms.
 4. PLC CPU and communication link cabinets of the subsystems furnished with equipment. Some or all PLC I/O may be in MCC rooms or local in skid mounted cabinets.
- D. The Instrument List (See References) identifies all estimated process measurement instruments, primary and final elements individually provided. In addition instruments and field switches furnished with equipment as well as subsystems with only a few interfaces signals will be connected to the DCS Process I/O.

For detailed multi-loop controller and I/O estimates see DCS Specification (See References).

E. Process Systems to be Controlled or Integrated

1. Coal/Limestone Loading System

Coal and Limestone Loading System which includes coal and pebble limestone bunkers, gravimetric feeders, a common belt conveyor with the corresponding drives will be operated and controlled by the DCS.

2. Compressed Air and Instrument Air System
(From Process Air Compressors)

These systems which include centrifugal and displacement type compressors, filters, dryers, and pressure regulators will be controlled by a PLC control subsystem via remote I/O rack with some measurements input directly to DCS I/O.

3. Dense Phase Coal Pressurization System.

This system from the outlet of the silo including the two stage pressure pots with fluidizing will have a PLC based subsystem and all rotary and other valves, switches etc. to control the process. DCS interface will be to the Gasifier System Controller.

4. Coal Gasifier System

The overall coal gasifier system, including the gasifier itself, coal feeding, air and steam supplies to the gasifier and coal gas system with the primary cyclone and flare, will be controlled from the DCS via a dedicated processor (controller).

In order to monitor and control the position and intensity of the gasification zone in the coal gasifier, we are proposing to install two (2) infrared (IR) monitors (scanners) on the sides and top of the gasifier. Each of these instruments will measure two parameters:

intensity and frequency of the IR radiation, which, as we expect, will characterize the intensity and position of the zone of max heat generation. These parameter measurements will allow the operators, during the initial testing and commissioning period, to establish patterns of normal operation and to recognize patterns of abnormal situations. By applying methods of pattern recognition, IR monitors in combination with temperature measurements and gas analyzers will allow development of methods of positioning of the gasification zone and of optimizing the overall gasification process. Nuclear level points or strip will be employed to determine bed height.

The gasifier system will also include a multipoint gas analyzer system to continuously monitor concentration of H₂S, CO, CH₄, CO₂, H₂, NH₃/HCN samples will also be taken to measure alkali, toxic, metals, tar, and the gas HHV at cyclone output and within the process area. The gas analyzers will be located in the common sampling room.

5. Hot Gas Clean-up Systems

Control requirements for these systems include a substantial number of control functions, mostly sequential logic operations. These system ill be controlled directly by DCS.

The HGCU will also be served by the multipoint gas analyzer system to continuously monitor concentration of the above gaseous components.

6. Ash Handling System

Bottom Ash Removal, Handling and Storage System will be controlled with the DCS.

7. Coal Gas Combustion in the HRSG.

The coal gas burners are expected to be equipped with a vendor supplied (PLC-based) burner management system (BMS) containing complete package of instruments, valves, flame scanners, etc., to comply with the NFPA recommendations for coal-fired burners. The BMS will be connected to the DCS via control link or hardwired connections and will be controlled from the CRT operator stations. Interlocks and permissive consistent with the safety shutdown philosophy of the existing Fort Martin Station utility boiler's burner management system will be provided. Remote indication of coal gas combustion and steam generation status will be provided and located in the existing Fort Martin Station utility control room.

- E. Continuous Emissions Monitoring System (CEMS) will include stack analyzers to continuously monitor HRSG Flue Gas for NO_x, SO₂, O₂, CO, H₂S and Opacity. The CEMS will be located on the exhaust breaching and in the sampling room. The CEMS I/O will be wired to the DCS.

II. Assumptions

- A. Since the HRSG flue gas is directed to the Fort Martin No. 2 Unit precipitator this project does not require a full Continuous Emission Monitoring System (CEMS) with the data storage, and reports required by the EPA. The CEMS measurements and calculations will go to the DCS for display, historization and logging for local use.
- B. The high degree of redundancy of processors, I/O and links sometimes employed in systems in which a failure, even with a meantime of 5 to 10 years, may result in lost production from one incident sufficient to more than pay for it is not justified in this project. The best use of capital is to have the extra capacity, measurements, and data processing.
- C. The data terminal (PC based) to be supplied and placed in the Fort Martin Power Plant control room is in lieu of any link to the Plant control or data system.
- D. Process simulation for engineering information or operator training should be given consideration in a later task. (7 or 8) when the empirical information necessary for the design of a process model has been obtained from the initial operation and tests. Simulation for the purpose of control system check-out is not cost effective.
- E. The whole system is to be configured, tested, and shipped on the same schedule (check-out and start-up) and therefore will not require extra support equipment (e.g., engineer station, etc.)
- F. Instruments and equipment for use in the laboratory will be supplied by D.O.E.
- G. The two IR Scanners on the Gasifier and the Multipoint Gas Analyzer for H₂S and HN₃/HCN are in contract to be supplied by PSIT (see Appendix F "PSI PowerServ Scope").

III. References

- A. Functional Control System and Communication Diagram, 301604-60-S-001
- B. DCS Specification
- C. Preliminary Instrument List
- D. Process Flow Diagrams
- E. Standards which apply to the control and instrument system
 - National Fire Protection Association (NFPA)
 - National Electric Code (NEC)
 - National Electrical Manufacturers Association (NEMA)
 - Instrument Society of America (ISA)
 - Institute of Electrical and Electronics Engineers (IEEE)
 - American National Standards Institute (ANSI)

3.11 Host Site Interfaces

As shown in Table 29, there are many important interface ties with Ft . Martin Generating Station :

Table 29
Interfaces with Ft Martin Generating Station

- High Voltage Power Supply
- Medium Voltage Power Supply
- 600 psig Backup Steam for Startup
- No.2 Oil (or natural gas) Supply
- Cooling Water Supply/Return
- Wastewater to Treatment
- Potable Water Supply
- Flue Gas Breeching
- Coal Sourcing
- Condensate Supply
- Byproduct Steam Use Host

Fort Martin piping tie-ins and site piping appear in Figure 17 as follows :

Two power sources of different capacities will be utilized from Ft. Martin to the GPIF site. Additional power and sanitation requirements for METC office trailers will be added when information on their required capacities becomes available.

Valved steam supply and return, cooling tower supply and return, service water supply, condensate supply, fuel oil (or natural gas) supply, combined coal handling waste water runoff and process drain waste water return tie-ins (to Fort Martin) shall all be provided. The actual Ft Martin tie-ins will be designed and furnished by APS.


Steam lines shall be furnished from HRSG to gasifier, ash lock hopper nitrogen vaporizer, deaerator and from the GPIF to Ft Martin Unit No. 2's No. 7 Heater where APS will pick-up the design and installation of the actual tie-in. Quality requirements for the steam to Ft Martin shall include conductivity of 0.06 to 0.1 micromohs, and 75 to 100 TDS.

Condensate piping from all sources including steam line traps to condensate receiver tank, condensate piping from GPIF to Ft Martin Unit No. 2 building limits, as boiler and chemical feedwater make-up (through new condensate storage tank and transfer pumps), cooling water supply line from Ft. Martin's Unit No. 2 cooling tower sump to the GPIF, Air Compressor System and Waste Treatment Vacuum Pump and for seal water, cooling water return line from Gasifier, Air Compressor System, Waste Treatment Vacuum Pump and from seal water users to the cooling water return tank, and cooling water return piping from the cooling water return tank, through pumps, to the existing cooling tower sump with cantilevered submersible pump shall be furnished.

Service water piping from Ft Martin to the coal receiving and preparation area, oxidation reactor, blowoff and CBD Flash Tank discharge lines shall be furnished.

Metered fuel oil (or natural gas) piping from the Ft. Martin tie-in to Gasifier, Booster Pumps and Gasifier, Dry Air Heater, and HRSG shall be supplied.

Proposed Ties Between GPIF and Ft. Martin



CRS Sirrine Engineers, Inc.
Project 31694.00
Approved by: R.S. Sadowski
October 13, 1993

Figure 17
Host Site Interface Sketch

Potable water piping from storage tank through pumps and to safety/eyewash showers, lab, battery room, and men's and women's wash rooms shall be included.

Plant air piping (no Ft Martin tie-in) to coal transfer pressure vessels, Gasifier/Pyrolyzer and to interconnecting vendor supplied equipment associated with air compressors and dryers, instrument air piping to coal receiving and preparation area, Gasifier area, boiler room area, HVAC equipment, and lab shall be included.

The new storage building will be located between the railroad fence and the Ft Martin rail spur approximately half-way between the GPIF and existing Unit No. 2.

Additional parking spaces will be located South of the GPIF in the vicinity of the former new storage building location.

The instrumentation tie-in to Ft Martin shall include one copper cable and one fiber optic cable from the GPIF to the Unit No. 2 control room. No copper instrumentation or tubing shall be utilized in the steam or condensate systems intertied into the Ft Martin system.

The existing three phase power feed to the GPIF shall include a Contractor furnished 600 to 460 volt transformer.

The flue gas duct design shall take into consideration flue gas acid dew point, flue gas exit temperature, and materials of construction. In an effort to avoid direct impingement of GPIF flue gas on precipitator elements, the flue gas from the GPIF duct shall exit into the Ft Martin Unit No. 2 electrostatic precipitator inlet breeching through a sparge pipe configuration to distribute and mix the flue gas into the existing ductwork.

Toxicity Characteristic Leaching Protocol (TCLP) and the disposal of any materials determined to be defined as "hazardous" shall be the responsibility of the DOE/METC. It is anticipated that the laboratory room furnished in the GPIF shall be used for such testing and determinations.

During normal operation, the GPIF is not expected to produce any waste water. However, to accommodate potential boiler chemical spills, facility washdowns, etc., a rate of 5 gpm has been anticipated to be collected in an in-building sump-tank and pump set for disposal via a single waste water line to your waste water treatment tank. In addition, an exterior in-ground sump and pump system is also provided for storm-water run-off, which when filled, will trigger one of two 100 gpm pumps. The sump and pumps have been sized for rainwater runoff from the covered coal pile and ash collection areas.

Process vent piping from the lock hoppers (2), oxidation reactor, and vacuum pump to a main header routed to the HRSG shall be supplied.

Vent or relief vent piping to atmosphere from Gasifier flare stack, steam drum (2), steam lines from HRSG, blowdown separator, fueled gas line from Gasifier, deaerator (3), air compressors, and air dryers shall be included.

Nitrogen piping from storage tank to vaporizer, vaporizer to Gasifier, lock hopper, lab, and deaerator shall be included.

Coal gas piping from the Gasifier to the gas cyclone and the HRSG with provisions for future Hot Gas Cleanup System piping integration shall be provided.

Water and waste piping associated with the oxidation reactor, settling tank, water injection tank and drum filter, process drain waste piping to Fort Martin wastewater treatment facility, and run-off wastewater pipe line to (from) north column line at coal preparation area (combine line with Item 2 above) shall all be provided.

Blowdown and drain piping associated with the HRSG, piping associated with the boiler feedwater system including condensate transfers, piping from blowdown and CBD tanks to the solid waste treatment system.

Chemical feed and interconnecting vendor supplied equipment piping for phosphate service, neutralizing amine service, and oxygen scavenger service shall be included.

The following services shall be insulated: steam, cooling water supply, cooling water return, condensate supply, coal gas piping, misc. vents and for personnel protection as required.

Section 4 Site Requirements, Revised Costs & Schedule

For the most part, site requirements and costs contained within this "Conceptual Design" reflect the best thinking of the contractor and METC at the time of contract award. The basic plan to construct the GPIF adjacent to the Ft. Martin Generating Station Unit No. 2 has remained in tact. The plans to design and fabricate the required vessels to be housed within the confines of the GPIF as self-supported entities has remained. The plan to use a pre-engineered building for both the process and administration containment areas is also unchanged from the originally proposed facility. As a result of either new technological information not available at the time of contracting, or new process requirements developed after contract date, site requirements have changed in several minor areas as are described in this section.

4.1 Site Preparation Requirements

4.1.1 Foundations/Pads, Designs

Drilled pier caisson or driven pile type supported foundations for Process Tower, Main Equipment Foundations, and Building shall be provided.

The building foundation and 6" concrete slab, with 4' X 4' X 6' sump and three (3) 4" floor drains to the storm runoff collection pit.

One sump pump, capacity 5 gpm, 52 HTDH, 2 HP

All process runoff shall be collected in a sump and pumped to the existing Fort Martin Generating Station waste water treatment system.

A spread type footing shall be utilized for minor equipment. A slab on grade to be 6 in. deep reinforced with W.W.F. shall be furnished, including a 6 mil vapor barrier and gravel sub-base, a 5 ft. by 5 ft. by 6 ft. deep process drain sump, and a 6 ft. by 10 ft. by 9 ft. deep sanitary waste sump.

Reinforced concrete foundations shall be furnished for Material Handling equipment and structures, including an open steel frame structure to support bucket elevator coal & limestone silos and screw conveyor, ash storage enclosure with roof and siding, 3 sides with push-up wall, 3-sides.

4.1.2 Steel Support , Blast Wall, Structure, Layout

The vertical process tower support structure is provided. Process tower is enclosed by pre-engineered building but is completely isolated from it. The tower structure will support Gasifier, Absorber, and other process equipment. Tower will contain grating, platforms, access stairs, reinforced concrete blast wall and hoist way with 5 ton monorail to support process. Two sets of steel stairs to 54' high elevation, with steel treads, landings and handrails per code.

The criteria for the blast wall design shall be per Factory Mutual Loss Prevention Data "DAMAGE-LIMITING CONSTRUCTION" I-44.

The pressure-resistant walls and their supports shall be capable of resisting explosion forces of at least 100 psf.

Monolithic walls or those which have a degree of elasticity are most desirable. Types of construction in this category include reinforced concrete, which is the GPIF conceptual design material of choice for construction.

4.1.3 Process Building & Area Major Features

The pre-engineered type building shell erected shall be approximately :
54'W X 148'L X 64'H.

For the heat protection in the winter to maintain 50°F ambient temperature at 0° exterior temperature (except in open gasifier bay), the steam-fired or electric unit heaters are included using existing 600 psi steam or electricity from Ft Martin Station.

Control room inside process building area 20' X 15', with 5' X 7' personnel door with half glass.

A 10' x 7' Input/Output (I/O) room , 10' x 8' Uninterruptable Power Supply (UPS) room, 50 sq ft telecommunications room, and a 10' x 10' office shall all be provided.

Second and third floors for gasifier and future hot gas cleanup system access, 3' X 7' personnel doors with half glass, entrance from the inter platforms. Ventilation fans are included, and grating floor steel form deck.

An electrically operated hoist located near the top of steel including monorail shall be provided for lifting top of gasifier and future hot gas cleanup system vessel heads for access and maintenance.

A lavatory facility, to include separate male & female showers, each with a toilet stall (suitable for handicapped persons), a single wash basin (suitable for handicapped persons), and a men's urinal all complete with standard fixtures will be provided. A pumping and storage tank for waste disposal by portable tank truck will also be furnished.

A furnished combination meeting/break and laboratory room complete with dry erase marker board, hooded sink and microwave oven, and with coffee making, snack and soda machine provisions will be provided. Furniture will consist of two 4 ft x 8 ft folding type tables and twelve (12) straight back chairs.

Piping between the GPIF and Ft Martin Unit #2 shall be ground supported on pre-fabricated concrete supports on sleepers.

Insulated carbon steel breeching with stiffeners and support steel for run from HRSG to Induced Draft Fan, 48 in. dia. non-insulated duct from fan for a run of 1800 ft. to Fort Martin precipitator shall be provided.

The existing shed building along with its slab and foundation shall be demolished. A new pre-engineered type structure with slab on grade and foundation to the same square footage as existing shed shall be furnished in a new location for Ft Martin.

A pre-engineered structure and related concrete work including 4 ft. x 11 ft. x 12 ft. deep sump shall be provided for the Fire Pump House.

4.1.3.1 Entrance Road

The entrance road, plant roads, and parking areas will be asphalt paved. The pavement cross section will consist of a 2 1/2 inch surface coarse, a 2 1/2 inch binder coarse, and a 10 inch aggregate base coarse. The roadways will be 20 feet wide with three foot shoulders. Asphalt aprons will be provided at the limestone unloading area, the ash disposal area, and the coal handling area. These areas shall include a 12 inch base of compacted crushed stone, prime coat, 4 1/2 inch thick base binder and a 1 1/2 inch wearing coarse. Four foot square man-door pads will be provided outside the exterior doorways and four foot wide sidewalks will be provided from parking areas to the office area. All sidewalks will be four inches thick non-reinforced concrete.

Six foot high chain link fence with three strands of barbed wire will enclose the plant property. There will be a motor operated slide gate at the main entrance. The gate will be operated by personnel in a remote location, viewing the gate by a TV monitor.

All disturbed earth areas on the site will have four inches of topsoil applied and be grassed with fescue.

A one inch potable waterline from the Fort Martin interface point to the facility reservoir tank will be provided.

An eight inch ductile iron pipe fire protection loop will be provided around the plant with fire risers to the building and other critical out buildings and facilities. Fire hydrants will be provided in the fire protection main loop at 300 foot intervals. All hydrants will be provided with gate valves and boxes. Post indicator valves will be used on fire riser lines. PIV division valves will be used to isolate each five major branches in the fire loop. The loop will be connected to a new 1500 GPM diesel fire water pump in an on-site fire pump house. A Jockey pump will also be provided.

Sanitary waste will be conveyed by gravity using six inch PVC sewer pipes. Sanitary waste will be collected in a holding tank to be pumped out by a local septic company.

4.1.3.2 Storm Water Collection

Provisions shall be made for storm water drainage consisting of ditching with concrete culverts where required to direct storm water to the detention pond before leaving the site via a natural drainage feature. Storm water discharged will be controlled. Storm water run-off from the coal and ash handling areas will be collected in a basin and be pumped to the Fort Martin waste treatment system. Provide two (2) 100 GPM storm water sump pumps.

4.1.3.3 Fire Protection

An automatic deluge system for the gasifier area shall be provided.

An automatic wet pipe system protecting all building areas except electrical rooms, control room, and IO room shall be provided. A similar system shall also be provided for the fire pump building. Fire pump intakes shall be from both existing lagoons such that one lagoon may be drained without impacting protection.

An automatic dry pipe system supplying vendor supplied sprinkler heads for bucket elevator, coal storage bin, dust collectors, sampler, crusher, fines bin, tote bins and charge hopper, transfer hopper, cyclone receiver and classifier shall be provided.

An automatic dry pipe system protecting the coal charge hopper, the chute from the coal weigh belt feeder to the coal dryer, and the 16" dia. duct from the coal prep. dust collector to the HRSG shall be provided.

Fire extinguishers shall be provided for all areas.

4.1.3.4 HVAC

Electric unit heaters and controls to maintain 40°F minimum, exhaust fan and air intake louver and motor operated dampers for ventilation to maintain 100°F maximum shall be furnished for the fire pump house, high voltage equipment room, and compressor room.

A makeup air unit shall be provided to supply makeup air to gasifier area air lock.

The gasifier area shall have roof mounted exhaust fans.

The boiler room shall have electric unit heaters and controls to maintain a minimum of 40°F, louvers and motor operated dampers for room ventilation, and exhaust fans to maintain room at a maximum temperature of 110°F.

The office area shall have a packaged, multi-zone, all electric, air conditioning unit to air condition all spaces. Design condition is 75°F with humidity uncontrolled. Outside air will pressurize area.

Separate exhaust fans shall be furnished for presentation/laboratory room, UPS room, control room, and two exhaust fans for men and women's locker rooms. A DDC control system shall be furnished with the HVAC system.

4.1.3.5 Plumbing

A sanitary waste and vent system for the men's and women's toilets shall be provided.

A lab waste and vent system serving the lab sink, under counter lab sink acid neutralization tank shall be included. Tank will drain to sanitary sewer.

A process waste and vent system for main building floor and hub drain collection and routing to the process waste sump shall be provided. A similar system for the fire pump house routed to sanitary sewer shall be provided.

A potable water system from the potable water tank and pump to toilets, urinals, sinks, showers, and water coolers shall be provided. The potable water piping shall be insulated.

An electric potable water heater shall be provided for showers and sinks.

4.1.4 Office Configuration

Administration Building to be single story with varying roof heights (i.e. no intermediate floors). Roof system to be insulated standing seam metal roof deck. Walls to be insulated metal siding.

4.1.5 Utility Service (Other than from Ft. Martin)

The design of the GPIF includes potable water, Uninterruptable Power Supply (UPS), telephone service, and portable sewage removal.

4.2 Revised Construction Cost Estimate

The revised Cost Estimate -- Budget for Phases I and II of the GPIF project (Table 30) along with a breakdown of anticipated sub-contract cost estimates including the potential impact of state taxes is shown on the following page. The complete Cost Estimate appears in Appendix G "Detailed Cost Estimate".

Table 30

**GPIF PROJECT ESTIMATE SUMMARY
(\$)**

PHASE I

CRS SIRRINE ENGINEERS, INC.	6,536,609	
PSIT SUB-CONTRACT	926,800	
RILEY STOKER SUB-CONTRACT	<u>20,332,520</u>	
		27,795,929

PHASE II

TOTAL DIRECT COST	2,967,000	
TOTAL INDIRECT COST	<u>869,000</u>	
SUBTOTAL	3,836,000	
ESCALATION	<u>100,894</u>	
		3,936,894

PROJECT TOTAL	31,732,823
----------------------	-------------------

4.2.1 Construction Cost Estimate

During the course of the development of Task 4, Riley Stoker Corporation and CRS Sirrinc Engineers, Inc. painstakingly collaborated on the cost estimate. Specialists from both companies met on several occasions to identify all potential differences in assumptions and historical cost information in order to develop as accurate an estimate as possible.

After weeks of review and commenting, the detailed estimate which appears in Appendix G was completed to the satisfaction of both organizations. Appendix G includes the estimated CRS Sirrinc Engineers, Inc. (CRSS) costs and hours to complete the remaining GPIF project tasks, the Riley Stoker Corporation detailed cost estimate including direct cost quantities and construction labor, and the current PSI Power Serv sub-contract cost estimate breakdown.

Backup detailed cost estimates for piping, instrumentation, and electrical are also included in Appendix G.

4.2.1 Value Engineering Cost Reduction Potentials

1. Consistent with METC's suggestion that we may include used and Government surplus equipment, we recommend consideration be given to not demolishing the existing storage building at Ft. Martin. We believe the cost of refurbishing it into a larger than proposed administration building for the GPIF will save METC trailer leasing costs, and provide them with the added storage capacity which METC has been seeking. The existing storage building was originally constructed as a field office which is the same purpose as the GPIF administration building. While its skin and roof need replacing, its steel internal structure and concrete flooring appear to be in excellent condition, and it currently is wired consistent with one of the contemplated GPIF project power sources. Since it occupies the same spot where the primary site GPIF administration building conceptual design is located, such a consideration should not impact the NEPA process. It is, therefore, recommended that METC give serious consideration to implementing this cost saving approach under the Task 6 "Detailed Design".

2. Locating the GPIF on the alternate site has the potential to cut the cost of the interconnecting piping, ducting, electrical, and communications lines to Ft. Martin by 50% since the distance is approximately cut in half. It would also result in an increase in the grade elevation of the GPIF by approximately 20 ft. in contrast to the primary site location which could have positive "flood plain" implications. We understand that from a NEPA perspective, however, the primary site is preferred due to less tree cutting required for the primary site. The METC decision to utilize the more costly primary site for NEPA reasons shows a high METC consciousness to protect existing vegetation in the vicinity of the GPIF site, a laudable position.

3. Identification of I & C equipment items recommended for testing the PyGas™ gasification process, but for METC to purchase separately under their "Data Base" program represents an additional potential project cost saving measure. This will result in METC absorbing the cost of these items as capitalized equipment for their future internal use thereby not associating such charges with the GPIF project funding.

As a minimum, the following items are included in this recommendation :

- 3.1 PSI-E's alpha-NH3 Monitor
- 3.2 PSI-E's Gastemp Monitor for Preheat Control
- 3.3 PSI-E's Gastemp Monitor for Cracking Burner Control
- 3.4 A Gas Chromatograph
- 3.5 A Mass Spectrophotometer

3.6. Test Conducting Position DCS Station -- This is a dual CRT DCS operator station that would allow viewing and analysis of process conditions, data, and historical trends. In addition, it would serve as a backup operator station.

3.7. PC based DCS Reporting Station -- The report generation PC was combined with the historian PC. Having separate PC's would allow for the collection of more points and faster sampling frequencies.

3.8. H₂S and HHV analyzers -- These were recommended by PSI, but were not included in the task 4 estimate.

3.9. Oxygen analyzer on the HRSG -- This would allow trim of the air/fuel ratio. This is especially important with a variable BTU fuel. The alternative is to always run with a very high excess air.

3.10. Opacity monitor on HRSG flue gas.

CRSS recommends retaining the \$588,000 originally proposed cost figure in the PSI-E scope, and include additional funding for the PSI-E's alpha-NH₃ Monitor and PSI-E's Gastemp Monitor from the "Data Base" program as required for PSI-E's instruments development. These instruments were not included in the original proposal or contract, however, subsequent investigations conducted under Task 4 has identified them as items worth development under a separate CRADA, and modified versions from the CRADA development results subsequently applied as a cost extra to the contract.

4.2.2 Recommended Project Scope Changes

The following actions are recommended to be followed-up with by the "Project Team" as part of the "Detailed Design" functions of Task 6 :

1. The original proposal and contract included a 5 ft diameter PyGasTM gasifier vessel. This was the result of extrapolating available carbonizer tube data (C. Lowell, et al) with the anticipation that approximately 50% of the gasification duty (DOE/METC Contract No. DE-AC21-78MC-10484) would be produced from the pyrolyzer tube of PyGasTM. A review of the results of subsequent testing conducted by Foster Wheeler Development Corporation under DOE/METC Contract DE-AC21-86MC21023 and made available to CRSS after GPIF contract was entered into, indicated that almost 70% of the coal could be gasified in the pyrolyzer tube.

The implications of the new data are very positive to the likelihood of success with the PyGasTM gasifier, because it means that almost 20% more coal gasification can take place under rapid pyrolysis conditions than was originally thought to be possible. Original concerns expressed by METC that the pyrolyzer tube performance was critical to the success of PyGasTM should now be eliminated.

The "Project Team" recommends modifying the PyGasTM gasifier conceptual design to incorporate the ability to operate the pyrolyzer in the same mode that resulted in Foster Wheeler converting almost 70% of the coal to gaseous fuel in their carbonizer tube.

This will require operating the pyrolyzer with 36% of stoichiometric air rather than 27% as originally contemplated under the contract. In order to maintain the same superficial velocity through the lower pyrolyzer tube as originally contemplated, it must be increased from 20 inches diameter to 24 inches diameter. In addition, to lower its exit velocity to minimize spouting per METC recommendations, its diameter will need to be further increased to 34 inches. Increasing the pyrolyzer tube diameter results in the necessity to increase the overall gasifier vessel from 5 ft. to 6.5 ft. diameter in order to fit its rotating grate mechanical components.

While we may continue to contemplate a 5 ft. diameter gasifier as required under the contract, it is our understanding that METC does not want to penalize the "Project Team" for utilizing data developed from their other programs in ways that will increase the likelihood of success of the GPIF and PyGas™ gasifier when such data was unavailable at the time of our original proposal. We, therefore, recommend METC consider a contract change to include the aforementioned design modifications in detailed design Task 6.

2. The same technical premises which result in the recommendation of the larger test gasifier also impact the sizing of the high pressure air compressor. The CRS Sirrine Engineers, Inc. model predicts that going from the original design and operating conditions as was proposed and contracted for to the latest conditions determined from METC Contract DE-AC21-86MC21023 and utilizing Ft. Martin coal results requires an increase in the required air compressor capacity from 5,500 scfm to 8,770 scfm. Again, we recommend METC cover the added cost of a larger air compressor by issuing a contract change during the Task 6 "Detailed Design" period.

3. The original DOE/METC specifications contemplated piping the coal gas from the GPIF to Ft. Martin Unit No. 2 for combustion in the existing furnace. Due to potential legal concerns regarding indemnification, the decision was made to combust the coal gas at the GPIF in a package boiler and then duct the flue gas to the existing Unit No. 2 precipitator inlet. A 100,000 pph, 175 psig saturated steam package boiler was priced and included in both the proposal and the contract.

Subsequently, additional considerations associated with Ft. Martin operating conditions and steam needs has led to a new requirement for a fired Heat Recovery Steam Generator (HRSG) to operate with steam safety valves to relieve at 950 psig, and to produce 700°F steam of very high quality for use in the Ft. Martin cold reheat system.

Since these new HRSG requirements have little to do with the gasification test unit, and everything to do with the METC/Ft. Martin Site Access Agreement, we recommend METC issue a contract change during Task 6 to cover the increased costs associated with the currently contemplated HRSG design conditions.

4.3 Schedule for Detailed Design and Construction

The consolidated schedule reflecting the project team's latest assessment of remaining Task 5 through Task 9 appears in Appendix H of this report.

A bar chart type schedule showing major tasks and milestones (Figure 18) and including assumptions (Table 31) associated with its generation appear on the following pages.

4.3.1 Long Lead Items Description

There are four long lead items which either have had or will have an impact on the performance of this project. These include NEPA permitting, Gasifier Design & Fabrication, High Pressure Air Compressor Fabrication, and the Heat Recovery Steam Generator (HRSG) Design & Fabrication. Fortunately, one of the team members is a boiler manufacturer which will facilitate design and fabrication of the Gasifier & HRSG.

The development of the NEPA document, and process time (now expected to run through December, 1993) has already delayed the GPIF project by several months.

MILESTONE SCHEDULE

☒ PLAN ☐ STATUS REPORT

FORM APPROVED
OMB 1901-1400

1. TITLE		2. REPORTING PERIOD		3. IDENTIFICATION NUMBER	
DEVELOPMENT OF STANDARDIZED GASIFICATION PRODUCT IMPROVEMENT FACILITY		1 Oct thru 31 Oct, 1993		DE-RP21-91MC28202	
4. PARTICIPANT NAME AND ADDRESS					
CRS Sirtina, Inc. ATTN: Larry S. House P. O. Box 5456 Greenville, SC 29606					
7. ELEMENT CODE		8. REPORTING ELEMENT		9. DURATION	
TASK		DESCRIPTION		10. PERCENT COMPLETE	
				a. Plan	
				b. Actual	
1	Env. Impact (NEPA rpt)	Δ	Δ	100	100
2	Work Plan - Phase I	Δ	Δ	100	100
3	Permit Information Obtain Permits	Δ	Δ	100	100
4	Conceptual Design	Δ	Δ	100	100
5	Bench-Scale Tech. Cont. Studies	Δ	Δ	0	0
6	Detailed Construction Design	Δ	Δ	0	0
7	Site Preparation Procurement & Delivery Construction	Δ	Δ	0	0
8	Pre-Operational Test Plan	Δ	Δ	0	0
9	Pre-Operational Testing	Δ	Δ	0	0
Total Phase I		Δ	Δ	0	0

Table 31
Assumptions Associated with Schedule

DEPARTMENT OF ENERGY
GASIFICATION PRODUCT IMPROVEMENT FACILITY
SIRRINE JOB NO. 31604

ASSUMPTIONS

1. NEPA Report approval received by January 17, 1994.
2. DOE/RILEY/CRSS agrees with Gasifier design concept.
3. Gasifier and HRSG design will be by Riley.
4. Riley will be responsible for the bidding/procurement of subcontracts, equipment, and material. CRS SIRRINE will provide drawings and specifications and will review bid tabulations.
4. Vendor drawings will not be a part of the Contract Bid Package, but will be received prior to mobilization.
5. HVAC will spec equipment (dampers, exhaust fans, unit heaters, (1) a/c unit) on drawings -- will not develop individual specifications.
6. All equipment will include motors provided by the vendor -- no separate motor purchases.

Care must be exercised to avoid future delays, as it is in our collective best interests to expeditiously complete this project at the earliest time possible.

4.3.2 Anticipated Time Requirements

The Project Team would prefer to go to a "Fast Track" schedule from this point to completion of the project. Riley, PSIT, and CRS SIRRINE all see the "opportunity window" for the development of the PyGas™ gasification process and peripheral technologies to be now, such that it is in time to support commercialization of the product in the latter half of this decade when most utilities will be giving serious consideration to gasification processes and IGCC's for both Retrofit/Repowering as well as new installations.

The NEPA process has introduced about a year long delay in the originally anticipated GPIF design and installation schedule. This has put the testing and technology development schedules about a year behind what was thought to be a reasonable schedule. All parties now strongly urge DOE/METC to hasten the pace from this point on to completion of this all important project.

REFERENCES :

1. "Coal Gasification", David M. Jones, Babcock Woodall-Duckham Ltd., Crawley, West Sussex, England, Chapter 3-9, Page 183, Table 9-2
2. "System Analysis of Simplified IGCC Plants", by J.C. Corman, General Electric, Topical Report No. ET-14928-13, September, 1986
3. "Gas Producers and Blast Furnaces - Theory and Methods of Calculation", Wilhelm Gumz, D.Eng., John Wiley & Sons, Inc., Copyright 1950
4. Bureau of Mines Report of Investigation RI 6721
5. "Production of Low Btu Gas Involving Coal Pyrolysis and Gasification", by Wen, et al., West Virginia University
6. "Lurgi Process, the Route to SNG from Coal", Paul F. H. Rudolph, Lurgi Mineralotechnik GmbH, Frankfurt, Germany, Proceedings of the Fourth Synthetic Pipeline Gas Symposium of the AGA, Chicago, Illinois, October 30, 1972
7. Bureau of Mines RI 6721, Oppelt, et al, Lurgi-Gasifier Tests of Pittsburgh Bed Coal, November 1963
8. Hippo, E. & P.L. Walker, Jr., "Reactivity of Heat Treated Coals in Carbon Dioxide at 900°C", ACS Div. of Fuel Chemistry, Aug. 1975
9. "Chemistry of Coal Utilization", Supplementary Volume, Table 16, Page 961, H.H. Lowry Editor, John Wiley, 1963
10. "Desulfurization of Hot Coal-Derived Gas by Calcined Dolomite", by E.J. Nemeth, et al, AIChE, 1981"
11. "Intrinsic Kinetics of CaS(s) Oxidation", by Rowena J. Torres-Ordóñez, et al, AIChE 1989
12. "Chemistry of Coal Utilization", Supplementary Volume, Table 16, page 961, John Wiley & Sons, Inc., 1963
13. "Modeling Fixed-bed Coal Gasifiers", by M.L. Hobbs, et al, AIChE Journal, 5/92
14. "Coal Devolatilization in a Low Pressure, Low Residence Time Entrained Flow Reactor", by R. L. Coates, et al, Chemical Engineering Department, Brigham Young University, May, 1973
15. "Pressurized Hydrogasification of Raw Coal in Dilute Phase Reactor", by H.F. Feldmann, et al, U.S. Bureau of Mines, May 1973
16. "Devolatilization of Coal by Rapid Heating", by M. Menster et al, U.S. Bureau of Mines, PERC, 1973
17. "Pressurized Hydrogasification of Raw Coal in Dilute Phase Reactor", by H.F. Feldmann, et al, U.S. Bureau of Mines, May 1973

REFERENCES : (continued)


18. "Solid-Gas Reactions in Coal Conversion Processes", by C.Y. Wen et al, West Virginia University, mid-1970's
19. "The Kinetics of Fast Pyrolysis (Ultrapyrolysis) of Cellulose in a Fast Fluid Bed Reactor", by B.A. Freel, et al, The University of Western Ontario, AIChE Symposium Series, No 255, Vol 83
20. "Entrained Bed Carbonization of Highly Fluid Bituminous Coals", by M. Gomez, et al, U.S. Bureau of Mines, Denver, RI 7141
21. "Social and economical aspects of the introduction of gasification technology in rural areas of developing countries e.g. Tanzania", M.J. Groeneveld & K.R. Westerterp, Thermal Conversion of Solid Wastes and Biomass, ACS Symposium, Washington, DC, September, 1979
22. C. Lowell, et al, DOE/METC Contract No. DE-AC21-78MC-10484
23. Foster Wheeler, DOE/METC Contract No. (DE-AC21-86MC21023)

Conceptual Design Report

Gasification Product Improvement Facility (GPIF)

Appendix B

PyGasTM Kinetics Details



Prepared by : CRS Serrine Engineers, Inc.
1041 East Butler Road
Greenville, South Carolina 29606

Prepared for : United States Department of Energy
Morgantown Energy Technology Center
Morgantown, West Virginia 26507-0880

September, 1994

Equations to find Cp of air (column 2)			
TEMP (K) =			
cp CO2		Pyrolyzer Steam (column 3)	525.58
cp H2O		Temp (K)	0.481
cp O2		Latent Heat of Vapor	
cp N2		730.85 Btu/lbm	
cp Ar			
Total			
Latent Heat of Vapor	989.19	Btu/lbm	
Coal Handling Considerations			
Stoichiometric amount of air			
needed to combust coal			
7.74 lb of air/lb of coal			
Sensible heat (absorbed during crushing)			
Temp of coal (K)	338.89		
C - delta h	17.42 Btu/lbm		
H - delta h	310.48 Btu/lbm		
O - delta h	18.30 Btu/lbm		
N - delta h	22.15 Btu/lbm		
S - delta h	12.32 Btu/lbm		
ASH - delta h	12.20 Btu/lbm		
Total of coal	426.84 Btu/lbm		
Pyrolysis Gas (column 4)			
Latent Heat of Vapor.			
Products of Pyrolysis - Gase:			
Finding Cp of Gases			
delta h CO2	53.83 B		
delta h CO	68.51 B		
delta h H2O	52.76 B		
delta h H2	65.72 B		
delta h CH4	11.09 B		
delta h H2S	5.84 B		
delta h N2	230.65 B		
delta h Ar	2.59 B		
delta h NH3	5.91 B		
TOTAL	496.90 B		
cp Gases	0.322 B		

Finding the Results of Pyrolysis			
Positive sign means heat is absorbed in process / Negative sign means heat is released in process			
Char & Ash			
Sensible heat (absorbed during pyrolysis)			
Temp of coal (K)	1144.44		
C - delta h	520.64 Btu/lbm		
ASH - delta h	364.75 Btu/lbm		
Total of coal	391.76 Btu/lbm		
Total heat	3547596 Btu/hr		
PYROLYSIS OUTPUT (COLUMN 10A, CH1) INPUTS FROM SKINNER			
27	6684	*CO 4515	14.55
18	-64	*H2 323	14.46
5	4274	*CO2 3551	7.28
3.5	810	*H2O 1834	9.19
4	230	*CH4 230	1.29
	0	*C2H6 0	0.00
	357	H2S 100	0.95
	0	CO2 0	0.00
		*N2 15715	50.63
		Ar 366	0.83
			99.17
Elemental Balance			
(Inputs vs Outputs)			
0.98% C			
-0.53% H			
-0.62% O			
0.28% N			
0.01% S			
Gases of Pyrolysis			
Predicted Temperature			
Heat Absorbed during Pyrolysis			
delta h CO2	391.02 Btu/lbm		
delta h CO	387.74 Btu/lbm		
delta h H2O	735.71 Btu/lbm		
delta h H2	5193.50 Btu/lbm		
delta h CH4	1253.80 Btu/lbm		
delta h H2S	419.39 Btu/lbm		
delta h N2	374.84 Btu/lbm		
delta h Ar	180.40 Btu/lbm		
delta h NH3	968.30 Btu/lbm		
Total	16261092		
Equations In Pyrolysis			
*C	2222 lb/hr		
CO2	3887 lb/hr		
*C	667 lb/hr		
*C	89 lb/hr		
C	172 lb/hr		
H2	21 lb/hr		
0.5 N2	130 lb/hr		
*H2	105.55 lb/hr		
O2	5919 lb/hr		
*C	1055 lb/hr		
1/2 O2	888 lb/hr		
H2O	133 lb/hr		
2 H2	59 lb/hr		
S	336 lb/hr		
1.5 H2	28 lb/hr		
1/2 O2	837.61 lb/hr		
CO2	8141 lb/hr		
CO	4923 lb/hr		
H2	15 lb/hr		
*CH4	230 lb/hr		
H2S	357 lb/hr		
NH3	158 lb/hr		
H2O	943.15 lb/hr		
CO2	169294		
CO	74196		
H2	56487		
*CH4	32200		
H2S	8586		
NH3	19728		
H2O	104036		
CO2	389951		
CO	13039580		
H2	2648.91		
*CH4	-1697.57		
H2S	1881.28		
NH3	-2007.24		
H2O	-251.97		
CO2	-3846.71		
CO	-2638884		
H2	-481668		
*CH4	-89965		
H2S	-182502		
NH3	-5446670		
H2O	779 *CaS		
CO2	1.74 *Air/Coal		

CARBON AVAILABLE	85.44 LB/HR	HEAT ABSORBED	16261092	22.49%	% Theo. Air to Pyrolyzer
CARBON USED	8631 LB/HR	HEAT FORMED	-26103454	0.0000015	*Pyrolyzer Steam/Coal
OXYGEN AVAILABLE	5494 LB/HR	TEMP Predicted	1600	1600	*Assumed Pyrolysis Temp (°F)
OXYGEN USED	7053 LB/HR	TEMP Calc. (Less No Assumed He	2578	35.00%	*Empirical Pyrolysis (FW)
1559	1mole H ₂ S	1559		924 °C	
CaCO ₃	H ₂ S	CaS +	+ CO ₂	Btu/lb mol	Btu/lbm
1162	397	838	210	27930	279.05
	CaCO ₃	CaO	CO ₂	51901	1523
	1744	618	767	42610	425.72
2.78*CaCO ₃	H ₂ S	CaS + 1.78 CaO + 2.78*CO ₂	+ H ₂ O		-26103454
Pyrolyzer Gases					
1. Match WEN's H ₂ O	WEN DATA	CRSS PREDICTION	Tech Paper	Empirical Analysis	
2. Match WEN's CO ₂	27.15 CO	14.55		.	Energy Bal Error
3. Match WEN's CO	18.65 H ₂	14.46		.	Pyrolyzer Exit Gases (Btu/sec
4. Adjust Eq. 4. to Match WEH ₂ O	4.71 CO ₂	7.28		.	24.02%
5. Adjust all to Match WEN CH ₄	3.5 H ₂ O	9.19		.	111
6. Adjust Pred. Temp.	3.74 CH ₄	1.29		.	
7. Balance C with MJB	C ₂ H ₆	0.00		.	
8. Chk Reasonableness	H ₂ S	0.95		.	
(Is delta T a few hundred deN2	CO ₂	0.00		.	
	N ₂	50.83		.	
	Ar	0.83		.	
	HCl	0.00		.	
	HCN	0.00		.	
	NH ₃	0.83		.	
	CS ₂	0.00		.	
	SO ₂	0.00		.	
	NO	0.00		.	
	O ₂	0.00		.	
	NaCl	0.00		.	
	KCl	0.00		.	
	CaSO ₄	0.00		.	
	Ca(OH) ₂	0.00		.	
	Cl ₂	0.00		.	
	Total	100.00		.	
					16229.194
					3168.1637
					224.00111
					3966.1205
					198.44111
					864.51231

Pyrolyzer Tube Sizing		Gasification Ratios	
FW Gasification Rate	931 lb/square foot		
GPIF to FW Ratio	23.62 @ 199 psig		3.87
GPIF @ 600 psig	14 times FW area		24.49
FW Diameter	10 inches diameter		14.14
FW Area	78.54 square inches		1.73
FW Area	0.55 square feet		6.32
GPIF per FW Data	7.44 square feet		
GPIF per FW Data	1071.14 square inches		
GPIF per FW Data	37 inches diameter		
	Carbonizer Tube		
	15 Ft FW Effective		
	Carbonizer Tube Hgt		
Gasifier Sizing		Gasification Ratios	
Gasifier Diameter	5 ft		
Gasifier Area	19.64 square feet		
Less Carbonizer Tube	12.20 square feet		
Superficial Velocity	2.13 ft per second		
Gasifier Diameter	6.5 ft		
Gasifier Area	33.18 square feet		
Less 37" Carb. Tube	26.74 square feet		
Superficial Velocity	0.29 ft per second		
Less 24" Carb. Tube	30.04 square feet		
Superficial Velocity			
Superficial Velocity	0.25 ft per second above grate		
Superficial Velocity	0.51 ft per second above grate (2 ft above grate)		
Pyrolyzer Tube Sizing		Gasification Ratios	
Lowell's Gasification Rate	GPIF to Lowell's Ratio		
GPIF @ 600 psig	14 times FW area		
Lowell's Diameter	Lowell's Area		
Lowell's Area	Lowell's Area		
GPIF per Lowell Data	7.44 square feet		
GPIF per Lowell Data	1071.14 square inches		
GPIF per Lowell Data	37 inches diameter		
	Carbonizer Tube		
	15 Ft FW Effective		
	Carbonizer Tube Hgt		
Gasifier Sizing		Gasification Ratios	
Gasifier Diameter	5 ft		
Gasifier Area	19.64 square feet		
Less Carbonizer Tube	12.20 square feet		
Superficial Velocity	0.49 ft per second		
Gasifier Diameter	6.5 ft		
Gasifier Area	33.18 square feet		
Less 37" Carb. Tube	30.78 square feet		
Superficial Velocity	0.24 ft per second		
Superficial Velocity			
Superficial Velocity	0.25 ft per second above grate		
Superficial Velocity	0.51 ft per second above grate (2 ft above grate)		
Pyrolyzer Tube Sizing		Gasification Ratios	
Lowell's Gasification Rate	GPIF to Lowell's Ratio		
GPIF @ 600 psig	14 times FW area		
Lowell's Diameter	Lowell's Area		
Lowell's Area	Lowell's Area		
GPIF per Lowell Data	7.44 square feet		
GPIF per Lowell Data	1071.14 square inches		
GPIF per Lowell Data	37 inches diameter		
	Carbonizer Tube		
	13 Ft Effective		
	Carbonizer Tube Hgt		
Gasifier Sizing		Gasification Ratios	
Gasifier Diameter	5 ft		
Gasifier Area	19.64 square feet		
Less Carbonizer Tube	17.24 square feet		
Superficial Velocity	0.49 ft per second		
Gasifier Diameter	6.5 ft		
Gasifier Area	33.18 square feet		
Less Carbonizer Tube	30.78 square feet		
Superficial Velocity	0.24 ft per second		
Superficial Velocity			
Superficial Velocity	0.87496736 ft per second		
Superficial Velocity	Through Pyrolyzer Tube		

Determination of the makeup of air based on a given amount of moisture in the air					
0.00686 LB H2O / LB DRY AIR					
144.32056 LB/HR OF H2O					
20735.713 LB/HR OF DRY AIR					
15665.831 LB/HR OF N2					
4800.3175 LB/HR OF O2					
274.7482 LB/HR OF AR					
9.8909351 LB/HR OF CO2					
559.49397 MOLS OF N2					
150.00992 MOLS OF O2					
6.8687049 MOLS OF AR					
0.224794 MOLS OF CO2					
8.017809 MOLS OF H2O					
724.6152 TOTAL MOLS					
0.7721256 MOLS % OF N2					
0.2070201 MOLS % OF O2					
0.0094791 MOLS % OF AR					
0.0003102 MOLS % OF CO2					
0.0110849 MOLS % OF H2O					
Void Fraction Assumption		40.00%			
Coal Feed Rate (pph)		12000			
Coal Density (lb/cu ft)		55			
Coal Volume (cu ft/min)		9.09			
Coal Velocity (fpm)		3.79			
Solids Velocity Through Inner Annulus					
Char Volume Reduction		20.00%			
Char Volume		7.27	cu ft/min		
Char Velocity Assumption		1.00	ft. per min		
Inner Annulus Area (sq ft)		1.92			
Pyrolyzer OD (inches)		32			
Pyrolyzer OD Area		5.59	1152	sq ft cross sect area	
Inner Annulus + Pyrolyzer Area		7.51	8.07	act cu ft/min gas flow	
Outside Diameter of IA (inches)		37.09		fps @ 1700°F	
Solids Velocity Through the Gasifier					
Char Volume @ Mid-Gasifier		7.27			
Inside Dia of Gasifier (ft)		8			
Outside Dia of Pyrolyzer (ft)		2.67			
Gasifier ID Area (sq ft)		50.27			
Pyrolyzer OD Area		5.59			
Gasifier Actual Area (sq ft)		44.68			
Char Velocity (ft/min)		0.04			
Char Velocity (ft/hr)		2.58			

Pyrolyzer Tube Volume :
27.52 cu ft

Inner Annulus Volume, 6 ft hgt
18.98 cu ft

Coal Proximate Analysis, %

	Fixed Carbon	Volatiles Matter	Ash	Total	Interactive	New Analysis	Limestone Analysis Input
	52.00%	30.00%	3.00%	15.00%	52.00%	Purity	CaCO ₃
				100.00%	30.00%	Moisture	95.94%
					15.00%	Calcium	0.40%
					100.00%		1167

Dry Interactive Coal & Limestone

Coal Ultimate Analysis

	Carbon	Hydrogen	Oxygen	Nitrogen	Sulfur	Chlorine	Moisture	Ash	Total	Interactive	New Analysis	Limestone Analysis Input
	70.74%	4.74%	4.80%	1.24%	2.89%	0.10%	0.00%	15.47%	100.01%	68.60%	need to verify	350
										4.60%	need to verify	1398
										1.20%	need to verify	
										2.80%	need to verify	
										0.10%	need to verify	12% Moisture
										3.00%		124% Ash
										15.00%		3050
										100.00%		

*Moisture remaining in coal/limestone after drying

*Coal Feed Rate (per PyGas Gasifier)

*Coal, Higher Heating Value

*Coal Feed Temperature

*Gasifier Pressure

*Pyrolyzer Steam to Coal Ratio (lb/lb)

*Enthalpy of Steam entering pyrolyzer

*Temperature of Feed Air to Pyrolyzer in Gasifier

*Temperature of Feed Steam to Pyrolyzer in Gasifier

*Moisture in Air

*Percent Conversion of Coal Nitrogen to NH₃ in gas

Pyrolyzer Temperature

*Air to Coal Ratio into top of Gasifier

*Temperature of Air into top of Gasifier

*Steam to Coal Ratio into top of Gasifier

*Temperature of Steam into top of Gasifier

*Enthalpy of Steam injected at top of gasifier

*Peak Temperature at Top of Gasifier

*Percentage Bed Voidage

0.0000 start by adding air to peak desired temp. make sure M317 = M318

300 F

0.000000

700 F

1351.80 Btu/lbm

1589 F (set = to G322, let iteration happen, then insert the number)

38.00%

In Determining Gas Composition at the top of Gasifier, you must enter lb/hr of H₂ to be combusted. Balance oxygen. If some oxygen still remains after hydrogen is gone, input lb/hr of carbon monoxide to consume remaining oxygen. Then, increase steam to coal ratio until temperature balances.

lb/hr of H₂ available*lb/hr of H₂ combusted

lb/hr of CO combusted

Steam to Coal Ratio

Temperature Estimated

Temperature Desired

Difference

*Low-Btu Gas Exit Temperature

adjust G317 input until balanced

228 lb/hr (-G113) Oxygen Balance

0.0000001 lb/hr Oxygen available

0 lb/hr Oxygen Consumed

0.0000001

-IF (G322-G323-G324-G325-G326-G327-G328-G329-G330-G331-G332-G333-G334-G335-G336-G337-G338-G339-G340-G341-G342-G343-G344-G345-G346-G347-G348-G349-G350-G351-G352-G353-G354-G355-G356-G357-G358-G359-G360-G361-G362-G363-G364-G365-G366-G367-G368-G369-G370-G371-G372-G373-G374-G375-G376-G377-G378-G379-G380-G381-G382-G383-G384-G385-G386-G387-G388-G389-G390-G391-G392-G393-G394-G395-G396-G397-G398-G399-G400-G401-G402-G403-G404-G405-G406-G407-G408-G409-G410-G411-G412-G413-G414-G415-G416-G417-G418-G419-G420-G421-G422-G423-G424-G425-G426-G427-G428-G429-G430-G431-G432-G433-G434-G435-G436-G437-G438-G439-G440-G441-G442-G443-G444-G445-G446-G447-G448-G449-G450-G451-G452-G453-G454-G455-G456-G457-G458-G459-G460-G461-G462-G463-G464-G465-G466-G467-G468-G469-G470-G471-G472-G473-G474-G475-G476-G477-G478-G479-G480-G481-G482-G483-G484-G485-G486-G487-G488-G489-G490-G491-G492-G493-G494-G495-G496-G497-G498-G499-G500-G501-G502-G503-G504-G505-G506-G507-G508-G509-G510-G511-G512-G513-G514-G515-G516-G517-G518-G519-G520-G521-G522-G523-G524-G525-G526-G527-G528-G529-G530-G531-G532-G533-G534-G535-G536-G537-G538-G539-G540-G541-G542-G543-G544-G545-G546-G547-G548-G549-G550-G551-G552-G553-G554-G555-G556-G557-G558-G559-G560-G561-G562-G563-G564-G565-G566-G567-G568-G569-G570-G571-G572-G573-G574-G575-G576-G577-G578-G579-G580-G581-G582-G583-G584-G585-G586-G587-G588-G589-G590-G591-G592-G593-G594-G595-G596-G597-G598-G599-G600-G601-G602-G603-G604-G605-G606-G607-G608-G609-G610-G611-G612-G613-G614-G615-G616-G617-G618-G619-G620-G621-G622-G623-G624-G625-G626-G627-G628-G629-G630-G631-G632-G633-G634-G635-G636-G637-G638-G639-G640-G641-G642-G643-G644-G645-G646-G647-G648-G649-G650-G651-G652-G653-G654-G655-G656-G657-G658-G659-G660-G661-G662-G663-G664-G665-G666-G667-G668-G669-G670-G671-G672-G673-G674-G675-G676-G677-G678-G679-G680-G681-G682-G683-G684-G685-G686-G687-G688-G689-G690-G691-G692-G693-G694-G695-G696-G697-G698-G699-G700-G701-G702-G703-G704-G705-G706-G707-G708-G709-G710-G711-G712-G713-G714-G715-G716-G717-G718-G719-G720-G721-G722-G723-G724-G725-G726-G727-G728-G729-G730-G731-G732-G733-G734-G735-G736-G737-G738-G739-G740-G741-G742-G743-G744-G745-G746-G747-G748-G749-G750-G751-G752-G753-G754-G755-G756-G757-G758-G759-G760-G761-G762-G763-G764-G765-G766-G767-G768-G769-G770-G771-G772-G773-G774-G775-G776-G777-G778-G779-G780-G781-G782-G783-G784-G785-G786-G787-G788-G789-G790-G791-G792-G793-G794-G795-G796-G797-G798-G799-G800-G801-G802-G803-G804-G805-G806-G807-G808-G809-G810-G811-G812-G813-G814-G815-G816-G817-G818-G819-G820-G821-G822-G823-G824-G825-G826-G827-G828-G829-G830-G831-G832-G833-G834-G835-G836-G837-G838-G839-G840-G841-G842-G843-G844-G845-G846-G847-G848-G849-G850-G851-G852-G853-G854-G855-G856-G857-G858-G859-G860-G861-G862-G863-G864-G865-G866-G867-G868-G869-G870-G871-G872-G873-G874-G875-G876-G877-G878-G879-G880-G881-G882-G883-G884-G885-G886-G887-G888-G889-G890-G891-G892-G893-G894-G895-G896-G897-G898-G899-G900-G901-G902-G903-G904-G905-G906-G907-G908-G909-G910-G911-G912-G913-G914-G915-G916-G917-G918-G919-G920-G921-G922-G923-G924-G925-G926-G927-G928-G929-G930-G931-G932-G933-G934-G935-G936-G937-G938-G939-G940-G941-G942-G943-G944-G945-G946-G947-G948-G949-G950-G951-G952-G953-G954-G955-G956-G957-G958-G959-G960-G961-G962-G963-G964-G965-G966-G967-G968-G969-G970-G971-G972-G973-G974-G975-G976-G977-G978-G979-G980-G981-G982-G983-G984-G985-G986-G987-G988-G989-G990-G991-G992-G993-G994-G995-G996-G997-G998-G999-G1000-G1001-G1002-G1003-G1004-G1005-G1006-G1007-G1008-G1009-G1010-G1011-G1012-G1013-G1014-G1015-G1016-G1017-G1018-G1019-G1020-G1021-G1022-G1023-G1024-G1025-G1026-G1027-G1028-G1029-G1030-G1031-G1032-G1033-G1034-G1035-G1036-G1037-G1038-G1039-G1040-G1041-G1042-G1043-G1044-G1045-G1046-G1047-G1048-G1049-G1050-G1051-G1052-G1053-G1054-G1055-G1056-G1057-G1058-G1059-G1060-G1061-G1062-G1063-G1064-G1065-G1066-G1067-G1068-G1069-G1070-G1071-G1072-G1073-G1074-G1075-G1076-G1077-G1078-G1079-G1080-G1081-G1082-G1083-G1084-G1085-G1086-G1087-G1088-G1089-G1090-G1091-G1092-G1093-G1094-G1095-G1096-G1097-G1098-G1099-G1100-G1101-G1102-G1103-G1104-G1105-G1106-G1107-G1108-G1109-G1110-G1111-G1112-G1113-G1114-G1115-G1116-G1117-G1118-G1119-G1120-G1121-G1122-G1123-G1124-G1125-G1126-G1127-G1128-G1129-G1130-G1131-G1132-G1133-G1134-G1135-G1136-G1137-G1138-G1139-G1140-G1141-G1142-G1143-G1144-G1145-G1146-G1147-G1148-G1149-G1150-G1151-G1152-G1153-G1154-G1155-G1156-G1157-G1158-G1159-G1160-G1161-G1162-G1163-G1164-G1165-G1166-G1167-G1168-G1169-G1170-G1171-G1172-G1173-G1174-G1175-G1176-G1177-G1178-G1179-G1180-G1181-G1182-G1183-G1184-G1185-G1186-G1187-G1188-G1189-G1190-G1191-G1192-G1193-G1194-G1195-G1196-G1197-G1198-G1199-G1200-G1201-G1202-G1203-G1204-G1205-G1206-G1207-G1208-G1209-G1210-G1211-G1212-G1213-G1214-G1215-G1216-G1217-G1218-G1219-G1220-G1221-G1222-G1223-G1224-G1225-G1226-G1227-G1228-G1229-G1230-G1231-G1232-G1233-G1234-G1235-G1236-G1237-G1238-G1239-G1240-G1241-G1242-G1243-G1244-G1245-G1246-G1247-G1248-G1249-G1250-G1251-G1252-G1253-G1254-G1255-G1256-G1257-G1258-G1259-G1260-G1261-G1262-G1263-G1264-G1265-G1266-G1267-G1268-G1269-G1270-G1271-G1272-G1273-G1274-G1275-G1276-G1277-G1278-G1279-G1280-G1281-G1282-G1283-G1284-G1285-G1286-G1287-G1288-G1289-G1290-G1291-G1292-G1293-G1294-G1295-G1296-G1297-G1298-G1299-G1300-G1301-G1302-G1303-G1304-G1305-G1306-G1307-G1308-G1309-G1310-G1311-G1312-G1313-G1314-G1315-G1316-G1317-G1318-G1319-G1320-G1321-G1322-G1323-G1324-G1325-G1326-G1327-G1328-G1329-G1330-G1331-G1332-G1333-G1334-G1335-G1336-G1337-G1338-G1339-G1340-G1341-G1342-G1343-G1344-G1345-G1346-G1347-G1348-G1349-G1350-G1351-G1352-G1353-G1354-G1355-G1356-G1357-G1358-G1359-G1360-G1361-G1362-G1363-G1364-G1365-G1366-G1367-G1368-G1369-G1370-G1371-G1372-G1373-G1374-G1375-G1376-G1377-G1378-G1379-G1380-G1381-G1382-G1383-G1384-G1385-G1386-G1387-G1388-G1389-G1390-G1391-G1392-G1393-G1394-G1395-G1396-G1397-G1398-G1399-G1400-G1401-G1402-G1403-G1404-G1405-G1406-G1407-G1408-G1409-G1410-G1411-G1412-G1413-G1414-G1415-G1416-G1417-G1418-G1419-G1420-G1421-G1422-G1423-G1424-G1425-G1426-G1427-G1428-G1429-G1430-G1431-G1432-G1433-G1434-G1435-G1436-G1437-G1438-G1439-G1440-G1441-G1442-G1443-G1444-G1445-G1446-G1447-G1448-G1449-G1450-G1451-G1452-G1453-G1454-G1455-G1456-G1457-G1458-G1459-G1460-G1461-G1462-G1463-G1464-G1465-G1466-G1467-G1468-G1469-G1470-G1471-G1472-G1473-G1474-G1475-G1476-G1477-G1478-G1479-G1480-G1481-G1482-G1483-G1484-G1485-G1486-G1487-G1488-G1489-G1490-G1491-G1492-G1493-G1494-G1495-G1496-G1497-G1498-G1499-G1500-G1501-G1502-G1503-G1504-G1505-G1506-G1507-G1508-G1509-G1510-G1511-G1512-G1513-G1514-G1515-G1516-G1517-G1518-G1519-G1520-G1521-G1522-G1523-G1524-G1525-G1526-G1527-G1528-G1529-G1530-G1531-G1532-G1533-G1534-G1535-G1536-G1537-G1538-G1539-G1540-G1541-G1542-G1543-G1544-G1545-G1546-G1547-G1548-G1549-G1550-G1551-G1552-G1553-G1554-G1555-G1556-G1557-G1558-G1559-G1560-G1561-G1562-G1563-G1564-G1565-G1566-G1567-G1568-G1569-G1570-G1571-G1572-G1573-G1574-G1575-G1576-G1577-G1578-G1579-G1580-G1581-G1582-G1583-G1584-G1585-G1586-G1587-G1588-G1589-G1590-G1591-G1592-G1593-G1594-G1595-G1596-G1597-G1598-G1599-G1600-G1601-G1602-G1603-G1604-G1605-G1606-G1607-G1608-G1609-G1610-G1611-G1612-G1613-G1614-G1615-G1616-G1617-G1618-G1619-G1620-G1621-G1622-G1623-G1624-G1625-G1626-G1627-G1628-G1629-G1630-G1631-G1632-G1633-G1634-G1635-G1636-G1637-G1638-G1639-G1640-G1641-G1642-G1643-G1644-G1645-G1646-G1647-G1648-G1649-G1650-G1651-G1652-G1653-G1654-G1655-G1656-G1657-G1658-G1659-G1660-G1661-G1662-G1663-G1664-G1665-G1666-G1667-G1668-G1669-G1670-G1671-G1672-G1673-G1674-G1675-G1676-G1677-G1678-G1679-G1680-G1681-G1682-G1683-G1684-G1685-G1686-G1687-G1688-G1689-G1690-G1691-G1692-G1693-G1694-G1695-G1696-G1697-G1698-G1699-G1700-G1701-G1702-G1703-G1704-G1705-G1706-G1707-G1708-G1709-G1710-G1711-G1712-G1713-G1714-G1715-G1716-G1717-G1718-G1719-G1720-G1721-G1722-G1723-G1724-G1725-G1726-G1727-G1728-G1729-G1730-G1731-G1732-G1733-G1734-G1735-G1736-G1737-G1738-G1739-G1740-G1741-G1742-G1743-G1744-G1745-G1746-G1747-G1748-G1749-G1750-G1751-G1752-G1753-G1754-G1755-G1756-G1757-G1758-G1759-G1760-G1761-G1762-G1763-G1764-G1765-G1766-G1767-G1768-G1769-G1770-G1771-G1772-G1773-G1774-G1775-G1776-G1777-G1778-G1779-G1780-G1781-G1782-G1783-G1784-G1785-G1786-G1787-G1788-G1789-G1790-G1791-G1792-G1793-G1794-G1795-G1796-G1797-G1798-G1799-G1800-G1801-G1802-G1803-G1804-G1805-G1806-G1807-G1808-G1809-G1810-G1811-G1812-G1813-G1814-G1815-G1816-G1817-G1818-G1819-G1820-G1821-G1822-G1823-G1824-G1825-G1826-G1827-G1828-G1829-G1830-G1831-G1832-G1833-G1834-G1835-G1836-G1837-G1838-G1839-G1840-G1841-G1842-G1843-G1844-G1845-G1846-G1847-G1848-G1849-G1850-G1851-G1852-G1853-G1854-G1855-G1856-G1857-G1858-G1859-G1860-G1861-G1862-G1863-G1864-G1865-G1866-G1867-G1868-G1869-G1870-G1871-G1872-G1873-G1874-G1875-G1876-G1877-G1878-G1879-G1880-G1881-G1882-G1883-G1884-G1885-G1886-G1887-G1888-G1889-G1890-G1891-G1892-G1893-G1894-G1895-G1896-G1897-G1898-G1899-G1900-G1901-G1902-G1903-G1904-G1905-G1906-G1907-G1908-G1909-G1910-G1911-G1912-G1913-G1914-G1915-G1916-G1917-G1918-G1919-G1920-G1921-G1922-G1923-G1924-G1925-G1926-G1927-G1928-G1929-G1930-G1931-G1932-G1933-G1934-G1935-G1936-G1937-G1938-G1939-G1940-G1941-G1942-G1943-G1944-G1945-G1946-G1947-G1948-G1949-G1950-G1951-G1952-G1953-G1954-G1955-G1956-G1957-G1958-G1959-G1960-G1961-G1962-G1963-G1964-G1965-G1966-G1967-G1968-G1969-G1970-G1971-G1972-G1973-G1974-G1975-G1976-G1977-G1978-G1979-G1980-G1981-G1982-G1983-G1984-G1985-G1986-G1987-G1988-G1989-G1990-G1991-G1992-G1993-G1994-G1995-G1996-G1997-G1998-G1999-G2000-G2001-G2002-G2003-G2004-G2005-G2006-G2007-G2008-G2009-G2010-G2011-G2012-G2013-G2014-G2015-G2016-G2017-G2018-G2019-G2020-G2021-G2022-G2023-G2024-G2025-G2026-G2027-G2028-G2029-G2030-G2031-G2032-G2033-G2034-G2035-G2036-G2037-G2038-G2039-G2040-G2041-G2042-G2043-G2044-G2045-G2046-G2047-G2048-G2049-G2050-G2051-G2052-G2053-G2054-G2055-G2056-G2057-G2058-G2059-G2060-G2061-G2062-G2063-G2064-G2065-G2066-G2067-G2068-G2069-G2070-G2071-G2072-G2073-G2074-G2075-G2076-G2077-G2078-G2079-G2080-G2081-G2082-G2083-G2084-G2085-G2086-G2087-G2088-G2089-G2090-G2091-G2092-G2093-G2094-G2095-G2096-G2097-G2098-G2099-G2100-G2101-G2102-G2103-G2104-G2105-G2106-G2107-G2108-G2109-G2110-G2111-G2112-G2113-G2114-G2115-G2116-G2117-G2118-G2119-G2120-G2121-G2122-G2123-G2124-G2125-G2126-G2127-G2128-G2129-G2130-G2131-G2132-G2133-G2134-G2135-G2136-G2137-G2138-G2139-G2140-G2141-G2142-G2143-G2144-G2145-G2146-G2147-G2148-G2149-G2150-G2151-G2152-G2153-G2154-G2155-G2156-G2157-G2158-G2159-G2160-G2161-G2162-G2163-G2164-G2165-G2166-G2167-G2168-G2169-G2170-G2171-G2172-G2173-G2174-G2175-G2176-G2177-G2178-G2179-G2180-G2181-G2182-G2183-G2184-G2185-G2186-G2187-G2188-G2189-G2190-G2191-G2192-G2193-G2194-G2195-G2196-G2197-G2198-G2199-G2200-G2201-G2202-G2203-G2204-G2205-G2206-G2207-G2208-G2209-G2210-G2211-G2212-G2213-G2214-G2215-G2216-G2217-G2218-G2219-G2220-G2221-G2222-G2223-G2224-G2225-G2226-G2227-G2228-G2229-G2230-G2231-G2232-G2233-G2234-G2235-G2236-G2237-G2238-G2239-G2240-G2241-G2242-G2243-G2244-G2245-G2246-G2247-G2248-G2249-G2250-G2251-G2252-G2253-G2254-G2255-G2256-G2257-G2258-G2259-G2260-G2261-G2262-G2263-G2264-G2265-G2266-G2267-G2268-G2269-G2270-G2271-G2272-G2273-G2274-G2275-G2276-G2277-G2278-G2279-G2280-G2281-G2282-G2283-G2284-G2285-G2286-G2287-G2288-G2289-G2290-G2291-G2292-G2293-G2294-G2295-G2296-G2297-G2298-G2299-G2300-G2301-G2302-G2303-G2304-G2305-G2306-G2307-G2308-G2309-G2310-G2311-G2312-G2313-G2314-G2315-G2316-G2317-G2318-G2319-G2320-G2321-G2322-G2323-G2324-G2325-G2326-G2327-G2328-G2329-G2330-G2331-G2332-G2333-G2334-G2335-G2336-G2337-G2338-G2339-G2340-G2341-G2342-G2343-G2344-G

Two reactions dominate the gasification of char. The rate at which these equations occur is a function of temperature and reactant and product concentration. As the gases move down through the upper bed, the char reacts with the gases fueled by the internal heat evolved from the partial combustion of the gases in the upper section of the gasifier. The gasification reactions slow down as the temperature of the bed and concentration of carbon decreases. To determine the gas composition exiting the upper bed, the rates for these two equations must be evaluated to find the amount of reactants consumed and amount of products produced. For accuracy, the rate equations are evaluated at different points within the bed. This is done by calculating the rate per unit volume with the conditions and selecting a volume to "step" through the bed and calculate the heat absorbed by the gasification reactions. By iterating the temperature at the end of the volumetric step, we can balance the heat absorbed by the reactions with the heat released by the products of the reactions and inerts as they cool from the initial temperature to the final (iterated) temperature. Upon balancing heat, all variables within the rate equations are re-calculated and the process repeated by selecting larger volumetric steps until the final temperature reaches a predetermined gas exit temperature.

Step One through upper bed

	Last iteration values		
*Volumetric Step (select between 2000 and 5000 ccm)	1466.225974	1413.51293 iteration formula	
	3397.568	3768.902 ccm	
	2179.206753	2084 F	
*Predicted Temp after First Step (iterate Temp)	1405.803119	1413.51293 Kiterate to within +/- 1,000 Btu/hr	

Heat Released by Bed Cooling	2276950.66	3337522 Btu/hr	
Heat Absorbed by Gasification Reactions	2276950.569	3337522 Btu/hr	
	-0.09099674	0 Btu/hr	Difference

Step Two through upper bed

*Volumetric Step (select between 4000 and 15000 ccr)	1371.852569	1325.41050 iteration formula	
	10677.73333	11776.6 ccm	
	2009.334625	1926 F	
*Predicted Temp after Second Step (iterate Temp)	1322.306011	1325.41050 Kiterate to within +/- 1,000 Btu/hr	

Heat Released by Bed Cooling	3168950.672	2369312 Btu/hr	
Heat Absorbed by Gasification Reactions	3168950.665	2369312 Btu/hr	
	-0.00657716	0 Btu/hr	Difference

Step Three through upper bed

*Volumetric Step (select between 8000 and 45000 ccr)	1296.024886	1252.26722 iteration formula	
	31469.09333	34707.64 ccm	
	1872.844795	1794 F	
*Predicted Temp after Third Step (iterate Temp)	1247.847017	1252.26722 Kiterate to within +/- 1,000 Btu/hr	

Heat Released by Bed Cooling	2501434.795	1929246 Btu/hr	
Heat Absorbed by Gasification Reactions	2501434.785	1929246 Btu/hr	
	-0.00498772	0 Btu/hr	Difference

Step Four through upper bed (stay above 1700°F)

*Volumetric Step (select between 16000 and 135000)	1237.66423	1199.68117 iteration formula	
	85566.6	94989.9 ccm	
	1767.795615	1699 F	
*Predicted Temp after Fourth Step (iterate Temp)	1194.07830	1199.68117 Kiterate to within +/- 1,000 Btu/hr	

Heat Released by Bed Cooling	1899709.376	1367116 Btu/hr	
Heat Absorbed by Gasification Reactions	1899709.374	1367116 Btu/hr	
	-0.0022529	0 Btu/hr	Difference

Step Five through upper bed (go for approx. 1750 F, stay above 1700°F)

*Volumetric Step (select between 32000 and 405000)	1175.22164	1173.71169 iteration formula	
	323102.1667	225000 ccm	
	1655.398953	1653 F	
*Predicted Temp after Fifth Step (iterate Temp)	1161.46106	1173.71169 Kiterate to within +/- 1,000 Btu/hr	

Heat Released by Bed Cooling	2008708.379	669423 Btu/hr	
Heat Absorbed by Gasification Reactions	2008708.376	669423 Btu/hr	

..... -0.00391865 0 Btu/hr Difference

Step Six through upper bed

*Volumetric Step (select between 64000 and 1215000 1174.786878
 64469.33333
 1654.616381
 *Predicted Temp after Sixth Step (Iterate Temp) 1181.41290
 Heat Released by Bed Cooling 13914.93086
 Heat Absorbed by Gasification Reactions 13914.94391
 0.013055852

Step Seven through upper bed

*Volumetric Step (Iterate volumetric step) 1174.683486
 17088
 1654.430274
 *Predicted Temp after Seventh Step 1181.40797
 Heat Released by Bed Cooling 3309.003567
 Heat Absorbed by Gasification Reactions 3309.008182
 0.00461485

LOWER BED CALCULATIONS

*Air/Coal Ratio for air to grate (Range = 0.3 to 0.9) Air/Carbon (Above Grate) 4.08
 *Temperature of Air Injected into grate of Gas/Steam/Carbon (Above Grate) = 0.92
 *Steam to Air Ratio for steam input to grate (typ range is 0.14 bit, 0.2 for anthr, 0.5 char)
 *Temperature of Steam Injected into grate of Gas/Air/Steam (Above Grate) = 4.42
 *Enthalpy of Steam into Grate
 *Peak Temperature in Combustion Section of Gasifier

In order to calculate the gasification reactions in the bottom bed, the bed will be viewed from the grate up to the exit. Initially, we look at the temperature rise caused by the incoming steam/air mixture cooling down the exiting ash. Iterate steam/air mixture temperature until the heat released by the ash equals the heat absorbed by the steam/air mixture.
 Note: The Ash is cooled from maximum peak temperature of gasifier to entry temperature of air/steam.

*Temperature of air/steam mixture upon contact with 528.566837

Heat Absorbed by Steam/Air Heating
 Heat Released by Ash Cooling
 Difference

Once the steam/air mixture passes the ash cooling zone, the oxygen is assumed to combine with the char to raise the bed temperature high enough to support the gasification reactions in conjunction with the oxidation of carbon. Vary lb/hr of carbon until the heat required to raise the bed temperature to 1700 F is reached. Carbon is iterated until the heat balances.

*Carbon Consumed Available Carbon 4189
 546.8

Heat Released by Oxidation of Carbon to 1700_F
 Heat Absorbed by Bed

Difference

1173.55445 iteration formula

71104 ccm
 1652 F
 1173.55445 Kiterate to within +/- 1,000 Btu/hr

4043 Btu/hr
 4043 Btu/hr
 0 Btu/hr

Difference

1173.53105 iteration formula

18332 ccm
 1652 F
 1173.53105 Kiterate to within +/- 1,000 Btu/hr

602 Btu/hr
 602 Btu/hr
 0 Btu/hr

Difference

1.4251 iteration formula for balancing undergrate air with O2 consumed

1.425 Iterate to within 1% carbon in ash 111.44
 225 F 127.81
 0.226 129 Low-Btu Gas HHV 126.73
 700 F 129.23
 1351.80 E 0.43% Carbon in Ash (wt%)
 2500 F 0.00 lb/hr O2

533.82800 iteration formula

533.82800 Iterate to within +/- 1,000 Btu/hr

1228815 Btu/hr
 1228815 Btu/hr
 0 Btu/hr

612.44470 iteration formula

51%
 612.44470 Iterate to within +/- 1,000 Btu/hr

8632002 Btu/hr
 8632002 Btu/hr
 0 E Adding 100 # C Reduces This 1.3-mil

Once 1700 F is met, the gasification reactions now begin in conjunction with the oxidation of carbon. Here, again, we iterate volume to determine reaction rates, and then iterate temperature until the heat released/absorbed by the reactions equals the heat released/absorbed by the bed. This process is done until the final gas temperature is reached. Finally, carbon conversion is computed. If the carbon conversion is unacceptable, change air input and redo lower bed iterations.

Step One through lower bed

Volumetric Step (select between 1000 and 4000 ccm)
(if temp increases above limit, go back & add steam, or reduce air)
*Predicted Temp after First Step (iterate Temp) 1292.77978

Heat Absorbed by Bed Heating
Heat Released by Oxidation Reaction

Difference

0.21 A/C
0.91 S/A
-12.54 O2

1293.14371 iteration formula
1218.945313 ccm
1868 F
1293.14371 K iterate to within +/- 1,000 Btu/hr

0.21 A/C
0.84 S/A
-1.94 O2

1459512 Btu/hr
1459512 Btu/hr
0 EAdding 10_K Increases This by 150k

Step Two through lower bed

*Volumetric Step (iterate volume to get to peak temp) 4838.061985
Predicted Temp after Second Step 1533.3

Heat Released by Bed Cooling
Heat Absorbed by Gasification Reactions

Difference

0.21 A/C
0.79 S/A
-5.25 O2

5437.61083 iteration formula
5437.61083 ccm iterate to within +/- 1,000 Btu/hr
2500 F varies With Ash Fusion Characteristics
1644.4 K
6053613 Btu/hr
6053613 Btu/hr
0 EAdding 1000 ccm Decreases This by 700k

0.22 A/C
0.88 S/A
-1.14 O2

Step Three through lower bed

Volumetric Step (select between 1000 and 6000 ccm)

*Predicted Temp after Third Step 1539.83090

Heat Released by Bed Cooling
Heat Absorbed by Gasification Reactions

Difference

0.23 A/C
0.92 S/A
-21.8 O2

1552.48130 iteration formula
1167.96875 ccm
2334 F
1552.48130 K iterate to within +/- 1,000 Btu/hr
1691821 Btu/hr
1691821 Btu/hr
0 EAdding 10_K Decreases This by 150k

0.23 A/C
0.86 S/A
-0.23 O2

Step Four through lower bed

Volumetric Step (select between 2000 and 18000 ccm)

*Predicted Temp after Fourth Step (iterate Temp) 1472.89351

Heat Released by Bed Cooling
Heat Absorbed by Gasification Reactions

Difference

0.23 A/C
0.85 S/A
-0.64 O2

1477.18494 iteration formula
3333 ccm
2199 F
1477.18494 K iterate to within +/- 1,000 Btu/hr
1436771 Btu/hr
1436772 Btu/hr
0 EAdding 10_K Decreases This by 150k

0.23 A/C
0.87 S/A
0.99 O2
6.51 Ash Carbon

Step Five through lower bed

*Volumetric Step (iterate until all oxygen is consumed 9842.436614
(if negative, go back & add more O2)
lb/hr of Oxygen 0.00 lb/hr

*Predicted Temp after Fifth Step (iterate Temp) 1394.42812

Heat Released by Bed Cooling
Heat Absorbed by Gasification Reactions

Difference

0.25 A/C
0.86 S/A
0.86 O2
3.85 Ash Carbon

11103.81393 iteration formula
11103.81393 ccm iterate to within 0.0-0.5 lb/hr of O2
Adding 300 ccm Decreases This by 5#
1403.11399 iteration formula
2066 F
1403.11399 K iterate to within +/- 1,000 Btu/hr
1516506 Btu/hr
1516506 Btu/hr
0 EAdding 10_K Decreases This by 180k

0.26 A/C
0.86 S/A
-1.79 O2
1.2 Ash Carbon
0.26 A/C
0.85 S/A
0.02 O2

Step Six through lower bed

Volumetric Step (select between 4000 and 85000 ccm)

*Predicted Temp after Sixth Step (iterate Temp)

Heat Released by Bed Cooling
Heat Absorbed by Gasification Reactions

Step Seven through lower bed

*Volumetric Step (iterate volumetric step)

Predicted Temp after Seventh Step

Heat Released by Bed Cooling
Heat Absorbed by Gasification Reactions

Carbon in Ash (wt%):

0%

Temperature (°F) Top to Middle

% of Vol

Temperature (°F) Bottom to Middle

Temperature (°F) Pyrolyzer

% of Vol

Char Temp Top to Middle

Char Temp Bot to Mid

Coal Temp Feed to Pyro

Bed Temperature Profile

Step 1

Step 2

Step 3

Step 4

Step 5

Step 6

Step 7

Blend

83%

78%

77%

76%

71%

61%

58%

57%

55%

2302

2084

1926

1794

1699

1653

1652

1587

534

150

150

1600

1600

1600

1600

1600

1600

1600

1600

1600

1600

1600

1600

1600

1600

1600

1600

1600

1600

1600

1600

1600

1600

1600

1600

1600

ial Volume (to Kinetic Limits) (cc)

Total Gasif Inner Annulus Vol (cc)

459679 16.23 cu ft need

537527 assuming 6 ft h 86%

18.98 cu ft for vert wall pyrolyzer

29.86 calculated cu ft vol with increasing pyrolyzer tube diameter

*Input Moisture of Gas to HGU

*Input Final Temperature of Gas

Steam Injection Required

Water Injection Required

PHASE II, Hot Gas Cleanup Unit (HGU) Input Data & References

* PDU Capacity

PDU vs GPIF Size (Ref:DOE 2/23/93, Table 3, Page 6)

*Zinc Titanate/Ferite (Ref:DOE 2/23/93, Table 3, Page -9-)

*Spent Zinc Titanate/Ferite (Ref: DOE 2/23/93, Table 3, Page -9-)

*Process Air (Ref: DOE 2/23/93, Table 3, Page -9-, then make SO₂vol=12%)

Ratio of Wgt% SO₂ to vol% SO₂ (Skinner 3/8/93)le 34/12 ---->

*Process Steam (Ref: DOE 2/23/93, Table 3, Page -9-)

*Process Steam (Scaled Up From PDU to GPIF)

*Process Steam (Ref: DOE Blissett 8/15/90)

*Process Steam (Scaled Up From PDU to GPIF)

*Process Steam (Select Either Reference Above, K568 or K570)

PAGE SETUP: 51% FOR MASS E

PAGE SETUP: 72% FOR INPUT

Total Heat needed from Water-Gas Shift

Equation
 $\text{CO} + \text{H}_2\text{O} \rightarrow \text{CO}_2 + \text{H}_2$
 Heat Released
 17708.6 Btu/mol
 402.38 Btu/lb of CO_2

Initial Gases Mass Flows

CO	8,414 lb/hr	300 mols/hr
H ₂ O	2,806 lb/hr	156 mols/hr
CO ₂	4,139 lb/hr	94 mols/hr
H ₂	346 lb/hr	172 mols/hr

Assume 1120 F average temp of absorber
 Constant for water-gas shift reaction - K 0.3710

Mols of CO Initially 300
 Mols of H₂O Initially 156
 Mols of CO₂ Initially 94
 Mols of H₂ Initially 172

$$K = (y_{\text{CO}_2} y_{\text{H}_2} / (y_{\text{H}_2\text{O}} y_{\text{CO}})) = [(2278+z)^2 (2811+z)] / [(1716-z)^2 (5862-z)]$$

following quadratic equation enters ($ax^2 + bx + c = 0$):

a= -0.6290307
 b= -438
 c= 1214

using the quadratic equation to solve

root 1 = -694.152
 root 2 = 2.780

Mols of CO finally	287.6077169	8.336 lb/hr
Mols of H ₂ O finally	152.9656716	2.766 lb/hr
Mols of CO ₂ finally	96.92387827	4.261 lb/hr
Mols of H ₂ finally	174.4189478	352 lb/hr

Heat Released in Water-Gas Shift
 40,227 Btu/hr

1579.72
 0.073
 0.032
 0.180
 0.000
 0.000
 0.057
 0.001
 0.031
 0.374

18.80 Temp (N)
 cp H₂O
 cp CO₂
 cp H₂
 cp O₂
 cp CH₄
 cp CO
 cp Ar
 cp H₂
 Total

Gasification of Char

Gases		Char & Ash	
Predicted Temperature	1000.00 K	Sensible heat	
		Temp of coal (K)	1000.00
delta h CO2	-270.03 Btu/lbm	C - delta h	-448.40 Btu/lbm
delta h CO	-250.03 Btu/lbm	ASH - delta h	-292.50 Btu/lbm
delta h H2O	-531.16 Btu/lbm	Total of coal	-337.97 Btu/lbm
delta h H2	-3374.08 Btu/lbm	Total heat	(1,080,353) Btu/hr
delta h CH4	-1130.96 Btu/lbm		
delta h H2S	-311.15 Btu/lbm		
delta h N2	-247.03 Btu/lbm		
delta h Ar	-109.89 Btu/lbm		
delta h NH3	-783.53 Btu/lbm		
Total	(13,794,115)		
	(14,674,466)		
	(7,115,829)		
	2001.37259		

Heat of reactions (Btu/hr)		HEAT OF FORMATION	
CO	0 LB/HR	Btu/mol	Btu/lbm
C	0 LB/HR	-17708.00	-402.38
CO	0 LB/HR	-32200.20	-2007.24
CO2	0 lb/hr	50407.40	2016.00
2,301 lb/hr		74198.00	2048.91
			7758639

CARBON AVAILABLE	2113.24
CARBON USED	628.00
HEAT RELEASED	7,758,639
HEAT ABSORBED	-1487,468
TEMP CALC	2001
TEMP EST	1800.2

Initial Conditions at the Top of Gasifier

P_{H_2O} 3.56 P_{H_2} 4.06
 P_{CO} 6.97 P_{CO_2} 2.27

$Temp(K) = 1580$
 $Density\ of\ Coal\ (lbm/ft^3)$ 40
 (g/cm^3) 0.641

$carbon\ in\ char/ash\ (lb/hr)$ 3.508
 $ash\ in\ char/ash\ (lb/hr)$ 1.802
Total 5.310

$Percent\ Carbon\ in\ Char/Ash$ 66.07%
 $Bed\ Voltage$ 12.00%
 $Concentration\ of\ Carbon\ (gmol/ccm)$ 0.373
 $Volumetric\ Step$ 4000 ccm



$rate = 930e^{(-45,000/(RT))} [C]^r [P_{H_2O} \cdot P_{H_2O}]$
 where : $P_{H_2O} = P_{H_2} \cdot P_{CO} / e^{(17.29-16330/T)}$

First Iteration:

$P_{H_2O} = 0.027$
 $rate = 0.00072999\ g\text{-mol/ccm-sec}$


After First Volumetric Step:

$rate = 2.90274428\ g\text{-mol/sec}$
 $C\ Consumed$ 276.69 lb/hr
 $H_2O\ Consumed$ 415.02 lb/hr
 $CO\ Made$ 845.28 lb/hr
 $H_2\ Made$ 46.44 lb/hr

Totals:

CO 9,799
 H_2 308
 CO_2 3,819
 H_2O 2,341
 H_2S 358
 N_2 27,725
 Ar 485
 NH_3 156
Total 44,882

lb/hr 349.84
 $moles/hr$ 197.46
 $wt\%$ 8.00%
 $mol\%$ 8.00%
 $wt\%$ 5.22%
 $mol\%$ 0.80%
 $wt\%$ 61.77%
 $mol\%$ 1.06%
 $wt\%$ 0.35%
 $mol\%$ 100.00%



$rate = 930e^{(-45,000/(RT))} [C]^r [P_{CO_2} \cdot P_{CO_2}]$
 where : $P_{CO_2} = P_{CO} \cdot 2 / e^{(20.82-20260/T)}$

$P_{CO_2} = 0.015$
 $rate = 0.0004598\ g\text{-mol/ccm-sec}$

$rate = 1.8391849\ g\text{-mol/sec}$

$C\ Consumed$ 175.31 lb/hr
 $CO_2\ Consumed$ 842.40 lb/hr
 $CO\ Made$ 817.71 lb/hr

Heat Absorbed During Reactions:

Temp after First Step	1470.78 K	3,487,371 Btu/hr	Temp of coal (K)	1470.78
delta h CO2	-84.31 Btu/lbm	(232,736)	C - delta h	-107.98 Btu/lbm
delta h CO	-59.01 Btu/lbm	(576,283)	ASH - delta h	-56.77 Btu/lbm
delta h H2O	-125.90 Btu/lbm	(294,700)	Total of coal	-88.98 Btu/lbm
delta h H2	-764.03 Btu/lbm	(304,139)	Total heat	(432,285) Btu/hr
delta h CH4	-279.66 Btu/lbm	0		
delta h H2S	-73.03 Btu/lbm	(28,109)		
delta h H2	-56.17 Btu/lbm	(1,557,410)		
delta h Ar	-24.39 Btu/lbm	(11,835)		
delta h NH3	-187.78 Btu/lbm	(29,623)		
Total		(3,034,634)		
		(3,487,119)		

Second Iteration

Conditions		
PH2O	2.98 PH2	4.53
PO2	8.02 PO2	1.88
Temp(K) =	1471	40
Density of Coal (lbm/ft3)		0.841
carbon in char/ash (lb/hr)		3,056
ash in char/ash (lb/hr)		1,802
Total		4,858
Percent Carbon in Char/Ash		62.91%
Bed Volume		12.00%
Concentration of Carbon (gmol/ccm)		0.355
Volumetric Step		12000 ccm



rate = $930e^{(-45,000/(RT))} [C]^{1/2} (PH_2O \cdot P^{1/2} H_2O)$
 where : $P^{1/2} H_2O = PH_2 \cdot PO_2 (e^{(17.29-16330/T)})$

rate = $930e^{(-45,000/(RT))} [C]^{1/2} (PCO_2 \cdot P^{1/2} CO_2)$
 where : $P^{1/2} CO_2 = PCO_2^2 (e^{(20.82-20280/T)})$

Second Iteration:

PH2O =	0.075	P^{1/2} CO2 =	0.051
rate =	0.00019508 g-mol/ccm-sec	rate =	0.0001232 g-mol/ccm-sec

After Second Volumetric Step:

rate =	2.34094957 g-mol/sec	rate =	1.4781292 g-mol/sec
C Consumed	223.14 lb/hr	C Consumed	140.90 lb/hr
H2O Consumed	334.70 lb/hr	CO2 Consumed	516.29 lb/hr
CO Made	520.40 lb/hr	CO Made	857.18 lb/hr
H2 Made	37.46 lb/hr		

Totals:

	lb/hr	mole/hr	wt%	mole%	lb/hr	wt%
CO	10,977	391.68	24.26%	21.63%	2,692	59.90%
H ₂	436	216.04	0.96%	11.93%	1,802	40.10%
CO ₂	3,103	70.50	8.86%	3.89%	4,494	100.00%
H ₂ O	2,006	111.35	4.43%	6.15%		
H ₂ S	366	10.49	0.79%	0.56%		
N ₂	27,725	989.73	61.28%	54.84%		
Ar	465	12.14	1.07%	0.67%		
N ₂ O	186	9.26	0.35%	0.51%		
Total	45,246	1,811	100.00%	100.00%		

Heat Absorbed During Reactions:

	lb/hr	mole/hr	wt%	mole%	lb/hr	wt%
Temp after Second Step	1381.17 K					
delta h CO ₂	-51.97 Btu/lbm	(160,926)			1381.17	
delta h CO	-47.87 Btu/lbm	(525,404)			-85.25 Btu/lbm	
delta h H ₂ O	-96.93 Btu/lbm	(200,456)			-46.44 Btu/lbm	
delta h H ₂	-82.14 Btu/lbm	(270,980)			-89.89 Btu/lbm	
delta h CH ₄	-218.80 Btu/lbm	0			(313,166) Btu/hr	
delta h H ₂ S	-56.36 Btu/lbm	(20,875)				
delta h N ₂	-48.84 Btu/lbm	(1,285,452)				
delta h Ar	-20.07 Btu/lbm	(8,736)				
delta h N ₂ O	-148.56 Btu/lbm	(23,437)				
Total		(2,477,247)				
		(2,790,412)				

Third Iteration

Conditions			
PH ₂ O	2.51 PH ₂	4.87	
PO ₂	6.93 PO ₂	1.59	
Temp(K) =	1381		
Density of Coal (lbm/ft ³)		40	
carbon in char/ash (lb/hr)		0.841	
ash in char/ash (lb/hr)		2.882	
Total		1,902	
		4,494	
Percent Carbon in Char/Ash		59.90%	
Bed Voltage		12.00%	
Concentration of Carbon (gmol/ccm)		0.336	
Volumetric Step		36000 ccm	

C + H₂O → CO + H₂

rate = $930e^{-(45,000/(RT))} [C]^2 [PH_2O-P^*H_2O]$
 where : $P^*H_2O = PH_2^2 P^*CO / (e^{-(17.29-16330/T)})$

Third Iteration:

PH₂O = 0.182
 rate = 5.4605E-05 g-mol/ccm-sec

CO₂ + C → 2CO

rate = $930e^{-(45,000/(RT))} [C]^2 [PCO_2-P^*CO_2]$
 where : $P^*CO_2 = PCO^2 / (e^{-(20.92-20280/T)})$

P^*CO₂ = 0.153
 rate = 3.881E-05 g-mol/ccm-sec

After Third Volumetric Step:

rate =	1.97299422 g-mol/sec	rate =	1.2172801 g-mol/sec
C Consumed	188.07 lb/hr	C Consumed	118.03 lb/hr
H2O Consumed	282.09 lb/hr	CO2 Consumed	425.18 lb/hr
CO Made	438.60 lb/hr	CO Made	541.21 lb/hr
H2 Made	31.67 lb/hr		
Totals:			
CO	11,956 lb/hr	wt%	28.25%
H2	487 lb/hr	mol%	23.24%
CO2	2,877 lb/hr	wt%	1.03%
H2O	1,724 lb/hr	wt%	5.86%
H2S	356 lb/hr	wt%	3.78%
N2	27,725 lb/hr	wt%	0.78%
Ar	485 lb/hr	wt%	60.87%
NH3	158 lb/hr	wt%	1.07%
Total	45,580 lb/hr	wt%	0.35%
		wt%	100.00%

Heat Absorbed During Reactions:

Temp after Third Step	1305.41 K	2,319,122 Btu/hr	1,980 F
delta h CO2	-43.11 Btu/lbm		
delta h CO	-39.98 Btu/lbm		
delta h H2O	-82.08 Btu/lbm		
delta h H2	-82.40 Btu/lbm		
delta h CH4	-176.71 Btu/lbm		
delta h H2S	-48.17 Btu/lbm		
delta h N2	-38.18 Btu/lbm		
delta h Ar	-18.97 Btu/lbm		
delta h NH3	-121.42 Btu/lbm		
Total			
	(115,415)		
	(478,019)		
	(141,458)		
	(243,541)		
	0		
	(17,221)		
	(1,058,585)		
	(8,231)		
	(19,154)		
	(2,081,622)		
	(2,317,992)		

Fourth Iteration

Conditions			
PH2O	2.13 PH2	5.15	
PCO2	9.49 PCO2	1.35	
Temp(K) =	1308	40	
Density of Coal (lbm/ft3)		0.641	
carbon in char/ash (lb/hr)		2,388	
ash in char/ash (lb/hr)		1,802	
Total		4,190	
Percent Carbon in Char/Ash		56.90%	
Bed Volume		12.00%	
Concentration of Carbon (gmol/ccm)		0.321	
Volumetric Step		109000 ccm	



$$rate = 930e^{-(45,000/(RT))} [C]^1 [PH_2O-P^*H_2O]$$

where : $P^*H_2O = PH_2^*PCO/(e^{(17.29-16330/T)})$

Fourth Iteration:

$$P^*H_2O = 0.410$$

$$rate = 1.4841E-05 \text{ g-mol/ccm-sec}$$

After Fourth Volumetric Step:

$$rate = 1.6027852 \text{ g-mol/sec}$$

C Consumed	152.78 lb/hr
H ₂ O Consumed	229.16 lb/hr
CO Made	356.30 lb/hr
H ₂ Made	25.64 lb/hr

Totals:

	lb/hr	mole/hr
CO	12,703	453.50
H ₂	493	244.41
CO ₂	2,371	53.96
H ₂ O	1,495	82.97
H ₂ S	359	10.49
N ₂	27,725	989.73
Ar	465	12.14
N ₂ O	156	9.26
Total	46,787	1,856



$$rate = 930e^{-(45,000/(RT))} [C]^1 [P^*CO_2-P^*CO_2]$$

where : $P^*CO_2 = PCO_2^2/(e^{(20.92-20260/T)})$

$$P^*CO_2 = 0.413$$

$$rate = 8.119E-06 \text{ g-mol/ccm-sec}$$

$$rate = 0.8768808 \text{ g-mol/sec}$$

C Consumed	83.59 lb/hr
CO ₂ Consumed	306.28 lb/hr
CO Made	389.96 lb/hr

	wt%	mole%	lb/hr	wt%
C	27.74%	24.43%	2,151	84.42%
ASH	1.06%	13.17%	1,802	45.58%
Total	5.16%	2.90%	3,953	100.00%
C	3.26%	4.47%		
ASH	0.76%	0.57%		
Total	60.35%	53.31%		
C	1.06%	0.85%		
ASH	0.34%	0.50%		
Total	100.00%	100.00%		

Heat Absorbed During Reactions:

	Temp after Fourth Step	1247.39 K
delta h CO ₂	-32.55 Btu/lbm	(77,181)
delta h CO	-30.32 Btu/lbm	(385,130)
delta h H ₂ O	-61.42 Btu/lbm	(91,807)
delta h H ₂	-396.50 Btu/lbm	(195,371)
delta h CH ₄	-130.32 Btu/lbm	0
delta h H ₂ S	-36.15 Btu/lbm	(12,925)
delta h N ₂	-29.99 Btu/lbm	(803,793)
delta h Ar	-12.99 Btu/lbm	(6,303)
delta h H ₂ O	-90.40 Btu/lbm	(14,261)
Total		(1,586,771)
		(1,751,540)

$$1,751,268 \text{ Btu/hr}$$

$$1,785 \text{ F}$$

Temp of coal (K)	1247.39
C - delta h	-51.66 Btu/lbm
ASH - delta h	-29.76 Btu/lbm
Total of coal	-41.66 Btu/lbm
Total heat	(164,769) Btu/hr

Fifth Iteration
 Conditions
 PH₂O 1.82 PH₂ 5.38
 PCO 9.97 PCO₂ 1.18
 Temp(K) = 1247 40
 Density of Coal (lbm/ft³) 0.641
 carbon in char/ash (lb/hr) 2.151
 ash in char/ash (lb/hr) 1.802
 Total 3.953
 Percent Carbon in Char/ash 54.42%
 Bed Volume 12.00%
 Concentration of Carbon (gmol/ccm) 0.307
 Volumetric Step 1705000 ccm

$C + H_2O \rightarrow CO + H_2$
 $rate = 930e^{-(-45,000/(RT))} [C]^1 [PH_2O-P^*H_2O]$
 where : $P^*H_2O = PH_2-PCO/(e^{-(17.26-16330/T)})$
 $CO_2 + C \rightarrow 2CO$
 $rate = 930e^{-(-45,000/(RT))} [C]^1 [PCO_2-P^*CO_2]$
 where : $P^*CO_2 = PCO^2/(e^{-(20.92-20280/T)})$

Fifth Iteration:
 PH₂O = 0.805
 rate = 3.7830E-06 g-mol/ccm-sec
 After Fifth Volumetric Step:
 rate = 6.400147E4 g-mol/sec
 C Consumed 810.07 lb/hr
 H₂O Consumed 915.07 lb/hr
 CO Made 1422.76 lb/hr
 H₂ Made 102.40 lb/hr

P*CO₂ = 0.940
 rate = 9.023E-07 g-mol/ccm-sec
 rate = 1.538491 g-mol/sec

C Consumed 146.65 lb/hr
 CO₂ Consumed 537.37 lb/hr
 CO Made 684.02 lb/hr

Totals:
 CO 14,809 lb/hr 528.72 mola/hr 31.92% 27.55% C 1,395 lb/hr 43.83%
 H₂ 595 285.21 1.28% 15.38% ASH 1,602 59.37%
 CO₂ 1,834 41.67 3.94% 2.17% Total 3,197 100.00%
 H₂O 590 32.18 1.25% 1.68%
 H₂ 368 10.49 0.77% 0.55%
 N₂ 27,725 989.73 59.57% 51.56%
 Ar 485 12.14 1.04% 0.83%
 N₂ 158 9.28 0.34% 0.46%
 Total 46,543 100.00% 100.00%

Heat Absorbed During Reactions:

Temp after Fifth Step	1088.97 K	4,681,170 Btu/hr	1,500 F	Temp of coal (K)	1088.97
delta h CO2	-88.80 Btu/lbm	(159,170)		C - delta h	-134.00 Btu/lbm
delta h CO	-81.48 Btu/lbm	(1,206,404)		ASH - delta h	-80.50 Btu/lbm
delta h H2O	-161.88 Btu/lbm	(93,830)		Total of coal	-103.84 Btu/lbm
delta h H2	-1070.22 Btu/lbm	(936,931)		Total heat	(331,937) Btu/hr
delta h CH4	-333.72 Btu/lbm	0			
delta h H2S	-85.44 Btu/lbm	(34,125)			
delta h H2	-76.08 Btu/lbm	(2,164,163)			
delta h Ar	-35.48 Btu/lbm	(17,211)			
delta h NH3	-236.42 Btu/lbm	(37,139)			
Total		(4,348,973)			
		(4,880,909)			

Sixth Iteration

Conditions					
PH2O	0.88 PH2	0.28			
PCO	11.25 PCO2	0.89			
Temp(K) =	1089	40			
Density of Coal (lbm/ft3)		0.641			
carbon in char/ash (lb/hr)		1,395			
ash in char/ash (lb/hr)		1,902			
Total		3,197			
Percent Carbon in Char/Ash		43.63%			
Bed Volume		12.00%			
Concentration of Carbon (gmol/ccm)		0.246			
Volumetric Step		0 ccm			



rate = $930e^{(-45,000/(RT))} [C]^n [CO_2 - P \cdot CO_2]$
 where : $P \cdot CO_2 = PCO_2^2 / (e^{(20,92-20290/T)})$

Sixth Iteration:

PH2O =	7.122	
rate =	-1.352E-06 g-mol/ccm-sec	

P·CO2 =	12.720	
rate =	-2.485E-06 g-mol/ccm-sec	

After Sixth Volumetric Step:

rate =	0 g-mol/sec	
C Consumed	0.00 lb/hr	
H2O Consumed	0.00 lb/hr	
CO Made	0.00 lb/hr	
H2 Made	0.00 lb/hr	

rate =	0 g-mol/sec	
C Consumed	0.00 lb/hr	
CO2 Consumed	0.00 lb/hr	
CO Made	0.00 lb/hr	

Totals:

	lb/hr	mole/hr	wt%	mole%	lb/hr	wt%
CO	14,809	528.72	31.82%	27.55%	1,395	43.83%
H ₂	595	295.21	1.28%	15.38%	1,802	56.37%
CO ₂	1,834	41.67	3.94%	2.17%	3,197	100.00%
H ₂ O	590	32.18	1.25%	1.68%		
H ₂ S	368	10.49	0.77%	0.55%		
N ₂	27,725	989.73	59.57%	51.56%		
Ar	485	12.14	1.04%	0.83%		
NH ₃	158	9.26	0.34%	0.48%		
Total	46,843	1,919	100.00%	100.00%		

Heat Absorbed During Reactions:

	1088 K	0 Btu/hr	1,500 F	Temp of coal (K)
Temp after Sixth Step				
delta h CO ₂	0.02 Btu/lbm	30		C - delta h
delta h CO	0.02 Btu/lbm	226		ASH - delta h
delta h H ₂ O	0.03 Btu/lbm	17		Total of coal
delta h H ₂	0.20 Btu/lbm	120		Total heat
delta h CH ₄	0.06 Btu/lbm	0		
delta h H ₂ S	0.02 Btu/lbm	6		
delta h N ₂	0.01 Btu/lbm	408		
delta h Ar	0.01 Btu/lbm	3		
delta h NH ₃	0.04 Btu/lbm	7		
Total		814		1088.00
		875		0.02 Btu/lbm

Seventh Iteration

Conditions	
PH ₂ O	0.68 PH ₂
PO ₂	11.25 PO ₂
Temp(K) =	1088
Density of Coal (lbm/ft ³)	40
carbon in char/ash (lb/hr)	0.841
ash in char/ash (lb/hr)	1,395
Total	1,802
	3,197

Percent Carbon in Char/Ash

Bed Voltage	43.83%
Concentration of Carbon (gmol/ccm)	12.00%
Volumetric Step	0.246
	0 ccm

C + H₂O → CO + H₂

CO₂ + C → 2CO
 rate = $930e^{(-45,000/(RT))} [C]^1 [PCO_2 - P^*CO_2]$
 where : $P^*CO_2 = PCO_2 / (e^{(20,92-20200/T)})$

Seventh Iteration:

P*H ₂ O =	7.119
rate =	-1.352E-06 g-mol/ccm-sec

P*CO₂ = 12.714
 rate = -2.486E-06 g-mol/ccm-sec

After Seventh Volumetric Step:

rate =	0 g-mol/sec	rate =	0 g-mol/sec
C Consumed	0.00 lb/hr	C Consumed	0.00 lb/hr
H2O Consumed	0.00 lb/hr	CO2 Consumed	0.00 lb/hr
CO Made	0.00 lb/hr	CO Made	0.00 lb/hr
H2 Made	0.00 lb/hr		
Totals:			
CO	lb/hr	mole/hr	wt%
H2	14,809	528.72	31.82%
CO2	595	295.21	1.28%
H2O	1,834	41.67	3.94%
H2S	560	32.18	1.25%
N2	358	10.49	0.77%
Ar	27,725	989.73	59.57%
NH3	485	12.14	1.04%
	158	9.26	0.34%
Total	49,843	1,919	100.00%

lb/hr
1,395
1,802
3,197

wt%

43.63%
54.37%
100.00%

Heat Absorbed During Reactions:

Temp after Seventh Step	1089 K	0 Btu/hr	1,500 F	Temp of coal (K)	1089.00
delta h CO2	0.00 Btu/lbm	0		C - delta h	0.00 Btu/lbm
delta h CO	0.00 Btu/lbm	0		ASH - delta h	0.00 Btu/lbm
delta h H2O	0.00 Btu/lbm	0		Total of coal	0.00 Btu/lbm
delta h H2	0.00 Btu/lbm	0		Total heat	0 Btu/hr
delta h CH4	0.00 Btu/lbm	0			
delta h H2S	0.00 Btu/lbm	0			
delta h N2	0.00 Btu/lbm	0			
delta h Ar	0.00 Btu/lbm	0			
delta h NH3	0.00 Btu/lbm	0			
Total					

Ash Cooling & Steam/Air Heating

Combined Stream 12 & 13:

	LB/HR	MOLS/HR	WT%	MOL%
CO2	9	0.20	0.03	0.02
H2O	7498	416.20	29.23	39.91
N2	13706	489.29	53.43	46.92
Ar	240	6.01	0.94	0.58
O2	4198	131.19	16.37	12.58
TOTALS	25651	1042.87	100.00	100.00

ASH COMPOSITION

	LB/HR	MOLS/HR	WT%	MOL%
CARBON*	101	8.38	5.00	20.84
ASH	1911	31.81	95.00	79.16
TOTALS	2012	40.19	100.00	100.00

COMBUSTION ZONE TEMPERATURE IN GASIFIER =

2400 F
1589 K

ASH EXIT TEMPERATURE =

424 F
491 K

AIR/STEAM ENTRANCE TEMPERATURE =

423.94755 F
491 K

HEAT RELEASED IN COOLING EXITING ASH:

SENSIBLE HEAT

C - delta h	-862.92	Btu/lbm	CO2	34.81 Btu/lbm	301 Btu/hr
ASH - delta T	-539.81	Btu/lbm	H2O	66.53 Btu/lbm	498854 Btu/hr
TOTAL	-555.96	Btu/lbm	N2	34.67 Btu/lbm	475173 Btu/hr
Total Heat	-1118614	Btu/hr	Ar	17.19 Btu/lbm	4124 Btu/hr
			O2	33.39 Btu/lbm	140162 Btu/hr
			TOTALS		1118614 Btu/hr

TOTALS

Temperature of air/steam leaving ash bed =

567.8347769 K
562 F

0 Btu/hr difference

Calculation of Mean Cp of gases during combustion
 Initial Temp 562 F 1700 F
 568 K 1200 K

Gases	Btu/hr
delta h CO2	322.55 Btu/lbm 852788
delta h CO	311.21 Btu/lbm 0
delta h H2O	596.54 Btu/lbm 4472713
delta h H2	4140.67 Btu/lbm 0
delta h CH4	1099.81 Btu/lbm 0
delta h H2S	346.69 Btu/lbm 0
delta h N2	299.94 Btu/lbm 4111049
delta h Ar	141.57 Btu/lbm 33970
delta h NH3	819.76 Btu/lbm 0
delta h O2	292.40 Btu/lbm 666623
Total	10137144

Combustion Equations above ash bed:

C	+	O2	----->		
719 lb/hr			1918 lb/hr	CO2	2635 lb/hr
C	+	1/2 O2	----->	CO	0 lb/hr
0 lb/hr			0 lb/hr		0

Heat absorber 10137144 Btu/hr
 Heat Release -10137102 Btu/hr

Gas Composition after Combustion Zone

	LB/HR	MOLS/HR	WT%	MOL%	LB/HR	MOLS/HR	WT%	MOL%
CO2	2644	60.08	10.03	5.76	820	68.26	30.02	68.21
H2O	7498	416.20	28.44	39.91	1911	31.81	69.98	31.79
N2	13706	489.29	51.98	46.92	2731	100.07	100.00	100.00
Ar	240	6.01	0.91	0.58				
O2	2280	71.25	8.65	6.83				
CO	0	0.00	0.00	0.00				
TOTALS	26368	1042.81	100.00	100.00				

Char and Ash Composition

Once 1700 F is met, not only does oxidation of carbon occur, but also the gasification reactions occur

Determination of rate for chemical reactions:

PO2	2.93 atm		
Particle Size	0.635 cm	Part. Voidage	0.5
Film Coef. =	0.000392 (gmole/cm3-s-atm)		
Ash Layer Co	0.0002655 (gmole/cm3-s-atm)	Surface Reaction Rate	0.0055155 (gmole/cm3-s-atm)
Rate	0.0004506 gmole/cm3-s		

Conditions at Combustion Zone		
PH ₂ O	17.11	PH ₂
PCO	0.00	PCO ₂
Temp(K) =	1200	
Density of Coal (lbm/ft ³)		40
		0.641
carbon in char/ash (lb/hr)		820
ash in char/ash (lb/hr)		1911
		2731
Total		
Percent Carbon in Char/Ash		30.02%
Bed Voidage		38.00%
Concentration of Carbon (gmol/ccm)		0.119
Volumetric Step		1219.287109 ccm
C + H ₂ O → CO + H ₂		CO ₂ + C → 2CO
rate = $930e^{(-45,000/(RT))} [C]^*(PH_2O-P^*H_2O)$		rate = $930e^{(-45,000/(RT))} [C]^*(PCO_2-P^*CO_2)$
where : $P^*H_2O = PH_2^*PCO/(e^{(17.29-16330/T)})$		where : $P^*CO_2 = PCO^*2/(e^{(20.92-20280/T)})$
First Iteration:		
P^*H ₂ O =	0.000	P^*CO ₂ =
rate =	1.194E-05 g-mol/ccm-sec	rate =
After First Volumetric Step:		rate =
rate =	0.0145634 g-mol/sec	rate =
C Consumed	1.39 lb/hr	C Consumed
H ₂ O Consumed	2.08 lb/hr	CO ₂ Consumed
CO Made	3.24 lb/hr	CO Made
H ₂ Made	0.23 lb/hr	
C + O ₂ → CO ₂		
rate =	0.5494477 g-mol/sec	
C Consumed	52.37 lb/hr	
O ₂ Consumed	139.54 lb/hr	
CO ₂ Made	191.91 lb/hr	

Totals:

CO	lb/hr	4	mols/hr	0.15	wt%	0.02%	mol%	0.01% C	lb/hr	874	wt%	31.37%
H ₂		0		0.12		0.00%		0.01% ASH		1911		68.63%
CO ₂		2835		64.42		10.73%		6.18% Total		2785		100.00%
H ₂ O		7496		416.08		28.37%		39.89%				
H ₂ S		0		0.00		0.00%		0.00%				
N ₂		13706		489.29		51.88%		46.91%				
Ar		240		6.01		0.91%		0.58%				
O ₂		2140		66.89		8.10%		6.41%				
Total		26422		1043		100.00%		100.00%				

Heat Absorbed During Reactions:

-729233 Btu/hr

Temp after First Step 1238.453239 K

delta h CO ₂	21.31 Btu/lbm	60413	1769 F	Temp of coal (K)	1238.45
delta h CO	19.92 Btu/lbm	83		C - delta h	33.34 Btu/lbm
delta h H ₂ O	39.94 Btu/lbm	299375		ASH - delta h	19.63 Btu/lbm
delta h H ₂	261.19 Btu/lbm	61		Total of coal	23.93 Btu/lbm
delta h CH ₄	83.54 Btu/lbm	0		Total heat	66655 Btu/hr
delta h H ₂ S	23.54 Btu/lbm	261422			
delta h N ₂	19.07 Btu/lbm	2066			
delta h Ar	8.61 Btu/lbm	39158			
delta h O ₂	18.30 Btu/lbm	662579			
Total		729233			

Determination of rate for chemical reactions:

PO ₂	2.75 atm	Part. Voidage	0.5
Particle Size	0.635 cm		
Film Coef. =	0.0004014 (gmole/cm ³ -s-atm)		
Ash Layer Co	0.0002718 (gmole/cm ³ -s-atm)		
Rate	0.0004456 gmole/cm ³ -s		

Conditions at Combustion Zone

PH ₂ O	17.10	PH ₂	0.00
PO ₂	0.01	PCO ₂	2.65
Temp(K) =	1238		
Density of Coal (lbm/ft ³)		40	
(g/ccm)		0.641	
carbon in char/ash (lb/hr)		874	
ash in char/ash (lb/hr)		1911	
Total		2785	

Percent Carbon in Char/Ash

Bed Voidage

Concentration of Carbon (gmol/ccm)

Volumetric Step

31.37%

38.00%

0.125

12479.45085 ccm

C + H2O --> CO + H2

CO2 + C --> 2CO

rate = $930e^{-(45,000/(RT))} [C]^2 (PH_2O \cdot P^{H_2O})$

rate = $930e^{-(45,000/(RT))} [C]^2 (PCO_2 \cdot P^{CO_2})$

where : $P^{H_2O} = PH_2 \cdot PCO / (e^{(17.29-16330/T)})$

where : $P^{CO_2} = PCO^2 / (e^{(20.92-20280/T)})$

Second Iteration:

$P^{H_2O} = 0.000$

$P^{CO_2} = 0.000$

rate = $2.243E-05$ g-mol/ccm-sec

rate = $3.5E-06$ g-mol/ccm-sec

After Second Volumetric Step:

rate = 0.2798981 g-mol/sec

rate = 0.04333 g-mol/sec

C Consumed 26.68 lb/hr

C Consumed 4.13 lb/hr

H2O Consumed 40.02 lb/hr

CO2 Consumed 15.14 lb/hr

CO Made 62.22 lb/hr

CO Made 19.27 lb/hr

H2 Made 4.48 lb/hr

C + O2 --> CO2

rate = 5.560224 g-mol/sec

C Consumed 530.01 lb/hr

O2 Consumed 1412.08 lb/hr

CO2 Made 1942.11 lb/hr

Totals:

	lb/hr	mols/hr	wt%	mol%	lb/hr	wt%
CO	86	3.06	0.32%	0.29%	1435	42.87%
H2	5	2.34	0.02%	0.22%	1911	57.13%
CO2	4762	108.20	17.65%	10.35%	3346	100.00%
H2O	7456	413.86	27.63%	39.58%		
H2S	0	0.00	0.00%	0.00%		
N2	13706	489.29	50.80%	46.80%		
Ar	240	6.01	0.89%	0.57%		
O2	728	22.76	2.70%	2.18%		
Total	26983	1046	100.00%	100.00%		

Heat Absorbed During Reactions: -7294199 Btu/hr

Temp after Second Step	1588.89 K	2400 F	Temp of coal (K)	1588.89
delta h CO2	202.29 Btu/lbm		C - delta h	331.56 Btu/lbm
delta h CO	186.83 Btu/lbm		ASH - delta h	181.38 Btu/lbm
delta h H2O	389.50 Btu/lbm		Total of coal	245.77 Btu/lbm
delta h H2	2429.61 Btu/lbm		Total heat	822363 Btu/hr
delta h CH4	849.22 Btu/lbm			
delta h H2S	227.49 Btu/lbm			
delta h N2	178.20 Btu/lbm			
delta h Ar	78.48 Btu/lbm			
delta h O2	168.33 Btu/lbm			
Total				

Determination of rate for chemical reactions:

PO2	0.93 atm	0.5		
Particle Size	0.635 cm			
Film Coef. =	0.0004838 (gmole/cm3-s-atm)			
Ash Layer Co	0.0003277 (gmole/cm3-s-atm)			
Rate	0.0001819 gmole/cm3-s	Surface Reaction Rate	0.08815297	(gmole/cm3-s-atm)

Conditions at Combustion Zone

PH2O	16.97	PH2	0.10
POO	0.13	PCO2	4.44
Temp(K) =	1589		
Density of Coal (lbm/ft3)			40
carbon in char/ash (lb/hr)			0.641
ash in char/ash (lb/hr)			1435
			1911
			3346
Total			

Percent Carbon in Char/Ash

Bed Voidage	42.87%
Concentration of Carbon (gmol/ccm)	38.00%
Volumetric Step	0.170
	1168.164063 ccm

C + H2O ---> CO + H2

CO2 + C ---> 2CO

rate = $930e^{(-45,000/(RT))} [C]^* (PH_{2O} \cdot P^{*}CO_2)$
 where : $P^{*}H_2O = PH_2 \cdot PCO / (e^{(17.29-16330/T)})$
 where : $P^{*}CO_2 = PCO^2 / (e^{(20.92-20280/T)})$

Third Iteration:

P*H2O =	0.000	P*CO2 =	0.000
rate =	0.0017206 g-mol/ccm-sec	rate =	0.00045 g-mol/ccm-sec

After Third Volumetric Step:

rate = 2.0098902 g-mol/sec rate = 0.52549 g-mol/sec

C Consumed	191.59 lb/hr	C Consumed	50.09 lb/hr
H2O Consumed	287.37 lb/hr	CO2 Consumed	183.54 lb/hr
CO Made	446.80 lb/hr	CO Made	233.63 lb/hr
H2 Made	32.16 lb/hr		

C + O2 --> CO2

rate = 0.2124833 g-mol/sec

C Consumed	20.25 lb/hr
O2 Consumed	53.96 lb/hr
CO2 Made	74.22 lb/hr

Totals:

	lb/hr	mols/hr	wt%	mol%	lb/hr	wt%
CO	766	27.35	2.81%	2.57% C	1697	47.02%
H2	37	18.29	0.14%	1.72% ASH	1911	52.98%
CO2	4653	105.72	17.08%	9.92% Total	3608	100.00%
H2O	7168	397.91	26.31%	37.34%		
H2S	0	0.00	0.00%	0.00%		
N2	13706	489.29	50.31%	45.92%		
Ar	240	6.01	0.88%	0.56%		
O2	674	21.07	2.47%	1.98%		
Total	27245	1066	100.00%	100.00%		

Heat Absorbed During Reactions:

1234440 Btu/hr

Temp after Third Step 1532.865223 K

delta h CO2	-33.31 Btu/lbm	Temp of coal (K)	2299 F
delta h CO	-30.50 Btu/lbm	C - delta h	1532.87
delta h H2O	-65.60 Btu/lbm	ASH - delta h	-56.34 Btu/lbm
delta h H2	-394.38 Btu/lbm	Total of coal	-29.26 Btu/lbm
delta h CH4	-146.41 Btu/lbm	Total heat	-41.99 Btu/lbm
delta h H2S	-37.94 Btu/lbm		-151500 Btu/hr
delta h N2	-29.02 Btu/lbm		
delta h Ar	-12.55 Btu/lbm		
delta h O2	-27.09 Btu/lbm		
Total	-1082148		
	-1233648		

Determination of rate for chemical reactions:

PO₂ 0.85 atm
 Particle Size 0.635 cm Part. Voidage 0.5
 Film Coef. = 0.000471 (gmole/cm³-s-atm)
 Ash Layer Co 0.000319 (gmole/cm³-s-atm)
 Rate 0.0001607 gmole/cm³-s Surface Reaction rate 0.06448992 (gmole/cm³-s-atm)

Conditions at Combustion Zone

PH₂O 16.01 PH₂ 0.74
 P_{CO} 1.10 P_{CO2} 4.25
 Temp(K) = 1533
 Density of Coal (lbm/ft³) 40
 (g/ccm) 0.641
 carbon in char/ash (lb/hr) 1697
 ash in char/ash (lb/hr) 1911
 Total 3608

Percent Carbon in Char/Ash

Bed Voidage 47.02%
 Concentration of Carbon (gmol/ccm) 38.00%
 Volumetric Step 0.187
 3333.75 ccm

C + H₂O → CO + H₂

CO₂ + C → 2CO

rate = $930e^{(-45,000/(RT))} [C]^*(PH_2O-P^*H_2O)$
 where : $P^*H_2O = PH_2^*PCO/(e^{(17.29-16330/T)})$

rate = $930e^{(-45,000/(RT))} [C]^*(PCO_2-P^*CO_2)$
 where : $P^*CO_2 = PCO^2/(e^{(20.92-20280/T)})$

Fourth Iteration:

P^{*}H₂O = 0.001
 rate = 0.0010569 g-mol/ccm-sec

P^{*}CO₂ = 0.001
 rate = 0.00028 g-mol/ccm-sec

After Fourth Volumetric Step:

rate = 3.523305 g-mol/sec

rate = 0.93604 g-mol/sec

C Consumed 335.85 lb/hr
 H₂O Consumed 503.75 lb/hr
 CO Made 783.24 lb/hr
 H₂ Made 56.37 lb/hr

C Consumed 89.22 lb/hr
 CO₂ Consumed 326.95 lb/hr
 CO Made 416.17 lb/hr

C + O₂ → CO₂

rate = 0.5358325 g-mol/sec

C Consumed

51.08 lb/hr

O₂ Consumed

136.08 lb/hr

CO₂ Made

187.16 lb/hr

Totals:

	lb/hr	mols/hr	wt%	mol%	lb/hr	wt%
CO	1965	70.17	7.09%	6.37% C	2173	53.20%
H ₂	93	46.25	0.34%	4.20% ASH	1911	46.80%
CO ₂	4513	102.54	16.28%	9.31% Total	4084	100.00%
H ₂ O	6665	369.95	24.04%	33.60%		
H ₂ S	0	0.00	0.00%	0.00%		
N ₂	13706	489.29	49.44%	44.44%		
Ar	240	6.01	0.87%	0.55%		
O ₂	538	16.82	1.94%	1.53%		
Total	27721	1101	100.00%	100.00%		

Heat Absorbed During Reactions:

1961988 Btu/hr

Temp after Fourth Step 1445.531971 K

delta h CO ₂	-51.19 Btu/lbm	-231033	Temp of coal (K)	1445.53
delta h CO	-47.07 Btu/lbm	-92517	C - delta h	-85.30 Btu/lbm
delta h H ₂ O	-99.62 Btu/lbm	-663916	ASH - delta h	-45.43 Btu/lbm
delta h H ₂	-610.26 Btu/lbm	-56902	Total of coal	-66.64 Btu/lbm
delta h CH ₄	-220.15 Btu/lbm	0	Total heat	-272168 Btu/hr
delta h H ₂ S	-57.95 Btu/lbm	0		
delta h N ₂	-44.83 Btu/lbm	-614495		
delta h Ar	-19.56 Btu/lbm	-4693		
delta h O ₂	-42.10 Btu/lbm	-22657		
Total		-1686212		
		-1958380		

Determination of rate for chemical reactions:

PO ₂	0.65 atm	Part. Voidage	0.5
Particle Size	0.635 cm		
Film Coef. =	0.0004507 (gmole/cm ³ -s-atm)		
Ash Layer Co	0.0003052 (gmole/cm ³ -s-atm)	Surface Reaction rate	0.03774835
Rate	0.0001186 gmole/cm ³ -s		(gmole/cm ³ -s-atm)

Conditions at Combustion Zone		
PH2O	14.40	PH2
POO	2.73	POO2
Temp(K) =	1446	
Density of Coal (lbm/ft3)		
	(g/ccm)	
carbon in char/ash (lb/hr)		
ash in char/ash (lb/hr)		
Total		
		1.80
		3.99
		40
		0.641
		2173
		1911
		4084
Percent Carbon in Char/Ash		
Bed Voldage		53.20%
Concentration of Carbon (gmol/ccm)		38.00%
Volumetric Step		0.211
		17866.36335 ccm
C + H2O ----> CO + H2		
		CO2 + C ----> 2CO
rate = $930e^{(-45,000/(RT))} [C] (PH2O - P^*H2O)$		
where : $P^*H2O = PH2 \cdot PCO / (e^{(17.29-16330/T)})$		
rate = $930e^{(-45,000/(RT))} [C] (PCO2 - P^*CO2)$		
where : $P^*CO2 = PCO^2 / (e^{(20.92-20280/T)})$		
Fifth Iteration:		
P^*H2O =	0.012	P^*CO2 =
rate =	0.0004401 g-mol/ccm-sec	rate =
		0.00012 g-mol/ccm-sec
After Fifth Volumetric Step:		
rate =	7.8631417 g-mol/sec	rate =
		2.17726 g-mol/sec
C Consumed	749.53 lb/hr	C Consumed
H2O Consume	1124.24 lb/hr	CO2 Consumed
CO Made	1747.99 lb/hr	CO Made
H2 Made	125.81 lb/hr	
		207.54 lb/hr
		760.48 lb/hr
		968.01 lb/hr
C + O2 ----> CO2		
rate =	2.118979 g-mol/sec	
C Consumed	201.98 lb/hr	
O2 Consumed	538.14 lb/hr	
CO2 Made	740.13 lb/hr	

Totals:

	lb/hr	mols/hr	wt%	mol%	lb/hr	wt%
CO	4682	167.14	16.21%	14.16% C	3332	63.54%
H ₂	219	108.66	0.76%	9.20% ASH	1911	36.46%
CO ₂	4493	102.08	15.56%	8.65% Total	5243	100.00%
H ₂ O	5540	307.54	19.18%	26.05%		
H ₂ S	0	0.00	0.00%	0.00%		
N ₂	13706	489.29	47.46%	41.44%		
Ar	240	6.01	0.83%	0.51%		
O ₂	0	0.00	0.00%	0.00%		
Total	28880	1181	100.00%	100.00%		

Heat Absorbed During Reactions:

3242272 Btu/hr

Temp after Fifth Step 1308.865003 K

1896 F

delta h CO ₂	-78.31 Btu/lbm	-351825	Temp of coal (K)	1308.87
delta h CO	-72.48 Btu/lbm	-339313	C - delta h	-127.30 Btu/lbm
delta h H ₂ O	-149.80 Btu/lbm	-829969	ASH - delta h	-70.59 Btu/lbm
delta h H ₂	-943.92 Btu/lbm	-206769	Total of coal	-106.63 Btu/lbm
delta h CH ₄	-324.76 Btu/lbm	0	Total heat	-559078 Btu/hr
delta h H ₂ S	-87.77 Btu/lbm	0		
delta h N ₂	-69.17 Btu/lbm	-948136		
delta h Ar	-30.61 Btu/lbm	-7344		
delta h O ₂	-65.55 Btu/lbm	-3		
Total		-2683359		
		-3242438		

Determination of rate for chemical reactions:

PO ₂	0.00 atm			
Particle Size	0.635 cm	Part. Voidage	0.5	
Film Coef. =	0.0004184 (gmole/cm ³ -s-atm)			
Ash Layer Co	0.0002833 (gmole/cm ³ -s-atm)	Surface Reaction rate	0.01414561	(gmole/cm ³ -s-atm)
Rate	0.0000 gmole/cm ³ -s			

Conditions at Combustion Zone

PH ₂ O	11.17	PH ₂	3.95
POO	6.07	POO ₂	3.71
Temp(K) =	1309		40
Density of Coal (lbm/ft ³)			0.641
carbon in char/ash (lb/hr)			3332
ash in char/ash (lb/hr)			1911
Total			5243

Percent Carbon in Char/Ash
 Bed Voidage
 Concentration of Carbon (gmol/ccm)
 Volumetric Step
 C + H2O ---> CO + H2
 rate = $930e^{(-45,000/(RT))} [C]^{(PH_2O-P^*H_2O)}$
 where : $P^*H_2O = PH_2^*PCO/(e^{(17.29-16330/T)})$

63.54%
 38.00%
 0.252
 10000 ccm

CO2 + C ---> 2CO

rate = $930e^{(-45,000/(RT))} [C]^{(PCO_2-P^*CO_2)}$
 where : $P^*CO_2 = PCO^{*2}/(e^{(20.92-20280/T)})$

Sixth Iteration:

$P^*H_2O = 0.194$
 rate = $7.799E-05$ g-mol/ccm-sec
 $P^*CO_2 = 0.162$
 rate = $2.5E-05$ g-mol/ccm-sec

After Sixth Volumetric Step:

rate = 0.7798852 g-mol/sec rate = 0.25193 g-mol/sec

C Consumed	74.34 lb/hr	C Consumed	24.01 lb/hr
H2O Consumed	111.51 lb/hr	CO2 Consumed	87.99 lb/hr
CO Made	173.37 lb/hr	CO Made	112.01 lb/hr
H2 Made	12.48 lb/hr		

C + O2 ---> CO2

rate = 0 g-mol/sec
 C Consumed
 O2 Consumed
 CO2 Made

0.00 lb/hr
 0.00 lb/hr
 0.00 lb/hr

Totals:

	lb/hr	mols/hr	wt%	mol%	lb/hr	wt%
CO	4967	177.33	17.14%	14.92% C	3430	64.22%
H2	232	114.85	0.80%	9.66% ASH	1911	35.78%
CO2	4405	100.08	15.20%	8.42% Total	5342	100.00%
H2O	5429	301.35	18.73%	25.35%		
H2S	0	0.00	0.00%	0.00%		
N2	13706	489.29	47.30%	41.15%		
Ar	240	6.01	0.83%	0.51%		
O2	0	0.00	0.00%	0.00%		
Total	28978	1189	100.00%	100.00%		

Heat Absorbed During Reactions:

646332 Btu/hr

Temp after Sixth Step	1281.282872 K	1846 F	
delta h CO2	-15.54 Btu/lbm	-68431	Temp of coal (K)
delta h CO	-14.45 Btu/lbm	-71787	C - delta h
delta h H2O	-29.38 Btu/lbm	-159519	ASH - delta h
delta h H2	-188.86 Btu/lbm	-43728	Total of coal
delta h CH4	-62.62 Btu/lbm	0	Total heat
delta h H2S	-17.28 Btu/lbm	0	
delta h N2	-13.82 Btu/lbm	-189358	
delta h Ar	-6.18 Btu/lbm	-1482	
delta h O2	-13.18 Btu/lbm	-1	
	Total	-534305	
		-646351	

Determination of rate for chemical reactions:

PO2	0.00 atm		
Particle Size	0.635 cm	Part. Voidage	0.5
Film Coef. =	0.0004117 (gmole/cm3-s-atm)		
Ash Layer Co	0.0002788 (gmole/cm3-s-atm)	Surface Reaction rate	0.01131259
Rate	0 gmole/cm3-s		(gmole/cm3-s-atm)

Conditions at Combustion Zone

PH2O	10.87	PH2	4.14
POO	6.39	PCO2	3.61
Temp(K) =	1281		
Density of Coal (lbm/ft3)		40	
(g/ccm)		0.641	
carbon in char/ash (lb/hr)		3430	
ash in char/ash (lb/hr)		1911	
		5342	
	Total		

Percent Carbon in Char/Ash

Bed Voidage	64.22%
Concentration of Carbon (gmol/ccm)	38.00%
Volumetric Step	0.255
	107272.0102 ccm

C + H2O --> CO + H2

CO2 + C --> 2CO

rate = $930e^{(-45,000/(RT))} [C]^*(PH_2O-P^*H_2O)$
 where : $P^*H_2O = PH_2^*PCO/(e^{(17.29-16330/T)})$

rate = $930e^{(-45,000/(RT))} [C]^*(PCO_2-P^*CO_2)$
 where : $P^*CO_2 = PCO^*2/(e^{(20.92-20280/T)})$

Seventh Iteration:

P*H2O =	0.281	P*CO2 =	0.251
rate =	5.238E-05 g-mol/ccm-sec	rate =	1.7E-05 g-mol/ccm-sec

After Seventh Volumetric Step:

rate = 5.6186189 g-mol/sec rate = 1.78222 g-mol/sec

C Consumed	535.57 lb/hr	C Consumed	169.88 lb/hr
H2O Consumed	803.33 lb/hr	CO2 Consumed	622.50 lb/hr
CO Made	1249.03 lb/hr	CO Made	792.38 lb/hr
H2 Made	89.90 lb/hr		

C + O2 --> CO2

rate = 0 g-mol/sec

C Consumed	0.00 lb/hr
O2 Consumed	0.00 lb/hr
CO2 Made	0.00 lb/hr

Totals:

	lb/hr	mols/hr	wt%	mol%	lb/hr	wt%
CO	7008	250.21	24.18%	21.05%	4136	68.39%
H2	321	159.44	1.11%	13.41%	1911	31.61%
CO2	3782	85.94	13.05%	7.23%	6047	100.00%
H2O	4626	256.76	15.96%	21.60%		
H2S	0	0.00	0.00%	0.00%		
N2	13706	489.29	47.30%	41.15%		
Ar	240	6.01	0.83%	0.51%		
O2	0	0.00	0.00%	0.00%		
Total	29684	1248	102.43%	104.94%		

Heat Absorbed During Reactions:

4617844 Btu/hr

Temp after Seventh Step 1088.70 K

delta h CO2	-105.91 Btu/lbm	1500 F	Temp of coal (K)
delta h CO	-99.28 Btu/lbm		C - delta h
delta h H2O	-197.88 Btu/lbm		ASH - delta h
delta h H2	-1303.35 Btu/lbm		Total of coal
delta h CH4	-409.86 Btu/lbm		Total heat
delta h H2S	-116.64 Btu/lbm		
delta h N2	-95.10 Btu/lbm		
delta h Ar	-43.13 Btu/lbm		
delta h O2	-91.44 Btu/lbm		
Total			

1088.70	
-164.23 Btu/lbm	
-98.00 Btu/lbm	
-143.30 Btu/lbm	
-866521 Btu/hr	