

COAL TO METHANOL FEASIBILITY STUDY BELUGA METHANOL PROJECT

DOE GRANT DE-FG01-80RA-50299


FINAL REPORT

DOE/RA/50299--1119 Vol. 2

DE82 005901

VOLUME II
TECHNICAL

MASTER



NOTICE

PORTIONS OF THIS REPORT ARE ILLEGIBLE. It
has been reproduced from the best available
copy to permit the broadest possible avail-
ability.

COOK INLET REGION, INC.
AND
PLACER AMEX INC.

SEPTEMBER 1981

DISTRIBUTION STATEMENT A - AVAILABLE TO THE PUBLIC

PORTIONS OF THIS REPORT ARE ILLEGIBLE. It has been reproduced from the best available copy to permit the broadest possible availability.

VOLUME II
COAL-TO-METHANOL PLANT
TABLE OF CONTENTS

DISCLAIMER
This book was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, disclosed, product or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

<u>SECTION</u>	<u>PAGE</u>
1.0 <u>INTRODUCTION</u>	1/1
1.1 General	1/1
1.2 Methanol Product	1/1
1.3 Process Selection	1/3
1.4 Coal Handling and Preparation	1/15
1.5 Synthesis Gas Upgrading	1/16
1.6 Selection of Methanol Synthesis Process	1/17
1.7 Overall Plant Description	1/20
1.8 Technical Viability	1/26
2.0 <u>CONCEPTUAL DESIGN BASIS</u>	2/1
2.1 General Design Considerations	2/1
2.2 Site and Climatic Data	2/2
2.3 Raw Materials and Utilities	2/2
2.4 Product Specifications	2/7
2.5 Drawings	2/9
2.6 Overall Plant Area Plan	2/10
3.0 <u>COAL PREPARATION</u>	3/1
3.1 Design Basis	3/1
3.2 Process Description	3/4
3.3 Engineering Design Data	3/6
Process Flow Diagrams	ff 3/6
Equipment List	3/7
Drawings	ff 3/23

<u>SECTION</u>	<u>PAGE</u>
4.0 <u>COAL GASIFICATION</u>	4/1
4.1 Design Basis	4/1
4.2 Process Description	4/2
4.2.1 Gasification	4/2
4.2.2 Waste Heat Recovery	4/4
4.2.3 Particulate Removal	4/4
4.2.4 Gasification at 10 Atmospheres	4/5
4.2.5 Dry Char Systems	4/5
4.2.6 Ash System	4/6
4.3 Engineering Design Data	4/7
Process Flow Diagrams	ff 4/7
Equipment List	4/8
Drawings	ff 4/31
5.0 <u>SYNGAS UPGRADING</u>	5/1
5.1 Design Basis	5/1
5.2 Process Description	5/2
5.2.1 Raw Gas Compression, Shift and Hydrolysis	5/2
5.2.2 Acid Gas Removal, Makeup Gas Compression	5/3
5.2.3 Sulfur Recovery	5/3
5.3 Engineering Design Data	5/4
Process Flow Diagrams	ff 5/4
Equipment List	5/5
Drawings	ff 5/21
6.0 <u>METHANOL SYNTHESIS AND DISTILLATION</u>	6/1
6.1 Design Basis	6/1
6.2 Process Description	6/1
6.2.1 Methanol Synthesis	6/1

<u>SECTION</u>	<u>PAGE</u>
6.2.2 Reforming	6/3
6.2.3 Distillation	6/5
6.3 Engineering Design Data	6/7
Process Flow Diagrams	ff 6/7
Equipment List	6/8
Drawings	ff 6/20
 7.0 <u>OXYGEN, NITROGEN AND COMPRESSED AIR</u>	 7/1
7.1 Design Basis	7/1
7.2 Process Description	7/1
7.2.1 Air Separation Plants	7/1
7.2.2 Nitrogen and Plant Air System	7/1
7.3 Engineering Design Data	7/2
Process Flow Diagrams	ff 7/2
Equipment List	7/3
Drawings	ff 7/6
 8.0 <u>UTILITIES</u>	 8/1
8.1 Plant Steam System	8/1
8.1.1 Power Plant	8/1
8.1.2 Reforming	8/2
8.1.3 Gasifier Waste Heat Boilers	8/3
8.1.4 Condensate	8/4
8.2 Electrical Power System	8/4
8.2.1 Design Basis	8/4
8.2.2 Electrical System Description	8/5
8.3 Raw Water Treatment	8/8
8.4 Cooling Water System	8/10
8.5 Natural Gas	8/11
8.6 Engineering Design Data	8/11
Process Flow Diagrams	ff 8/11
Equipment List	8/12
Drawings	ff 8/31

<u>SECTION</u>		<u>PAGE</u>
9.0	<u>WASTEWATER TREATMENT</u>	9/1
9.1	Design Basis	9/1
9.2	Process Description	9/1
9.2.1	Railroad Maintenance Area	9/1
9.2.2	Process Area Stormwaters	9/2
9.2.3	Boiler Cleaning Wastewaters	9/3
9.2.4	Coal Storage Area Stormwaters	9/3
9.2.5	Process Wastewater Treatment Facilities	9/3
9.2.6	Miscellaneous Wastewaters	9/5
9.2.7	Cooling Tower Blowdown	9/5
9.2.8	Effluent Storage Pond	9/5
9.2.9	Effluent Diffuser	9/6
9.2.10	Clean Stormwater Runoff	9/6
9.2.11	Construction Runoff	9/6
9.3	Engineering Design Data	9/6
	Tabulated Data on Wastewater Characteristics	9/7
	Process Flow Diagrams	ff 9/11
	Equipment List	9/12
	Drawings	ff 9/32
10.0	<u>EMERGENCY AND SAFETY SYSTEMS</u>	10/1
10.1	Relief and Flare Systems - Design Basis	10/1
10.2	General Description	10/1
10.3	Fire Water System	10/3
10.4	Engineering Design Data	10/4
	Drawing List	10/4
	Equipment List	10/5
	Drawings	ff 10/6

<u>SECTION</u>	<u>PAGE</u>
11.0 <u>STORAGE FACILITIES FOR METHANOL PRODUCT, PLANT FUELS AND CHEMICALS</u>	11/1
11.1 Methanol Storage and Pumping	11/1
11.2 Storage of Diesel Fuel, No. 2 Fuel Oil, Gasoline	11/1
11.3 Storage of Chemicals	11/2
11.4 Engineering Design Data	11/2
Drawing List	11/3
Equipment List	11/4
Drawings	ff 11/9
12.0 <u>BUILDINGS, VEHICLES, MAJOR MAINTENANCE EQUIPMENT</u>	12/1
12.1 Design Basis	12/1
12.2 Building Descriptions	12/3
12.3 Engineering Design Data	12/7
Drawing List	12/7
Equipment List	12/8
Drawings	ff 12/9
13.0 <u>DUST COLLECTION SYSTEMS</u>	13/1
13.1 Design Basis	13/1
13.2 Locations and Descriptions of Systems	13/2
13.3 Engineering Design Data	13/5
Drawings	ff 13/6
14.0 <u>DRAWING LISTS</u>	14/1
Process Flow Diagrams	14/1
Dust Collection/Suppression Flow Diagrams	14/4
Electrical Single Line Diagrams	14/5
Buildings - Layout Drawings	14/5
Plant Arrangements	14/5

TASK CROSS REFERENCE

The organization of this report does not follow the sequence of Tasks 1.00 through 9.00 in the Statement of Work and Study Schedule stipulated in the CIRI/Placer Proposal of 25 April, 1980. It has been found more convenient and orderly to arrange the subject matter as now presented in Volumes I through V.

To enable those concerned to review the study findings with respect to the associated assigned tasks, the following cross referenced tabulation is provided.

<u>TASK</u>	<u>REFERENCE</u>	
	<u>VOLUME</u>	<u>SECTION</u>
<u>1.00 CONCEPTUAL DESIGN</u>		
1.01 Mine	I	All Sections
	II	Conceptual Design
1.02 Railroad	III	Railroad
1.03 Process Plant Unsites	II	All Sections
1.04 Process Plant Offsites	II	All Sections
1.05 Camp, Town & Airstrip	III	Camp, Town & Airstrip
<u>2.00 ENGINEERING DESIGN</u>		
2.01 Mine	I	All Sections
2.02 Railroad	III	Railroad
2.03 Process Plant Onsites	II	Coal Preparation
		Gasification
		Syngas Upgrading
		Synthesis & Distillation
		Emergency & Safety Systems
		Building & Vehicles
		Dust Collection

2.04	Process Plant Offsites	II	Oxygen-Nitrogen-Air Utilities Wastewater Treatment Storage Facilities
2.05	Camp, Town & Airstrip	III	Camp, Town & Airstrip
2.06	Overall Plant Layout	Executive Review	Summary of Study
		II	Introduction
2.07	Pipeline Transport, Storage, Handling and Shiploading	III	Product Transportation
3.00	<u>TRADE-OFF STUDIES</u>		
3.01	Mining Operation Alternate	V	Trade-Off Studies
3.02	Shipping Coal Alternates	V	Trade-Off Studies
3.03	Coal Drying Alternates	V	Trade-Off Studies
3.04	Gasification Alternate with Various Qualities of Coal	V	Trade-Off Studies
3.05	Construction Approach Alternates	V	Trade-Off Studies
3.06	Product Shipping Alternates	V	Trade-Off Studies
3.07	Ash Disposal Studies	V	Trade-Off Studies
3.08	Natural Gas Alternate for Power Generation	V	Trade-Off Studies
3.09	Comparison of Cooling Water Systems	V	Trade-Off Studies
3.10	Hydrogen Sulfide Removal	V	Trade-Off Studies

4.00 DETAILED CAPITAL COST ESTIMATE

4.01	Obtain Vendor Costs	Included in 4.03
4.02	Obtain Subcontract Cost	Included in 4.03
4.03	Prepare Individual Cost	
	Estimates	V Capital Cost
a.	Mine	I Tables
b.	Railroad	III Railroad
c.	Camp-Town-Airstrip	III Camp-Town-Airstrip
d.	Coal to Methanol Plant	V Capital Cost
4.04	Prepare Overall Cost	
	Estimate	V Capital Cost

5.00 MARKETING

5.01	Evaluate Market	
	Requirements	V Marketing
5.02	Develop Marketing Methods	V Marketing

6.00 SITE EVALUATION

6.01	Site Data Collection	IV Site Evaluation
6.02	Site Data Evaluation	IV Site Evaluation
6.03	Applicable Construction	
	Codes and Ordinances	IV All Sections
6.04	Plans for Acquiring	Executive
	Permits & Licenses	Review Work Plan

7.00 ECONOMIC ANALYSIS

7.01	Basic Definition	V Financial
7.02	Economic Analysis	V Financial
7.03	Financial Plan	v Financial

8.00 ENVIRONMENTAL, HEALTH, SAFETY & SOCIOECONOMIC ASSESSMENT

8.01	Environmental	IV	Baseline Data Environmental Effects
8.02	Socioeconomics	IV	Baseline Data
8.03	Site Evaluation	IV	Site Evaluation
8.04	Health	IV	Safety and Risk
8.05	Safety	IV	Safety and Risk

9.00 TECHNICAL SUPPORT PLANS

9.01	Project Management Plan	Executive Review	Plan for Phase II
9.02	Project Manual	Issued at start of Phase I. To be expanded for each additional phase.	
9.03	Reports	Quarterly reports issued during Phase I. Progress reports will be issued as required in future phases.	

SECTION 1.0

INTRODUCTION

1.1 GENERAL

This Volume II contains the rationale for and conceptual design of the coal to methanol plant, and describes the feedstock, the selected processes, facilities, auxiliaries, utilities, buildings, equipment, plant operations and products.

For orientation and reference convenience the text which follows provides a general review of data on the methanol product, its utilization and production; the selection of processes, descriptions of the plant facilities, and an assessment of the technical viability of the Beluga Coal to Methanol Project as outlined in this Phase I Feasibility Study.

1.2 METHANOL PRODUCT

Utilization

Methanol has received great attention in recent years as a synthetic fuel which could substitute for conventional fuels currently used, or as a feedstock for chemicals. Examples of the new uses considered are:

1. Power generation in the electric utility industry, with particular interest in its use in existing combined cycle facilities which run at high efficiency and at reasonable load factors.

2. Use in gasoline blends at levels of 3 to 6%.
3. Use of neat methanol as a motor fuel in converted engines or engines factory-built to use methanol.
4. Production of gasoline additives, such as Methyl Tertiary Butyl Ether (MTBE).
5. Conversion to high octane gasoline.

Methanol is a clear liquid of low vapor pressure and is readily handled in fuel uses. When used as a fuel, it has no sulfur or particulate emissions and has less nitrogen oxides and carbon monoxide in the flue gases than those produced by natural gas, fuel oil or coal combustion. As a feedstock in its chemical grade form, it provides an easy to handle form of carbon and hydrogen suitable for use in producing a wide range of chemicals. It has the potential to replace petroleum as a source of ethylene and aromatics. Widespread success in the development of various engine types, internal combustion and turbine, and direct combustion systems indicate a rapidly expanding fuel-based market is available for methanol or methanol-derived products.

Methanol Feedstocks

In large commercial plants methanol is produced from synthesis gas, which is a controlled mixture of hydrogen, carbon monoxide, carbon dioxide and small amounts of inerts, usually nitrogen and methane. In theory, the required synthesis gas can be produced from any feedstock which contains carbon. Thus, potential feedstocks for methanol production include natural gas, naptha, LPG, low octane petroleum fractions, petroleum residues and all ranks of coal and biomass.

Plant complexity and the cost of producing synthesis gas increases as the hydrogen content of the feedstock decreases. Therefore, with respect to both capital and feedstock costs, large natural gas-based plants generally have been less costly. However, bottom line production costs, as well as feedstock availability, location, and desirability of use, will dictate which feedstocks will be used for very large scale methanol production.

Addressing specifically coal as a feedstock, there are particular methanol production and marketing situations in which the coal-based methanol is a viable economic candidate. This is particularly true when proven technologies are utilized and start-up delays and production interruptions are minimized.

1.3 PROCESS SELECTION FOR THE BELUGA PLANT

The production of methanol from coal requires multiple processing steps. Maximum utilization of energy in each process stage is of critical importance in achieving the highest overall plant thermal efficiency, which in turn enhances the technical and economic feasibility of the project.

The coal to methanol plant for this study has been designed utilizing commercially available and demonstrated technology. All major units have been selected to provide an integrated process plant with maximum reliability. The design incorporates multiple trains, the sparing of critical items and the incorporation of equipment of commercially available size. Particular attention has been given to the optimal integration of all utilities and heat recovery systems and controlling environmental impact to regulated levels.

Only developed technology, which has proven high reliability and thus economy of operation, has been utilized and each individual process stage has been carefully examined for the highest energy yield. As a result, an efficient, proven configuration for the 7500 STPD fuel grade methanol plant complex has been developed.


A graphic block diagram (Figure 1-1) illustrates the multiple train concept, which provides plant reliability necessary to meet the overall project production criteria.

The following is a discussion of process selections by major plant section. Gasification is discussed first, as this selection establishes various critical design parameters for the other major process and auxiliary sections.

1.3.1 Selection of the Gasification Process

The gasification section provides the mixture of H_2 , CO and CO_2 for the methanol synthesis. The selection of the gasification process is critical to any coal-based, chemical synthesis process, and this selection has been made using the following major criteria:

- o Feedstock characteristics
- o Product desired/product gas
- o Environmental impact
- o Competitive capital investment and operating/maintenance economy
- o Commercial status of the process



PROCESSING TRAINS
FIGURE 1-1

Davy McKee	ENGINEERS AND CONSTRUCTORS
PLACER AMEX INC. COOK INLET REGION, INC.	
FEASIBILITY STUDY FOR ALTERNATIVE FUELS PRODUCTION	
PC-5530	9/7/81

There are three commercially proven, large scale coal gasification processes capable of producing the synthesis gas in the required quantities from the available coal. In general, none of the three is the "best" process in all circumstances, but by addressing criteria particular to this project, the selected process does offer the best combination of features.

There are also a number of advanced coal conversion processes at various stages of development. Many advanced gasification systems exhibit great promise, and the progress of these will be closely monitored. A brief discussion of the most promising pioneer processes is included in the Technical Viability section of the Executive Review.

The type and size of the Beluga plant requires that risks be minimized. Start-up risks and risks of low plant production availability are much less with commercially proven processes than with the unproven advanced technologies, particularly if applied to this scale. Therefore, the commercial status of the gasification system is a very critical criteria for the large coal-based chemical complexes.

1.3.2 Comparison of Gasification Systems

There are three basic methods utilized for gasification of coal. They are:

- o Fixed bed gasification
- o Fluidized bed gasification
- o Entrained flow gasification

Table 1-1 presents the various process and hardware parameters for these three classifications. The hardware parameters in general refer to the most common features of the commercially available systems.

TABLE 1-1
GASIFIER COMPARISON TABLE

COMPARISON PARAMETER	FIXED BED GASIFICATION	FLUID BED GASIFICATION	ENTRAINED GASIFICATION
FEEDSTOCK REQUIREMENTS: A. Size B. Ash % C. Moisture content D. Reactivity E. Caking characteristics	Lump coal; no fines 1/4" x 1/4" Not critical Moderately high Up to 30% acceptable Moderate to high Low to moderate	Crushed coal 3/8" x 0 Not critical; up to 50% Moderately High 8-12% Moderate to high Low to moderate	Pulverized coal; 95% 200 mesh Low ash required for economy Low ash fusion preferable 2% All ranges Accepts caking coal
OPERATING CHARACTERISTICS: A. Gasification temp. B. Coal residence time C. Throughput/gasifier D. Steam requirements E. Oxygen requirements	Varies through bed 900-2200°F Hours Low Very High Low	Homogeneous bed temp. 1850-2100°F Minutes High Moderate Moderate	2500-3400°F Seconds High Low High
RAW PRODUCT GAS: A. H ₂ /CO Ratio B. CH ₄ C. Other components D. Solids content E. Product gas temp. F. Recoverable sensible heat lb. steam/lb. coal	2/1 to 1.5/1 55-60% (Liquids Free Basis) 10-18% Naphtha, phenols, ammonia, tars, oils Minimal char 450-1200°F Only low grade available	1.2/1 to .9/1 75-80% 1.5-6% Trace Some char 1850-2100°F 1.2/1 high pressure, superheated	.5/1 to .4/1 78-85% Trace Trace Fused ash 2500-3400°F Direct quench (to 1800°F) 1/1 high pressure, superheated
HARDWARE DESIGN: A. Gasifier 1. Shell 2. Refractory 3. Internals B. Ash handling C. Pressure operation	A. 1. Carbon steel, water jacketed 2. None in gasification zones 3. Mechanically driven distributors and ash gates B. Dry C. 20-25 ATA	A. 1. Carbon steel, single wall 2. Standard refractory materials, 2 component system 3. No internals B. Dry C. 1-1.5 ATA	A. 1. Carbon steel, water/steam jacket 2. Special refractories 3. Slag spray at gas outlet B. Molten slag discharge C. 1 ATA
Commercial	Lurgi	Winkler	Koppers-Totzek
Advanced/Pilot	BGC Slagging Lurgi	HTW Westinghouse IGT U-Gas	Shell-Koppers Toxaco

Beluga Gasification Criteria

Using the major criteria presented above, the following is a list of parameters specific to the Beluga project:

o Feedstock Characteristics

When considering the processing and, in particular, gasification for chemical synthesis, the Beluga coals can be generally characterized as follows:

- (1) Highly reactive
- (2) High ash
- (3) High moisture
- (4) High grindability index
- (5) Non-caking
- (6) Relatively high ash deformation temperature
- (7) Very low in sulfur
- (8) Ash widely varies in relative percentage and composition

o Product Desired/Product Gas

The maximum amount of product methanol from the processed coal with the minimization of any by-products is an important criteria for the Beluga plant. A maximum overall in-plant carbon utilization as feed and fuel with an optimum production of $\text{CO} + \text{H}_2$ is also critical. Due to plant location, certain coal processing by-products such as coal fines, char, tars and oils are not locally marketable items, and export costs would be prohibitive.

o Environmental Impact

Any coal conversion plant must be designed and built to provide an environmentally acceptable complex. This is particularly true in the state of Alaska. Proper handling, processing and disposal of all plant effluents is critical.

o Competitive Capital Investment and Operating/Maintenance Economy

This guideline for selection is especially critical in the Alaskan location where the costs of labor and delivery of materials for construction, plant operation and maintenance will be very high. A combination of initial capital cost and reliable low maintenance operation are a key to an economically feasible plant.

o Commercial Status

There are three gasification processes which are widely recognized as large scale commercially demonstrated processes. They are:

- Lurgi (dry ash/fixed bed)
- Winkler (fluid bed)
- Koppers-Totzek (entrained)

Each of these processes has a long history of commercial utilization, and they are the logical choices to consider for a project scheduled to proceed into detail design in the near future.

1.3.3 Selection of Type of Gasifier

Upon a quantitative evaluation of the available methods of gasification (fixed bed, fluid bed and entrained) and applying the specific Beluga gasification criteria, the selected gasification system is the fluid bed process. The advantages as applied to the Beluga plant include:

o Excellent Feedstock Suitability and Utilization

In particular, the Beluga coals are highly reactive, and high reactivity has been demonstrated to be most suitable for high throughput, fluid bed systems. The relatively high and variable ash percentage is not detrimental to the fluid bed operation relative to energy consumption or materials of construction as ash is not processed or handled in a molten state. The ash fusion temperature is high enough to allow relatively high temperature (2100°F) operation in a gasifier without slagging. The rapid mixing and bed turbulence occurring in a fluid bed can also prevent any localized problems which could be created by fusion of any lower melting ash components. The high moisture content of the run-of-mine coal will be moderately lowered by external drying to 2-10%. This ensures flowability and optimization of oxygen consumption in the gasifier. This is in contrast with the requirement for less than 2% moisture for the entrained gasifier.

Since crushed coal with fines is acceptable to a fluid bed, the overall utilization of feedstock is optimum. It is not necessary to reject the -1/4" coal as with the fixed bed, or to expend energy for coal pulverizing, as with the entrained system.

o Product Desired/Product Gas

The overall carbon utilization in the production of H_2 , CO, CO_2 and CH_4 in a fluid bed system is optimum for the Beluga plant. Probably the most important raw gas characteristic is the lack of any significant tar, oils, phenols, ammonia or other by-products not directly utilized for methanol synthesis. This is in great contrast to the Lurgi System, which makes large amounts of tars, oils and aqueous liquor.

The CO/H_2 ratio requires less shifting than the gas produced from an entrained unit. This characteristic offers savings in capital and operating expense. The amount of methane produced is at a level which does not significantly increase the syngas upgrading costs.

o Environmental Impact

The overall process design and operating conditions of a fluid bed gasifier provide effluent streams which can be easily handled and safely disposed of with conventional technology. The lack of significant quantities of higher hydrocarbons and other by-products, as produced in fixed bed systems, is an important advantage in the construction of the complex in the Beluga area.

o Capital Investment and Operating/Maintenance

The basic fluid bed gasifier is by far the least complex to construct and operate of the three major types of gasifiers. The high throughput and large raw gas production per gasification unit in combination with relatively low consumptions of steam and oxygen make fluid

bed operation the most cost effective system for the Beluga complex.

1.3.4 Selection of the Gasifier

With the significant advantages displayed by the fluid bed gasification system for the Beluga project, the final step in this selection process is to identify the specific fluid bed gasifier to be used. The Winkler process has been selected. This process, developed in Europe, has been operating commercially since 1926. Since that time, more than 60 commercial Winkler gasifiers have been built and operated in Europe and Asia. The majority of these Winkler gasifiers were designed to produce synthesis gas for methanol, ammonia and hydrogen.

The following information, of both a technical and operational nature, details the process advantages and the particular suitability of the Winkler process for the Beluga complex:


- o The demonstrated production of synthesis gas which has been used commercially for the production of methanol, ammonia, and hydrogen for a longer period than any other existing process.
- o Commercially demonstrated reliability, safety and flexibility of operation.
- o Coal utilization is high and preparation cost is low. Only minor crushing is required to prepare the coal size required for the gasifier. All coal 3/8" x 0 can be fed to the gasifier.

- o The suitability of the Beluga feedstock from the standpoint of reactivity can be seen in the Grout Apfelbeck Diagram (Figure 1-2). This diagram is a method of ranking gasifier feedstocks and indicating relative reactivity by carbon, hydrogen and oxygen composition. It can be seen that the Beluga coal is well within the range of Winkler experience and is nearly identical in rank to the coal used in the Kutahya plant in Turkey.
- o Gasifier operation at high enough temperatures to prevent the formation of tars, oils and higher hydrocarbons.

The trace compounds in the raw gas are predicted to fall into the following ranges:

NH ₃	3 to 10 ppm (vol)
HCN	10 to 20 ppm (vol)
C ₂ H ₂	50 to 150 ppm (vol)
C ₆ H ₆	10 to 30 ppm (vol)
H ₂ S	700 ppm (vol)
COS	100 ppm (vol)

- o The dry char material recovered after the gasifier is a suitable fuel and can be burned in an offsite boiler to increase total carbon utilization.
- o The operating campaigns on existing gasifiers average nine months between maintenance shutdowns. This is far longer than experienced on any other process.
- o The inventory of carbon in the fluid bed greatly reduces the possibility of oxygen breakthrough, thus providing safe operation.



RANGE OF WINKLER GASIFIER EXPERIENCE
GROUT APFELBECK TRIAXIAL DIAGRAM

FIGURE 1-2

- o The inventory of ash in the fluid bed is such that variations in the ash content of the incoming coal can be tolerated.
- o The Winkler gasifier has great flexibility between maximum and minimum flows and can be "banked" at time of zero gas requirement (e.g., when downstream equipment is undergoing maintenance).

1.4 COAL HANDLING AND COAL PREPARATION

All of the equipment selected for coal handling and preparation is of standard industrial design. All railcar unloading, blending, sampling, conveying, stacking, reclaiming, screening, crushing and drying units are sized to allow procurement of standard equipment widely used in the coal industry. Design for all units includes dust control and fire protection systems.

As large scale crushing and drying tests were not completed during this study, the available coal data was used in a conservative manner to specify the crushing and drying units. Due to the relatively large amount of fuel coal required for this complex, an initial screening of as received -3/8" material is designed to be conveyed directly to the boiler house. Although this fines screening is not required for gasification, it will significantly reduce boiler coal pulverizing power requirements of this relatively high Hardgrove index coal.

The fluid bed coal dryers are designed to be coal fired. Dried coal and carryover to cyclones from the drying bed are pulverized and used for direct coal firing to supply heat for drying. All storage for dried coal is blanketed with nitrogen to prevent explosions and fires.

SYNTHESIS GAS UPGRADING

A number of major processing steps are included in this section of the plant. Various processes and equipment configurations are available to accomplish these steps. Trade-off studies were completed to arrive at the system selected. The major criteria used in the system selection were:

- o Commercial availability of the process or equipment and proven operation at specific design conditions.
- o Environmental acceptability of effluent streams.
- o Capital, operating and maintenance costs.
- o Process efficiency.
- o Flexibility for large plant operation.

The trade-off studies and evaluations included the review of the available systems which meet the above criteria.

Synthesis gas upgrading includes three major processing steps:

- o Compression of the gas from the gasifier raw gas pressure to methanol synthesis pressure;
- o Adjustment of the relative compositions of H_2 , CO and CO_2 to the desired percentages required for methanol synthesis; and
- o Removal of all sulfur compounds and other catalyst poisons.

As certain key processing steps to be evaluated have not been demonstrated above 65 ATA, the initial raw gas compression ratio was limited to about 20:1 for the trade-off study. This limitation dictated an additional stage of compression prior to methanol synthesis. A total compression ratio of about 35:1 is required.

The result of this trade-off study is presented in Volume V (Task 3.10).

Three parallel trains are used for synthesis gas upgrading to provide operating flexibility and permit use of proven equipment.

It is also important to note that raw gas saturation, which is required prior to the sulfur resistant CO shift section, has been integrated within the methanol distillation column. This integration results in a significant steam savings.

Absorptive acid gas removal has been selected. The trade-off study indicates some capital and operating expense advantages for Selexol. The final selection will be made prior to start of final design when coal and gas properties and costs are sufficiently detailed.



1.6 SELECTION OF THE METHANOL SYNTHESIS PROCESS

The selected process (ICI Low Pressure) will synthesize methanol from a mixture of H_2 , CO and CO_2 , regardless of whether this mixture is derived from steam reforming of methane or naphtha, or alternatively, from the partial oxidation of oil or gasification of coal. However, all process and operating histories of methanol synthesis have been considered for this project.

There are two types of processes for the synthesis of methanol:

- "High Pressure" using zinc/chrome catalyst.
- "Low Pressure" using a copper catalyst.

The synthesis of methanol from mixtures of H_2 , CO and CO_2 is reversible, and the degree of conversion in the two reactions is favored by low temperature and high pressure.



The rate of reaction is, however, retarded by low temperature. The initial catalyst developed for the reaction (zinc/chrome) was so unreactive at the low temperatures favoring the equilibrium that it was necessary to raise the temperature to obtain adequate synthesis. To counter the adverse effect on the equilibrium caused by the high temperature, it was necessary to operate the process at very high pressures (typically 4500 psi) to obtain an economic level of product of methanol at the outlet of the converter.

The very high pressure used in the so-called "High Pressure Process" had the disadvantage that the compressors were invariably reciprocating machines with high capital cost, high maintenance cost, low availability, and high operating cost characteristics.

Prior to World War II, ICI in England, Commercial Solvents in the USA, and IG Farben in Germany experimented with a very active copper catalyst for the synthesis of methanol. However, with the gas purification techniques then available, it was not possible to remove trace impurities of sulfur and chlorides, preventing commercial development of the catalyst. As a result, ICI and others continued for many years to use the far less active zinc/chrome catalysts for methanol synthesis.

This situation changed dramatically in the 1960's when ICI, using the same techniques developed to remove sulfur from upstream of its Naphtha Reforming Catalyst, developed a practical methanol synthesis process based on a copper catalyst.

The new catalyst is so active at low temperature (400°F to 550°F) and the yield of methanol at the converter outlet so high that operation with pressures as low as 750 psi are possible. The pressures now used range from 750 to 1500 psi, depending upon plant size and various design optimizations. This low pressure allows centrifugal compressors to be used down to very low capacity (approximately 150 tons/day).

The process selected for this project, the ICI Low Pressure Process, is the most widely used methanol synthesis process in the world. Nearly 80% of the world capacity built during the past decade uses this process.

The ICI process is used for:

- o The largest single stream methanol plant in current operation.
- o The largest plants currently being built or on order.
- o The only modern methanol plant based on coal in current operation (A.E. & C.I., Modderfontein, South Africa).

The catalyst (ICI 51-2) is the most successful catalyst used in any methanol process and has:

- o The longest commercial experience of any copper catalyst.
- o Longest economic operating life.
- o Very high activity.
- o There has never been an unscheduled loss of catalyst on a commercial plant.

For the reason stated above the proposed plant is not a pioneer plant in size, capacity, operating pressure, temperature, nor any other parameter.

1.7 OVERALL PLANT DESCRIPTION

The Beluga coal-to-methanol plant design is a grass roots facility. It has been designed to be self-sufficient, importing only coal for feedstock and utility fuel, raw water, and small amounts of gas and water treatment chemicals. The product is 7,500 tons per day of fuel grade methanol, with the capability for production of chemical grade methanol. The only by-product is a minor amount of sulfur.

The processing and major ancillary systems include the following sections:

- o Coal Handling and Preparation
- o Gasification
- o Synthesis Gas Upgrading
- o Methanol Synthesis, Distillation and Purge Gas Reforming
- o Major Support Facilities
- o Air Separation
- o Steam and Power Generation

The plant being designed for self-sufficiency, all necessary ancillary systems are included in the design and are detailed in Sections 7 to 12 of this Volume.

The major processes are briefly described as follows:

1.7.1 Coal Handling and Preparation

A blend of 70% Capps and 30% Chuitna run-of-mine coals, 6" x 0, is received by rail, unloaded, stacked, and stored in 15-day capacity storage piles.

The coal is retrieved from active storage and transferred to either the process plant or utility boilers. Coal for the boilers is crushed to 1-1/2" x 0 in this area and transferred to the boiler area for pulverizing.

Coal to be used in gasification is crushed to 3/8" x 0; dried to 8% moisture; and sent to active, closed storage ready to be transferred to the gasification section.

1.7.2 Gasification

The gasification section consists of the gasifiers, waste heat recovery systems, and particulate removal systems. Eight fluid bed gasifiers are required. They operate at 4ATA and 2100°F. The coal is fed into the gasifiers by means of a lock hopper system. The coal feed rate is controlled by variable speed screw conveyors.

During gasification, the carbon in the coal reacts with oxygen and steam to form carbon oxides, methane, and hydrogen. Oxygen is supplied by three (3) large-tonnage air separation plants. These plants also supply nitrogen for process and utility use. The hot raw gas exits the top of the gasifiers. Larger residue solids are removed from the bottom of the gasifier, and finer particles exit with the gas. The ash exiting from the bottom is lock hopped to atmospheric pressure and pneumatically conveyed to storage for eventual disposal to the mine.

The hot gases leaving the top of the gasifier enter the waste heat recovery system (one unit for each gasifier train). These units use the heat in the gas to generate high pressure, superheated steam which is used throughout the plant. The solids, entrained in the raw gas, are a combustible char

(approximately 30% carbon, 70% ash) which is used as fuel in the utility boilers. A portion of the char is collected at the bottom of the waste heat recovery unit, but the majority is removed in a dry cyclone immediately following the waste heat recovery system. The dry char collected from the waste heat sections and cyclones is conveyed to the boiler for blending with raw coal for use as fuel.

Fine particles that may still be entrained in the gas are removed via a direct quench Venturi-type scrubber (one scrubber per gasifier train). The particle-laden water is sent to settling ponds where the particulate is concentrated and filtered. The water purge is sent to wastewater treatment for water recovery.

The raw gas is now cooled and clean of particulate. It is delivered to the synthesis gas upgrading section for production of a gas suitable for methanol synthesis.

1.7.3 Synthesis Gas Upgrading

Four (4) major gas processing steps are included in the synthesis gas upgrading section:

- Compression from 40 psia to 1390 psia (methanol loop pressure).
- Adjustment of H_2 to CO ratio.
- Removal of all sulfur compounds and other catalyst poisons.
- Reduction of CO_2 content.

The synthesis gas preparation area consists of three (3) parallel trains.

The first step in this section is raw gas compression which increases the pressure of the gas from 40 psia to 770 psia. Centrifugal, multi-body turbine driven compressors are used.

From compression, the gas is then saturated, preheated, and sent through a CO shift reactor, where the ratio of hydrogen to carbon monoxide is adjusted with sulfur-resistant catalyst to the required level for methanol synthesis. The reactor is a packed bed of catalyst.

From COS hydrolysis, the raw gas goes to the Selexol acid gas removal unit. The purpose of this unit is to remove the sulfur components in the gas and to adjust the CO₂ level in the gas to the required percentage for methanol synthesis. This process is selective in that it removes H₂S from the raw gas in the first absorber, and CO₂ removal is done with a second absorber. Since the solvent is recirculated, it must be continually regenerated by flashing. The absorbers are packed columns in which the gas streams are contacted with the liquid solvent. The purge gas stream leaving the H₂S flash system is sent to the sulfur recovery unit.

The gas leaving the CO₂ vent is 99%+ CO₂ and, hence, is simply vented. Since large amounts of CO₂ are released, consideration has been given to collection and possible sale for secondary oil recovery. The synthesis gas leaving the Selexol unit contains only trace levels of H₂S and COS and has the proper ratios of CO, CO₂ and H₂ for methanol synthesis. Guard beds are provided for removal of any trace sulfur compounds and other catalyst poisons.

The final stage in this preparation area is make-up gas compression. The synthesis gas is compressed to the level required for methanol synthesis, which is 1390 psia. Turbine driven, centrifugal type compressors are used.

1.7.4 Methanol Synthesis Distillation and Purge Gas Reforming

The ICI low pressure methanol process is used in this section of the plant. In order to produce 7500 STPD of product methanol, three (3) synthesis and distillation trains are required. Each train consists of one converter, one circulator, a distillation column and a set of heat recovery units. The circulator is a steam-driven, single-stage, centrifugal compressor.

The methanol converter is a pressure vessel of single-wall design constructed of low-alloy steel holding a single continuous bed of catalyst. Temperature control is achieved by injecting feed gas at appropriate levels directly into the bed, using specially developed distributors.

The converter exit gas is split for optimum heat recovery; one part heats the feed gas to the top of the converter, and the second heats the CO shift saturator water and reboils the distillation column. The streams are combined to heat all of the circulating gas and then cooled. The crude methanol is separated and let down from loop pressure to 60 psia.

The non-reactive components (mainly, CH_4 , and N_2) in the make-up gas are purged from the synthesis loop between the separator and the point of make-up gas addition. This purge gas and the flash gas from the letdown vessels are used as feed to a steam reformer. Seventy-five (75%) percent of this gas is used as process feedstock, and 25% is utilized as fuel for the reformer furnace. The reformed gas is recompressed and blended with the main synthesis gas stream.

A one-column distillation system is provided to produce the required product purity. The crude methanol from the letdown vessels flows to the preheater and then to the column. The reboiler heat is provided by part of the converter exit gas. The purpose of the distillation column is to remove water (and the light ends) from the crude methanol. The column overhead is completely condensed and returned to the column as reflux. Product methanol is withdrawn three trays below the reflux tray and is cooled prior to passing to the methanol product storage tank. The distillation column bottoms, which is essentially water, is cooled and pumped to the wastewater treatment area.

Product storage facilities have also been provided in this section. Storage tanks for crude methanol and methanol product are provided.

1.7.5 Major Support Facilities

- Air Separation

This section produces all the oxygen required for gasification. The normal production is 7500 STPD at 99.5% purity and 90 psia. Three (3) units are required for this capacity. Air and oxygen compressors are steam turbine-driven.

- Steam and Power Generation The remaining import coal not used in the gasification process is used in the boiler house for steam and power generation. Coal is blended with gasification char and is used as fuel for the three boilers to generate 1200 psig steam. This steam is used both for process requirements and power generation from turbo-generators.

1.8 TECHNICAL VIABILITY

The following text presents a review of key selected processes and critical hardware from a technical preparedness standpoint. As previously discussed, the coal-to-methanol route is more complex than the currently dominant natural gas-based methanol production. The overall design concept developed for the Beluga complex is similar to well established coal-based chemical plants, but varies with refinements justified by demonstrated innovations now available for use. A minor variation from commercial technology involves raising the pressure of the Winkler gasifier about 2.5 ATA. Numerous avenues of process and hardware design have been explored; and the resultant detail design minimizes risk, but assures state-of-the-art commercial operability, efficiency, and safety.

1.8.1 COAL HANDLING AND PREPARATION

All coal handling and preparation equipment is standard coal industry hardware. Final specification of crushing and drying equipment will be based upon large-scale testing of the Beluga coals.

1.8.2 GASIFICATION

o Fluid Bed Gasification

Earlier in this section the reasons for the selection of fluid bed gasification using Winkler technology are discussed in detail. In summary, this technology is the best system for the Beluga project for the following reasons:

- Excellent suitability to feedstock.
- Optimum raw gas for methanol production.
- Contaminants in effluent streams can be economically treated to environmentally acceptable levels with conventional technology.
- Best combination of capital, operating, and maintenance economy.
- Longest history of successful commercial operation for production of synthesis gas for chemicals.

The gasification system designed for use in the Beluga plant is the third generation Winkler system, which incorporates nearly 60 years of development including: laboratory and pilot plant testing (1922-1926), and commercial operating experience with continuing technical improvement from 1926 to the present.

Winkler gasification has been demonstrated in 22 plants since 1926. A list of these facilities with details of operation is included in Table 1-2.

The first generation Winkler gasifier was the first major industrial application of fluid bed technology. The system was based on the 1922 patent (No. 437970) awarded to Dr. Winkler for the gasification of coal fines. The gasifier was initially designed with a mechanically swept, water-cooled grid below the fluid bed area.

TABLE 1-2

WINKLER COAL AND COKE, FLUID BED GASIFICATION PLANTS

<u>Plant Number</u>	<u>Plant</u>	<u>Product</u>	<u>Capacity Per Gasifier 1000 scfh</u>	<u>Number Gasifiers</u>	<u>Operating Dates</u>
1	BASF, Ludwigshaven, West Germany	Pilot Plant	75	1	1925-58
2	Leuna-Werke, Merseburg, East Germany	LBTU Fuel Gas & Synthesis Gas for MeOH & NH ₃	3,730 2,240	5	1926-70
3	BRABAG, Bohlen, East Germany	Hydrogen	1,120	3	1938- Present
4	BRABAG, Magdeburg, East Germany	Hydrogen	1,230	3	1938-45
5	Yahagi, Japan	Ammonia	330	1	1937-60
6	Dai-Nihonyinzo- Hiryo, Japan	Ammonia	520	2	1937-59
7	Nippon Tar, Japan	Ammonia	520	2	1937-60
8	Toyo Koatsu, Japan	Ammonia	750	2	1938-69
9	Fushun, Mandschukuo, Japan	Syn. Gas for F. T. Fuel	750	4	1939-?
10	BRABAG, Zeitz, East Germany	Hydrogen	850	3	1941- Present
11	Treibstoffwerke, Brux (now Most), Czechoslovakia	Hydrogen	1,120 1,200	5 2	1943-72 1954-73
12	Salawad, USSR	Medium BTU Gas	860	7	?-Present
13	Baschkirien, USSR	Medium BTU Gas	860	4	?-Present
14	Dimitroffgrad, Bulgaria	Medium BTU Gas	670	4	1951- Present

TABLE 1-2 - WINKLER COAL AND COKE, FLUID BED GASIFICATION PLANTS (Continued)

<u>Plant Number</u>	<u>Plant</u>	<u>Product</u>	<u>Capacity Per Gasifier 1000 scfh</u>	<u>Number Gasifiers</u>	<u>Operating Dates</u>
15	Stara Zagora, Bulgaria	Medium BTU Gas	1,120	5	1962- Present
16	Fabrika Azotnih, Jendinjenja, Gorazde Yugoslavia	Ammonia	260	1	1952- Present
17	Calvo Sotelo I, Puertollano, Spain	Ammonia	350	1	1956-70
18	Calvo Sotelo II	Ammonia	350	1	1959-70
19	UKW, Wesseling I, West Germany	Synthesis Gas for MeOH and NH ₃	630	1	1958-67
20	UKW, Wesseling II, West Germany	Synthesis Gas for MeOH and NH ₃	630	1	1962-67
21	Azot Sanayii TAS, Kutahya, Turkey	Ammonia	450	2	1959- Present
22	Neyveli Lignite Corp., India	Ammonia	785	3	1965-79
22	(Including Pilot Plant)			63 (Including Pilot Plant)	
	IN OPERATION AT PRESENT			29	

September, 1981

This configuration was replaced with a simple refractory cone with fluidizing gases injected through circumferential nozzles at various levels in the cone. This simplified gasifier produced up to 3.73 MM SCFH of raw gas in the air-blown mode at the Leuna-Werke plant.

The second generation provided higher CO and H₂ in the raw gas, greater once-through carbon conversion, and the ability to gasify less reactive coals economically. The injection of additional gasifying media above the fluid bed was later introduced to further react unconverted carbon in any entrained solids. A radiant boiler (German Patent No. 1 421 655) was introduced in the upper portion of the gasifier to prevent any fused ash particles from leaving with the raw gas.

A significant step in the evolution of the Winkler process is included in the third generation system. This system (described in 1978 U. S. Patent 4017272) added pressurized gasification to the previous developments. A 4-ATA unit is currently offered.

o Pressurized Fluid Bed Design

The use of fluid beds at elevated pressure has been widely demonstrated. Catalytic cracking systems have successfully employed pressurized fluid beds for a number of years. The Institute of Gas Technology (IGT) has developed an extensive data base for pressurized fluid bed design. IGT has operated large gasification pilot units as high as 1,650 psig and the reliability and safety of fluid bed operation at elevated pressure.

Numerous studies, detail designs, and equipment test work have been completed in order to verify the advantages and technical viability of moderate pressurization of the fluid bed Winkler for synthesis gas production. The current commercial operating experience does not exceed 1.5 ATA for Winkler systems. Moderate pressurization (4 ATA) offers substantial reduction of capital cost by a reduction of the number of gasification trains required. This moderate pressurization also eliminates one stage of raw gas compression which reduces the overall compression ratio, raw gas to methanol synthesis pressure, from 70:1 to 35:1.

o Gasifier

The gasifier is designed in accordance with the ASME Unfired Pressure Vessel Code, Section VIII, Division 1. The carbon steel shell and nozzles are designed for 75 psig and a design temperature of 650°F. The refractory lining prevents all parts of the shell from reaching temperatures greater than 300°F during operation.

The overall dimensions of the gasifier are the same as those used in a number of commercial units: 18' I.D. by approximately 72' high. The refractory lining scheme is identical to that used in the Kutahya gasifiers; brick construction with an inner abrasion-resistant brick and an outer insulating brick. The linings in the Kutahya gasifiers, which are still operating, have not been replaced or required major repairs since the plant was commissioned in 1959. The actual lining materials selected are somewhat different to take advantage of advances in materials technology and more recent refractory installation techniques.

The radiant boiler section included in the top of the gasifier is to be constructed of low-alloy, superheater-quality boiler tubing. This same tubing material has been used with great success in operating gasifiers.

o Pressurized Solids Feed and Discharge Systems

In the development of a dry solids pressurized system, the most critical parameters are reliability and safety. The design of the Beluga coal feeding, char discharge, and ash discharge systems is based on extensive design, testing, and operating experience.

- Valve Design

The most critical single component in a lock hopper system is the lock hopper valve, which must be capable of reliable, continuous operation with positive pressure sealing. The valves and associated actuating systems have been tested and operated under conditions more severe than any that will be encountered by this gasification process.

The coal feed valves are very similar in configuration to the valves successfully operated in the FIOR (fluidized iron ore reduction) plant. The valves in the FIOR plant operate with a 10-ATA differential pressure and are used to feed 75 STPH of iron ore into a fluid bed. Similar valves have also been used for pressurized blast furnace feed systems.

The feed valve in the Beluga plant design is a full-opening, "bell"-type valve. Each valve has a redundant pneumatic actuator system. Heat resistant (up to 250°F) elastomer seals, which are protected from

direct exposure to the solids flow, are contacted with the metal bell and provide a positive pressure seal.

The large, full-open dimension is designed to provide rapid, reliable coal flow (42 STPH/hopper system) from surge bins to the lock hopper. The valve will operate only once every hour, assuring long valve life.

The valves to be used for the char and ash services are of a different design. They will be smaller in size as they will handle less material, and will be temperature-resistant. Both the char and ash will normally be cooled below 350°F prior to exposure to the valves, but provision is made to handle solids with temperatures as high as 900°F in case of a temporary process upset. All valve components are designed for the abrasive ash expected with the Beluga coal.

- Gasifier Screw Feeder

Although not directly a part of the lock hopper system, the gasifier screw feeder is a critical component used in the pressurized coal feed to the gasifier. The internals of this feeder are identical to the components developed in existing Winkler units. The low-speed, variable drive ensures a continuous, controlled feed to the gasifier. The outer pressure sealing shell is a coded, pressure pipe (ANSI B31.3) with abrasion-resistant linings. A standard double-seal arrangement is used for sealing the conveyor shaft.

- Redundancy and Maintenance

Each gasifier is provided with two complete coal feeding systems. The systems are designed for nominal gasifier capacity when both systems are operating. Should a system require maintenance, isolation valving is provided. Additionally, the single operating system can be adjusted, by programming shorter lock hopper cycles and increased speed on the screw conveyors, to provide adequate coal for full raw gas production.

o Waste Heat Recovery System

As discussed in the gasifier selection section, the Winkler fluid bed offers a distinct advantage over the other available systems in the area of waste heat recovery. The amount of the heat recovered before any direct quenching will be significant. The Beluga plant will recover in this section about one pound of superheated steam (870 psia, 840°F) for each pound of coal gasified. This steam will be utilized throughout the plant.

The pressure and temperature selected will allow the use of standard boiler construction materials. The overall design of this unit is particularly critical due in part to the solids loading. The special "know-how" for this recovery system has been developed over years of operating experience.

o Dry Solids Removal

A large portion of the char particles contained in the raw gas is removed in a dry cyclone. As the removal takes place at gasification pressure, special care must be taken to ensure the prevention of solids erosion on the pressure shell. A highly efficient design has been developed, which exposes only internal, non-pressure sealing components to erosion.

It should also be noted that the char cyclone is downstream of the waste heat recovery section. This allows much more efficient solids separation and at the same time utilizes commercially demonstrated materials in construction of the cyclone.

o 10 ATA Gasification

One train in the gasification section is designed for 10-ATA operation. This unit will have the capability to demonstrate a further advance in the Winkler system. A 60% increase in gasifier throughput, when compared to the 4-ATA unit, is predicted with a slight increase in production of CH_4 . This increase in methane (3.02 to 5.57 MOL %) in the particulate-free raw gas will not adversely affect the downstream syngas upgrading economics. Demonstration of the process and mechanical viability of this 10-ATA unit will provide any future plant expansion with the advantage of a reduced number of gasification trains for syngas production.

All of the components included in the design of the 10-ATA train also have the capability of 4-ATA operation.

o Advanced Gasification Technology

There have been extensive efforts in the research and development sector to improve coal conversion technologies. Many advanced pilot systems exhibit great promise. Certain members of the Beluga Project have been closely monitoring and were often directly involved with these developments. The area of fluid bed gasification development has been particularly active with U. S. organizations such as the Institute of Gas Technology (Hygas and U-Gas), Battelle Memorial Laboratories (Agglomerating Char Gasifier), the Westinghouse Corporation (The Westinghouse Gasifier), and the United States Department of Energy (Synthane, CO₂ Acceptor, and H-Coal). The Institute of Gas Technology has developed a vast data base on the kinetics and dynamics of high pressure (up to 1650 psig) fluid bed operation. Since 1975 in Europe, Rheinische Braunkohlenwerke AG, and Uhde GmbH have been cooperating in the development of the fluid bed HTW (High Temperature Winkler) process.

It is to be noted that the status of the more successful efforts will be followed. As the Beluga project develops through detail design and procurement, certain demonstration plants incorporating the more successful pilot designs could be operating. The final selection of the gasification system will take into consideration demonstrated advanced technologies from these pioneer units.

o The IGT U-Gas Gasifier

The IGT U-Gas gasifier is a pressurized fluid bed, ash-agglomerating unit. Successful pilot tests in the 4-foot diameter unit in Chicago have led to the following planned projects:

- 1) Memphis Power and Light: A medium BTU Fuel Gas Plant to operate at 6-ATA and produce 50 billion BTU/day of 300 BTU/SCF fuel gas.
- 2) Veg-Gasinstituut, Netherlands: A pilot unit for 20-ATA operation producing fuel gas.

o The Westinghouse Gasifier

Westinghouse and Sasol have recently announced a joint effort to demonstrate the technical viability of the Westinghouse gasifier in the Sasolburg facility. In an effort to utilize the fines not acceptable for use in the existing Lurgi fixed-bed units, and to avoid unwanted liquid and gaseous by-products, Sasol has selected fluid bed technology. This 1,200 STPD, ash-agglomerating gasifier will be totally supplied by Westinghouse for operation by Sasol. It is scheduled to start up in 1983.

o HTW Process

The HTW (High Temperature Winkler) process is an attempt to improve Winkler fluid bed technology by increasing the operating temperature and the operating pressure.

A pilot facility with a 24-inch diameter gasifier has been operated in West Germany by Rheinische Braunkohlwerke and Uhde. The technology is a pressurized (10-ATA) fluid bed process operating below the ash fusion temperature of the coal to be gasified. Their original processing scheme included an apparently unsuccessful limestone addition to the gasifier to allow operation above the normal ash fusion temperature.

With the support of the West German government, a facility will be constructed near Koln, Germany, to demonstrate a single HTW gasifier for production of synthesis gas from brown coal. This unit is scheduled to go on-stream in 1984.

o The Beluga Gasification System

The 4-ATA fluid bed gasifier to be used in this project is a moderate extension of many years of commercial experience and technological development in the production of synthesis gas from carbon-containing solids. The inclusion of a 10-ATA demonstration unit, which can also operate at 4-ATA for normal plant production, will permit test runs and allow future expansion of the Beluga complex to include developed improvements.

With the current status of advanced coal gasification technologies, there is little probability that significant technical improvements can be commercially applied in plants to be designed in the next two or three years.

It should also be noted that the capital cost of the gasification portion of the Beluga plant is less than 15% of the total plant cost. An absolute minimum of risk must be maintained in the development of large-scale, coal-based methanol plants, such as the Beluga complex. The Winkler process meets this criteria.

1.8.3 METHANOL PRODUCTION

All process design and components designed for use in the methanol synthesis, distillation, and purge gas reforming units are fully demonstrated technology. The basic ICI catalyst has been in use since 1967. The ICI low-pressure process for high-capacity methanol production has been demonstrated in the plants listed in Table 1-3.

A single distillation column for each train will be used to produce the fuel quality methanol. The steam reformer is of a standard design, with the furnace containing 312 reformer tubes. Reformer furnaces have been designed and constructed with 600 reformer tubes. The Mobil, New Zealand reformer will contain 680 tubes.

TABLE 1-3
PLANTS USING THE ICI LOW PRESSURE METHANOL PROCESS TECHNOLOGY

<u>LICENSED PLANTS</u>	<u>LOCATION</u>	<u>CAPACITY STPD</u>	<u>ICI LICENSEE</u>	<u>STATUS/ START-UP</u>
Taasung Lumber Company	Korea	165	Davy McKee	Onstream
Georgia Pacific Corp.	USA	1200	Davy McKee	Onstream
Chang Chun Petrochemical	Taiwan	165	Davy McKee	Onstream
Monsanto Company	USA	1000	Chemico	Onstream
Nishi Nihon	Japan	1100	Kellogg	Onstream
Dor Chemicals	Middle East	165	Humphreys & Glasgow	Onstream
Elf Oil, Speyer	W. Germany	900	Humphreys & Glasgow	Onstream
Celanese Corporation	USA	2100	Davy McKee	Onstream (Expansion 1976)
Methanol Chemie Nederland	Holland	1100	Davy McKee	Onstream
PCUK (Ugine Kuhlmann)	France	660	Davy McKee	Onstream
Metanol SA	Brazil	200	Davy McKee	Onstream
Indiquimica, Algeciras	Spain	660	Davy McKee	Onstream
Taasung Methanol Company	Korea	1100	Davy McKee	Onstream
Rumanian Ministry	Rumania	660	Davy McKee	Onstream
China National Technical	China	330	Humphreys & Glasgow	Onstream
National Methanol Company	Libya	1100	Uhde	Onstream
Techmashimport, Gubaha	USSR	2750	Davy McKee	1982
Techmashimport	USSR	2750	Davy McKee	1982
SCT	Saudi Arabia	2300	Davy McKee	1983
Borden	USA	2000	Davy McKee	1980 (Revamp)
Almer Arzew	Algeria	330	Humphreys & Glasgow	Onstream
AE & CI Modderfontein	South Africa	50	Uhde	Onstream
Gujarat SFC	India	70	Linde	1982
MSK Kidinda	Yugoslavia	330	Technip	1983
CPDC	Taiwan	140	Lummus	1983
Ocelot	Canada	1340	Davy McKee	1983
ARCO Chemical	USA	2000	Davy McKee	1983
Air Products	USA	500	Davy McKee	1982 (Revamp)
Mobil R & D Corporation	New Zealand	4850	Davy McKee	1984
ICI PLANTS				
Billingham	England	300		Onstream
Billingham	England	1200		Onstream

1.8.4 AIR SEPARATION PLANT

The type and size of air separation units selected for the Beluga complex are identical to operating units located in the Sasol facility in South Africa. The individual module has a capacity of 2500 STPD for production of 99.5% O₂. A recent survey of large air separation plants involving several hundred plant years of operation, indicates that the average plant on-stream factor is 98%.

There is considerable optimism in the air separation industry that a single train capacity of 5000 to 6000 STPD of O₂ is within the range of extension to existing technology. This would offer savings in the cost of oxygen production.

1.8.5 STEAM AND POWER GENERATION

The primary steam and power production facility for the Beluga plant will be a pulverized coal/char fired system with a steam turbine generation system. The aspect of char utilization when blended with raw coal has been demonstrated in the Winkler facilities in Mersberg, Wesseling, Neyveli and Kutahya. The ratio of raw coal to char for the Beluga project does not exceed the demonstrated successful combustion experience.

The possible application of fluidized bed combustion (FBC) is a consideration which will be explored prior to the final selection of boilers for this section. Proven FBC as applied to the Beluga complex could offer significant thermal efficiency and economic advantages.

SECTION 2.0
CONCEPTUAL DESIGN BASIS FOR PROCESS PLANT

2.1 GENERAL DESIGN CONSIDERATIONS

- 2.1.1 The coal-to-methanol process plant will be a grass roots facility including all required process and utility units. The overall plant area plan is shown on Drawing 5530-001-P-001, and mass and utility block flow diagrams are shown on drawings 5530-Y-001 and 5530-Y-002. (These drawings are inserted at the end of this Section 2.0).
- 2.1.2 The design capacity of the plant will be 2,550,000 tons per year (7500 tons per day and 340 days per year) of fuel grade methanol.
- 2.1.3 The Winkler gasification process and the ICI low pressure methanol synthesis process will be used.
- 2.1.4 The gasification units of the plant will operate at a pressure of four (4) atmospheres. One of these units will be so designed that it can be operated at either 4 or 10 atmospheres.
- 2.1.5 All gaseous and particulate emissions will be held within acceptable regulatory levels. Wastewater effluent will be minimized and treated to meet regulatory quality requirements.
- 2.1.6 Use of air coolers will be considered in process areas.
- 2.1.7 Use of cooling tower water will be the design basis for condensing turbine cooling water requirements. "Once-through" cooling water will be considered as an alternative.

2.2 SITE AND CLIMATIC DATA

- o Site Elevation: 225 ft.
- o Design Dry Bulb Temperature:
Summer, 62°F; Winter, -35°F extreme low
For Cooling Tower Design (5%, Summer):
Dry Bulb, 67°F
Wet Bulb, 59°F
- o Dew Point: Summer, 48°F; Winter, 5°F
- o Winds: Velocity, 110 mph max., 7 mph min.
Direction: Summer, S-SW; Winter, N-NE
- o Earthquake Code: 4
- o Ice and snow accumulation will be considered in design criteria.

2.3 RAW MATERIALS AND UTILITIES

2.3.1 "As Received" Coal

Will be delivered by rail, unloaded, blended (70% from Capps area and 30% from Chuitna area), and stored for process and boiler fuel.

		<u>Wt. %</u>
o	Size analysis: +6"	0
	-6" to +3/8"	85
	-3/8"	<u>15</u>
		100

2.3.2 Blended Coal

o	<u>Proximate Analysis</u>	<u>Wt. %</u>
	Moisture	23.90
	Ash	20.73
	Volatile	30.98
	Fixed Carbon	24.24
	Sulfur	<u>0.15</u>
		100.00

Higher Heating Value, Btu/lb. 12,409
(Dry, ash-free basis)

o	<u>Ultimate Analysis</u>	<u>Wt. % Dry Basis</u>
	Ash	27.24
	Carbon	53.23
	Hydrogen	3.92
	Nitrogen	0.70
	Oxygen	14.67
	Sulfur	0.20
	Chlorine	<u>0.04</u>
		100.00

2.3.3 Utility Coal

Coal for utility use will be supplied from primary crushers and screening operations. No drying will be required.
Size: -1 1/2" x 0.

2.3.4 Process Coal

Will be supplied from crushing and screening operations and dried to 8% moisture.

o	<u>Analysis</u>	<u>Wt.%</u>
	Carbon	48.97
	Hydrogen	3.61
	Sulfur	0.18
	Oxygen	13.50
	Nitrogen	0.64
	Moisture	8.00
	Ash	25.06
	Chlorine	<u>0.04</u>
		100.00

2.3.5 Water

Available from fresh water wells or surface water supplies.

2.3.6 Boiler Feed Water

Raw water will be treated to the quality specified by standard boiler codes for particular steam levels.

2.3.7 Oxygen

Supplied from the air separation plants.

- o Purity: 99.5% vol.
- o Temperature: 257°F
- o Pressure: 90 psia

2.3.8 Nitrogen

Available from the air separation plants.

- o Purity: 100% (10 ppm oxygen max.)

- o Temperature: Ambient
- o Pressure: 15 psia min.

2.3.9 Sulfuric Acid

2.3.10 Caustic (50% solution)

2.3.11 Lime

2.3.12 Start-up and Emergency Fuel

Fuel oil and natural gas will be used as required.

2.3.13 Start-up Steam

Will be available at two conditions:

- o Temperature: 338°F 950°F
- o Pressure: 115 psia 1270 psia

2.3.14 Steam Levels

High Pressure Superheated (Power generation)

- o Pressure: 1270 psia
- o Temperature: 950°F

High Pressure Superheated (Process)

- o Pressure: 870 psia
- o Temperature: 840°F

Medium Pressure

- o Pressure: 115 psia
- o Temperature: 338°F

Low Pressure

- o Pressure: 50 psia
- o Temperature: 298°F

2.3.15 Electric Power

Plant will be designed for utilization of gasification char in the boilers to generate steam for process steam turbines and electric power for the plant and supporting facilities.

169,000 Volts - 3 Phase - 60 Hz	Transmission
69,000 Volts - 3 Phase - 60 Hz	Subtransmission
13,800 Volts - 3 Phase - 60 Hz	Generation/Distribution for Plant
4,160 Volts - 3 Phase - 60 Hz	Plant Utilization
480 Volts - 3 Phase - 60 Hz	Plant Utilization

2.3.16 Vacuum Condensate

- o Pressure: 2 Hg" Absolute
- o Temperature: 100°F

Typical Analysis Concentration (MG/L)

<u>Parameter</u>	<u>#1 - Well Pad</u>
Bicarbonate	390.0
Calcium	89.0
Chloride	2.4
Copper	0.001
Fluoride	0.2
Iron	6.2
Lead	0.0
Magnesium	16.0
Manganese	1.1
Potassium	7.6
Silica	39.0
Sodium	13.0
Sulfate	2.2

Total Hardness 290.0
(as CaCO_3)

Corrosion Index 0.02

Me/L ($\text{Cl}^- = \text{SO}_4^{2-}$)

Me/L (Alkalinity as CaCO_3)

2.4 PRODUCT SPECIFICATIONS

2.4.1	<u>Fuel Grade Methanol</u>	<u>Wt. %</u>
o	Methanol and other alcohols	99.5 min.
o	Water Content	0.5 max.
o	Sodium Content	1 ppm max.

2.4.2 Federal Grade A Methanol (For Reference Only)

<u>Characteristics</u>			<u>Grade A Requirements</u>
o	Acetone and Aldehydes,	% max.	0.003
o	Acetone,	% max.	-----
o	Ethanol,	% max.	-----
o	Acidity (as Acetic Acid)	% max.	0.003
Appearance and hydrocarbons			Free of opalescence, suspended matter and sediment
Carbonisable substances, color			Not darker than color standard No. 30 of ASTM D1209, Platinum-Cobalt scale.
Color			Not darker than color standard No. 5 of ASTM D1209, Platinum-Cobalt scale.
Distillation Range			Not more than 1°C and shall include 64.6°C \pm 0.10°C at 760 mm.
Specific Gravity, max.			0.7928 @ 20°/20°C
Percent methanol by wt. min.			99.85
Nonvolatile content, gm/100 ml, max.			0.0010
Odor			Characteristics, non-residual
Permanganate			No discharge of color in 30 minutes
Water, percent max.			0.15

2.4.3 Sulfur

Sulfur will be available from the Sulfur Recovery unit as a flaked solid for sale or disposal.

Temperature: Ambient

2.4.4 Carbon Dioxide

CO₂ will be available for sale from the Selexol unit. The expected flow will be as follows:

	<u>% Vol.</u>
CO	0.08
CO ₂	99.45
H ₂	0.05
CH ₄	0.42
H ₂ S	1 ppm Vol
COS	58 ppm Vol
N ₂	<u>13 ppm Vol</u>
TOTAL	100.0

Total Lb Mols/Hr: 20,110.8

Pressure: 5 psig

Temperature: 50°F

2.5 Drawings

The following drawings will be found following Page 2/10:

5530-001-P-001 Process Overall Plant Area Plan

5530-Y-001 Mass Block Flow Diagram

5530-Y-002 Utility Block Flow Diagram

2.6 Overall Plant Area Plan

The numerical designations assigned to plant areas are as follows:

100 Areas

- 101 - Air Separation Plant
- 102 - Nitrogen/Plant Air System
- 103 - Cooling Water System and Distribution
- 104 - Railroad
- 105 - Chemical Storage
- 106 - Fuel Storage
- 107 - Dock

200 Areas

- 201 - Coal Receiving, Storage and Reclaim
- 202 - Coal Preparation
- 203 - Coal Dryers
- 204 - Process Coal Conveying
- 205 - Gasification, Gasification 10 ATM
- 206 - Waste Heat Recovery and Dry Cyclone
Waste Heat Recovery and Dry Cyclone 10 ATM
- 207 - Particulate Removal, Particulate Removal 10 ATM
- 208 - Gasification Char and Coal Dryer Particulate Settling and Filtration
- 209 - Raw Gas Compression
- 210 - Shift Conversion and COS Hydrolysis
- 211 - Acid Gas Removal
- 212 - Make-up Gas Compression
- 213 - Methanol Synthesis
- 214 - Methanol Distillation
- 215 - Product Storage and Pumping
- 216 - Dry Char System
- 218 - Ash System
- 219 - Reforming

300 Areas

- 300 - Power Plant
- 301 - Raw Water Treatment
- 302 - Boiler Feed Water System
- 305 - Plant Steam System
- 306 - Buildings and Major Maintenance Equipment
- 308 - Fire Water System
- 309 - Electrical Distribution


400 Areas

- 401 - Waste Water Treatment
- 404 - Relief and Flare System
- 405 - Sulfur Recovery


600 Areas

- 601 - Coal Facilities Capps Mine
- 602 - Coal Facilities Chuitna Mine

SCALE: 1" = 100'



NO.	DESCRIPTION	BY	CHK.	APPROVED	DATE	NO.	DESCRIPTION	BY	CHK.	APPROVED	DATE
1	UP DATED	HUS			1-18-84	1	ISSUED FOR FINAL REPORT	HUS			1/18/84
2	UP DATED	HUS			2-4-84						
3	UP DATED	GH			2-15-84						
4	UP DATED	GH			2-15-84						



LEGEND

100 AREAS

- 101 - AIR SEPARATION PLANT
- 102 - NITROGEN/PLANT AIR SYSTEM
- 103 - COOLING WATER SYSTEM DISTRIBUTION
- 104 - RAILROAD
- 105 - CHEMICAL STORAGE
- 106 - FUEL STORAGE

200 AREAS

- 201 - COAL RECEIVING, STORAGE & RECLAIM
- 202 - COAL PREPARATION
- 203 - COAL DRYERS
- 204 - PROCESS COAL CONVEYING
- 205 - GASIFICATION, GASIFICATION 10 ATM
- 206 - WASTE HEAT RECOVERY & DRY CYCLONE 10 ATM
- 207 - PARTICULATE REMOVAL, PART REMOVAL 10 ATM
- 208 - GASIFICATION CHAR & COAL DRYER PARTICULATE SETTLING & FILTRATION
- 209 - RAW GAS COMPRESSION
- 210 - SHIFT CONVERSION & CO2 HYDROLYSIS
- 211 - ACID GAS REMOVAL
- 212 - MAKE-UP GAS COMPRESSION
- 213 - METHANOL SYNTHESIS
- 214 - METHANOL DISTILLATION
- 215 - PRODUCT STORAGE & PUMPING
- 216 - DRY CHAR SYSTEM
- 218 - ASH SYSTEM
- 219 - REFORMING

300 AREAS

- 300 - POWER PLANT
- 301 - RAW WATER TREATMENT
- 302 - BOILER FEED WATER SYSTEM
- 303 - BUILDINGS & MAJOR MAINTENANCE EQUIPMENT
- 304 - FIRE WATER SYSTEM
- 305 - ELECTRICAL DISTRIBUTION

400 AREAS

- 401 - WASTE WATER TREATMENT
- 404 - RELIEF & FLARE SYSTEM
- 405 - SULFUR RECOVERY

- ROADS
- - - PIPEWAYS

NOTE: This print is the property of DAVY MCKEE CORPORATION. It must not be traced nor reproduced in any manner nor shall it be submitted to outside parties for examination without our consent. It shall be used only as a means of reference to work designed or furnished by us.

CLIENT
GRI/PLACER
BELUGA METHANOL PROJECT
COOK IN, ALASKA

Davy McKee
ENGINEERS AND CONSTRUCTORS
DAN 0012 Rev. 7/79

DESIGNED BY	DATE	DATE TO CLIENT	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T	U	V	W	X	Y	Z
DRAWN																												
CHECKED																												
APPROVED 1																												
APPROVED 2																												
APPROVED 3																												

TITLE
OVERALL PLANT AREA PLAN
SCALE: 1" = 200'
SHEET NO. 6


5530-001-P-001



1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44	45	46	47	48	49	50	51	52	53	54	55	56	57	58	59	60	61	62	63	64	65	66	67	68	69	70	71	72	73	74	75	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	93	94	95	96	97	98	99	100	101	102	103	104	105	106	107	108	109	110	111	112	113	114	115	116	117	118	119	120	121	122	123	124	125	126	127	128	129	130	131	132	133	134	135	136	137	138	139	140	141	142	143	144	145	146	147	148	149	150	151	152	153	154	155	156	157	158	159	160	161	162	163	164	165	166	167	168	169	170	171	172	173	174	175	176	177	178	179	180	181	182	183	184	185	186	187	188	189	190	191	192	193	194	195	196	197	198	199	200	201	202	203	204	205	206	207	208	209	210	211	212	213	214	215	216	217	218	219	220	221	222	223	224	225	226	227	228	229	230	231	232	233	234	235	236	237	238	239	240	241	242	243	244	245	246	247	248	249	250	251	252	253	254	255	256	257	258	259	260	261	262	263	264	265	266	267	268	269	270	271	272	273	274	275	276	277	278	279	280	281	282	283	284	285	286	287	288	289	290	291	292	293	294	295	296	297	298	299	300	301	302	303	304	305	306	307	308	309	310	311	312	313	314	315	316	317	318	319	320	321	322	323	324	325	326	327	328	329	330	331	332	333	334	335	336	337	338	339	340	341	342	343	344	345	346	347	348	349	350	351	352	353	354	355	356	357	358	359	360	361	362	363	364	365	366	367	368	369	370	371	372	373	374	375	376	377	378	379	380	381	382	383	384	385	386	387	388	389	390	391	392	393	394	395	396	397	398	399	400	401	402	403	404	405	406	407	408	409	410	411	412	413	414	415	416	417	418	419	420	421	422	423	424	425	426	427	428	429	430	431	432	433	434	435	436	437	438	439	440	441	442	443	444	445	446	447	448	449	450	451	452	453	454	455	456	457	458	459	460	461	462	463	464	465	466	467	468	469	470	471	472	473	474	475	476	477	478	479	480	481	482	483	484	485	486	487	488	489	490	491	492	493	494	495	496	497	498	499	500	501	502	503	504	505	506	507	508	509	510	511	512	513	514	515	516	517	518	519	520	521	522	523	524	525	526	527	528	529	530	531	532	533	534	535	536	537	538	539	540	541	542	543	544	545	546	547	548	549	550	551	552	553	554	555	556	557	558	559	560	561	562	563	564	565	566	567	568	569	570	571	572	573	574	575	576	577	578	579	580	581	582	583	584	585	586	587	588	589	590	591	592	593	594	595	596	597	598	599	600	601	602	603	604	605	606	607	608	609	610	611	612	613	614	615	616	617	618	619	620	621	622	623	624	625	626	627	628	629	630	631	632	633	634	635	636	637	638	639	640	641	642	643	644	645	646	647	648	649	650	651	652	653	654	655	656	657	658	659	660	661	662	663	664	665	666	667	668	669	670	671	672	673	674	675	676	677	678	679	680	681	682	683	684	685	686	687	688	689	690	691	692	693	694	695	696	697	698	699	700	701	702	703	704	705	706	707	708	709	710	711	712	713	714	715	716	717	718	719	720	721	722	723	724	725	726	727	728	729	730	731	732	733	734	735	736	737	738	739	740	741	742	743	744	745	746	747	748	749	750	751	752	753	754	755	756	757	758	759	760	761	762	763	764	765	766	767	768	769	770	771	772	773	774	775	776	777	778	779	780	781	782	783	784	785	786	787	788	789	790	791	792	793	794	795	796	797	798	799	800	801	802	803	804	805	806	807	808	809	810	811	812	813	814	815	816	817	818	819	820	821	822	823	824	825	826	827	828	829	830	831	832	833	834	835	836	837	838	839	840	841	842	843	844	845	846	847	848	849	850	851	852	853	854	855	856	857	858	859	860	861	862	863	864	865	866	867	868	869	870	871	872	873	874	875	876	877	878	879	880	881	882	883	884	885	886	887	888	889	890	891	892	893	894	895	896	897	898	899	900	901	902	903	904	905	906	907	908	909	910	911	912	913	914	915	916	917	918	919	920	921	922	923	924	925	926	927	928	929	930	931	932	933	934	935	936	937	938	939	940	941	942	943	944	945	946	947	948	949	950	951	952	953	954	955	956	957	958	959	960	961	962	963	964	965	966	967	968	969	970	971	972	973	974	975	976	977	978	979	980	981	982	983	984	985	986	987	988	989	990	991	992	993	994	995	996	997	998	999	1000	1001	1002	1003	1004	1005	1006	1007	1008	1009	1010	1011	1012	1013	1014	1015	1016	1017	1018	1019	1020	1021	1022	1023	1024	1025	1026	1027	1028	1029	1030	1031	1032	1033	1034	1035	1036	1037	1038	1039	1040	1041	1042	1043	1044	1045	1046	1047	1048	1049	1050	1051	1052	1053	1054	1055	1056	1057	1058	1059	1060	1061	1062	1063	1064	1065	1066	1067	1068	1069	1070	1071	1072	1073	1074	1075	1076	1077	1078	1079	1080	1081	1082	1083	1084	1085	1086	1087	1088	1089	1090	1091	1092	1093	1094	1095	1096	1097	1098	1099	1100	1101	1102	1103	1104	1105	1106	1107	1108	1109	1110	1111	1112	1113	1114	1115	1116	1117	1118	1119	1120	1121	1122	1123	1124	1125	1126	1127	1128	1129	1130	1131	1132	1133	1134	1135	1136	1137	1138	1139	1140	1141	1142	1143	1144	1145	1146	1147	1148	1149	1150	1151	1152	1153	1154	1155	1156	1157	1158	1159	1160	1161	1162	1163	1164	1165	1166	1167	1168	1169	1170	1171	1172	1173	1174	1175	1176	1177	1178	1179	1180	1181	1182	1183	1184	1185	1186	1187	1188	1189	1190	1191	1192	1193	1194	1195	1196	1197	1198	1199	1200	1201	1202	1203	1204	1205	1206	1207	1208	1209	1210	1211	1212	1213	1214	1215	1216	1217	1218	1219	1220	1221	1222	1223	1224	1225	1226	1227	1228	1229	1230	1231	1232	1233	1234	1235	1236	1237	1238	1239	1240	1241	1242	1243	1244	1245	1246	1247	1248	1249	1250	1251	1252	1253	1254	1255	1256	1257	1258	1259	1260	1261	1262	1263	1264	1265	1266	1267	1268	1269	1270	1271	1272	1273	1274	1275	1276	1277	1278	1279	1280	1281	1282	1283	1284	1285	1286	1287	1288	1289	1290	1291	1292	1293	1294	1295	1296	1297	1298	1299	1300	1301	1302	1303	1304	1305	1306	1307	1308	1309	1310	1311	1312	1313	1314	1315	1316	1317	1318	1319	1320	1321	1322	1323	1324	1325	1326	1327	1328	1329	1330	1331	1332	1333	1334	1335	1336	1337	1338	1339	1340	1341	1342	1343	1344	1345	1346	1347	1348	1349	1350	1351	1352	1353	1354	1355	1356	1357	1358	1359	1360	1361	1362	1363	1364	1365	1366	1367	1368	1369	1370	1371	1372	1373	1374	1375	1376	1377	1378	1379	1380	1381	1382	1383	1384	1385	1386	1387	1388	1389	1390	1391	1392	1393	1394	1395	1396	1397	1398	1399	1400	1401	1402	1403	1404	1405	1406	1407	1408	1409	1410	1411	1412	1413	1414	1415	1416	1417	1418	1419	1420	1421	1422	1423	1424	1425	1426	1427	1428	1429	1430	1431	1432	1433	1434	1435	1436	1437	1438	1439	1440	1441	1442	1443	1444	1445	1446	1447	1448	1449	1450	1451	1452	1453	1454	1455	1456	1457	1458	1459	1460	1461	1462	1463	1464	1465	1466	1467	1468	1469	1470	1471	1472	1473	1474	1475	1476	1477	1478	1479	1480	1481	1482	1483	1484	1485	1486	1487	1488	1489	1490	1491	1492	1493	1494	1495	14
---	---	---	---	---	---	---	---	---	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	----


PLANT UTILITY TABLE

UTILITY CODE		1	2	3	4	5	6	7	8	9	10	11	12
AREA		101	102	201, 202, 203, 204	205	206	207	208	209	210	211	212	213
COOLING WATER	CPM	80,060	850		920	300		62,310	82,980		16,370	15,370	75
ELECTRICITY	KW	24	5175	14,550	1910		155	2930	100	580	32,195	200	13
CONSUMED													
GENERATED													
STEAM USER	LB/HR												
1515 PSIA, 900°F													
1270 PSIA, 950°F		810,665											
870 PSIA, 840°F									929,779			184,320	117
115 PSIA, SAT.					535,006						57,620		
STEAM GENERATED	LB/HR												
1515 PSIA, 900°F													
1270 PSIA, 950°F													
870 PSIA, 840°F						1,222,512							
115 PSIA, SAT.						5937							
BAW REQUIRED	LB/HR					1,246,962				690,753			
AIR FOR COMBUSTION	SCFH			23,558,280									
NITROGEN	SCFH			27,000	447,911								
FUEL REQUIREMENTS													
NATURAL GAS	SCFH												
NO. 2 FUEL OIL	BAR/DAY												



NO.	DESCRIPTION	BY	CHK.	APPROVED	DATE	NO.	DESCRIPTION	BY	CHK.	APPROVED	DATE
1	ISSUED FOR FINAL REPORT					2					
3						4					
5						6					

11	12	13	14	15	16	17	18	19	20	21	22	23	24	25
218	213	214	215	216	218	219	405	301	302	300	103	404	401	308
18,370	7300	922				10,528	750			54,167	327,867			
200	1345	2995	4980	185	375	243	1570	520	2350	15,000	16,220		1089	410
						228,113				165,000				
184,320	117,000													
	64,314					492	155,523	116,350	38,411					
						236,700	(INCLUDES TOTAL PUMP STEAM TRAILING)			810,665				
						244,000				969,487				
						5,180,724				2,767,600				
					912,000					22,155,012				
												1000		
						128								



NOTE: This Print is the property of DAVY McKEE CORPORATION. It must not be traced nor reproduced in any manner nor shall it be submitted to outside parties for examination without our consent. It shall be used only as a means of reference to work designed or furnished by us.

CLIENT: CIRI / PLACER
BELUGA METHANOL PROJ.
COOK INLET, ALASKA

Davy McKee
ENGINEERS AND CONSTRUCTORS
200 West 5th Ave.

TITLE: UTILITY BLOCK
FLOW DIAGRAM

5530-Y-002



SCALE: NONE

DESIGNED BY	DATE	CHECKED BY	DATE	APPROVED BY	DATE
W.F.	2/11	W.F.	2/11	W.F.	2/11
W.F.	2/11	W.F.	2/11	W.F.	2/11
W.F.	2/11	W.F.	2/11	W.F.	2/11